



Convergent Technology Partners
6197 Miller Rd, Suite 4
Swartz Creek, MI 48473
810-720-3820
Fax 810-720-3886

E-mail: info@ctpartners.net
Website: www.ctpartners.net

ADDENDUM 1

Client / Address	Troy School District	Project / Location	Learning Center Paging
Date Issued	April 22, 2022	Project Number	

A1-1 NOTICE: The bid documents are amended herein which adds to and/or supersedes conflicting or additional information in the Request for Proposal.

1. Work covered by this Addendum shall be subject to the Introduction, Terms and Conditions and Technical Specifications.
2. Acknowledge this Addendum on the Cost Analysis Worksheet and include the cost of the work herein specified in the Bid.
3. **Notice:** The required electronic copies of the proposal must be in every way a duplicate of the hard copy. Provide the electronic copy in separate PDFs by tabular section as required by the hard copy. Failure to provide a duplicate of all information in both formats will be grounds for non-compliance and disqualification.

A1-2 Mandatory Pre-bid meeting notes

1. Reviewed Schedule of Events and SOW summary
2. Reviewed Instructions to Bidders and Bid Form
 - a. Bid due dates
 - i. Submit to the Owner as indicated in the RFP
 - ii. Bids open immediately after due date and time
 - b. Subcontractor requirements – one per discipline, noted on the bid form
 - c. RFP Communication and requests for clarification
 - i. Through Convergent Technology Partners, email only to designated email in the RFP.
 1. Note RFP Name in the subject line
 - ii. Bidders shall only communicate through Convergent Technology Partners and are not allowed to contact the Owner
 - d. Required documents to be included in the bid response:
 - i. Complete Bill of Material with installed unit pricing (Not Supplemental B – Unit Pricing)
 - ii. Bid Form and all Supplementals
 - e. Project manager must be assigned and is a management employee
3. Voluntary alternates will be accepted only after base bid requirements are met
4. Addenda will be posted to the Troy School District web site

5. Project review
 - a. Valcom IP6000 only
 - b. Proposals must be for a complete, 100%, turn-key, IP or Hybrid solution
 - c. Manufacturer must not have geographical or vender limitation
6. Walked the Building with bidders

A1-3 Specifications, Clarifications and Notes

1. Section 27 51 13 Page 9 of 12, Part 2.8.A.1 Angled Metal Wall Speaker - Change part number to S-504
2. Delete requirement for Section 27 51 13 Page 9 of 12, Part 2.9 (all- Free-standing rack)
 - a. Troy School District will rearrange equipment in existing rack for PA equipment
3. Building hours for work – during school year (end of June) 2:10PM – 4PM
 - a. July and August open to first shift work – no school
4. UPS backup is required for all components required for an operation paging system during power outages
5. Reuse of existing LV J-hooks (not fire alarm wiring) is acceptable, however bidders must make their own firewall penetrations and sealing after installation
6. Provide pricing for SIP connectivity as Mandatory Alternate 1

A1-4 Drawings

N/A

A1-2 Attachments

1. Sign in sheet

End of Addendum 1

NAME

REPRESENTING

TELEPHONE#

E-MAIL ADDRESS

ERIC HELSEL

Convergent Technology Partners

810-223-0531

ehelsel@ctpartners.netDana Boyd Ancora586 567 3504dboyd@ancoraminc.comRik Keeley HI-TECH810-326-9000 #222rkleeley@hitech.netSimon Earley MOSS616 291 4364simon.earley@mossintl.comWarren Neal TSU989-415-0090warren@tsu-inc.comBryan ScottTHE DATAVIEW GROUP517-699-5000bryan@dataviewgroup.comJohn AmosTHE RBB CON GROUP516-519-4813john@rbbcongroup.com