

Nick H. Barnard Architect LLC

697 W. 175 N., BLACKFOOT, ID 83221

E-MAIL: nhb@cableone.net

TEL: 208.242.6564

ADDENDUM NO. THREE

TO: Bidders

DATE: March 7, 2016

RE: Franklin Middle School Entry Vestibule Remodel
School District No. 25
2271 E. Terry
Pocatello, Idaho

This Addendum forms a part of the Contract Documents and modifies the original Bidding Drawings dated **February 2016**, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification. The following information is being issued to General Contractors only. It is the obligation of the Contractor to notify his Subcontractors and suppliers of items relating to their bids prior to bid opening. This Addendum consists of **1** page(s) and **no** drawing(s).

I - CHANGES TO PRIOR ADDENDA: NONE

II - CHANGES TO BIDDING REQUIREMENTS: NONE

III - CHANGES TO CONDITIONS OF THE CONTRACT: NONE

IV - CHANGES TO AGREEMENT & OTHER CONTRACT FORMS: NONE

V - CHANGES TO SPECIFICATIONS:

Item V-1. Section 07 5419, PVC Membrane Roofing. Change Article 1.6, A & B from 20 year to 10 year warranty (74 - 90 mph wind type).

Item V-2. Section 07 5419, PVC Membrane Roofing. Article 2.3, G, 1. Add traffic surface of 20 LF as directed by Architect.

VI - CHANGES TO DRAWINGS:

Item VI-1. Sheet A1.4, Floor Plan 2. Remove existing window in Conference and Office rooms and provide 2x4 framing 16" oc infill at window opening. Install two layers of 5/8" gypsum board over the interior (room side) surface -tape, texture and paint. Install R-19 insulation in wall cavity.

END of ADDENDUM