



POCATELLO/CHUBBUCK SCHOOL DISTRICT 25
LEARNING TODAY FOR THE POSSIBILITIES OF TOMORROW

**Administration Offices
3115 Pole Line Road
Pocatello, Idaho 83201**

Addendum No. 1

March 30, 2021

RE: Invitation to Bid, 2021 Reinforced Roofing Project

FROM: Business Services
(208) 235-3270

This Addendum No. 1 for clarification becomes a part of the Contract Documents and modifies the original Bidding Specifications, as noted below.

CLARIFICATION:

1. Overlay new roofing material over existing roof. Existing roof to be relief cut with no vapor barrier.
2. Install new 24 gage coping cap, drip edge and counter flashing.

Sealed bids for the 2021 Reinforced Roofing System to be opened on April 9, 2021 at 9:30 AM.

Acknowledge Addendum No 1 on the Bid Proposal, Page 1. Failure to acknowledge Addendum may subject the bidder to disqualification.

NO OTHER CHANGES
END OF ADDENDUM No.1 – March 30, 2021, rlb