



AQUA ENVIRONMENTAL LAB
56 Church Hill Road Newtown, CT 06470
A York Analytical Company



Report of Analysis

Name:	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	Sample ID#:	284187
Sample Date:	4/21/2022 10:20 AM	Sample Type:	Drinking Water
Receipt Date:	4/21/2022 3:00 PM	Sample Source:	PS017
Report Date:	4/27/2022	Sampler:	PD
Sample Site:	DISTRIBUTION SYSTEM	PWS ID:	CT0570212

Parameter	Sample Result	Units	Method	RL	Analysis Date	Analyst
Minerals Alkalinity	242	mg/L	SM 2320B (-97)	5	4/27/2022 12:23	KH

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected * = Above Specified Limit
--

Report Approved by:  CT Lic PH-0787 NY Lic 11706
Lab Director

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.