



# Mount Olive Township School District

*"Children are our first priority"*

**Larrie Reynolds, Ed.D.**  
**Superintendent of Schools**

(973) 691-4008 Extension 8100, [lreynolds@mtoliveboe.org](mailto:lreynolds@mtoliveboe.org)

227 US Route 206, Suite 10, Flanders, NJ 07836

Sept 1, 2017

Dear families of Mountain View:

I am writing to inform you that we are making progress remediating excessive lead in several faucets and sinks at Mountain View. In July, we discovered that 22 of the schools 80 sinks and faucets tested higher than 15 parts per billion for lead. We performed a first level intensity remediation and had the faucets re-tested. The remediation worked in 13 of these faucets. The other 9 faucets have not yet passed the state standard. As a result, the 9 faucets listed below have been turned off and shut down while we engage in a second more intense round of remediation.

Our more intense remedial efforts include permanently shutting off the faucet, replacing pipes, fixtures, drains, or other plumbing items, or replacing the whole water system from well to city water. Of the 9 failed faucets, only 3 are for potential drinking (ice maker). We plan to monitor the school's needs and replace with bottled water dispensers, if necessary.

### **Mt View (9 out of 22)**

<b>ID</b>	<b>Location</b>	<b>Outlet Type</b>	<b>Result (ppb)</b>
24-MVE-SF-K1T	Kitchen-1 Tub	Sink Faucet	40.3
30-MVE-SB-128	128	Sink Bubbler	29.0
31-MVE-SF-128	128	Sink Faucet	26.8
47-MVE-SB-118	118	Sink Bubbler	16.2
50-MVE-SF-115	115	Sink Faucet	16.5
51-MVE-SB-116	116	Sink Bubbler	24.6
52-MVE-SF-116	116	Sink Faucet	25.8
64-MVE-SF-106	106	Sink Faucet	34.9
72-MVE-SF-103	103	Sink Faucet	27.4

We appreciate your patience during our efforts to take care of this issue. We expect a re-test of all remediated items within a month and will report back our findings from that effort as soon as they are known.