



Mount Olive Township School District

"Children are our first priority"

Larrie Reynolds, Ed.D.
Superintendent of Schools

(973) 691-4008 Extension 8100, lreynolds@mtoliveboe.org

227 US Route 206, Suite 10, Flanders, NJ 07836

Sept 1, 2017

Dear families of MOMS:

I am writing to inform you that we are making progress remediating excessive lead in several faucets and sinks at MOMS. In July, we discovered that 14 of the schools 75 sinks and faucets tested higher than 15 parts per billion for lead. We performed a first level intensity remediation and had the faucets re-tested. The remediation worked in 6 of these faucets. The other 8 faucets have not yet passed the state standard. As a result, the 8 faucets listed below have been turned off and shut down while we engage in a second more intense round of remediation.

Our more intense remedial efforts include permanently shutting off the faucet, replacing pipes, fixtures, drains, or other plumbing items, or replacing the whole water system from well to city water. Of the 8 failed faucets, only 1 is for potential drinking (ice maker). We plan to monitor the school's needs and replace with bottled water dispensers, if necessary.

Middle School (8 out of 14)

ID	Location	Outlet Type	Result (ppb)
17-MOM-SF-DISHHW	Dish Wash Room-Hand Wash	Sink Faucet	107
18-MOM-FO-K	Kitchen-Kettle	Faucet Outlet	46.4
20-MOM-SFS-KST	Kitchen by Steamer Wall	Sink Faucet w/ Sprayer	16.0
21-MOM-SF-K1T-LONG	Kitchn-1 Tub Long Prep	Sink Faucet	17.3
28-MOM-SF-A145.1	A145-Snack Shack (Hand Wash)	Sink Faucet	27.2
29-MOM-SF-A145.2	A145-Snack Shack (1 Tub Prep)	Sink Faucet	24.6
31-MOM-IM-FACULTY1	1st Floor Faculty	Ice Machine	630
44B-MOM-SF-C157	C157	Sink Faucet	24.6

We appreciate your patience during our efforts to take care of this issue. We expect a re-test of all remediated items within a month and will report back our findings from that effort as soon as they are known.