



# Mount Olive Township School District

*"Children are our first priority"*

**Larrie Reynolds, Ed.D.**  
**Superintendent of Schools**

(973) 691-4008 Extension 8100, [lreynolds@mtoliveboe.org](mailto:lreynolds@mtoliveboe.org)

227 US Route 206, Suite 10, Flanders, NJ 07836

Sept 1, 2017

Dear families of MOHS:

I am writing to inform you that we are making progress remediating excessive lead in several faucets and sinks at MOHS. In July, we discovered that 21 of the schools 65 sinks and faucets tested higher than 15 parts per billion for lead. We performed a first level intensity remediation and had the faucets re-tested. The remediation worked in 13 of these faucets. The other 8 faucets have not yet passed the state standard. As a result, the 8 faucets listed below have been turned off and shut down while we engage in a second more intense round of remediation.

Our more intense remedial efforts include permanently shutting off the faucet, replacing pipes, fixtures, drains, or other plumbing items, or replacing the whole water system from well to city water. Of the 8 failed faucets, only 2 are for potential drinking. We plan to monitor the school's needs and replace with bottled water dispensers, if necessary.

### **High School (8 out of 21)**

<b>ID</b>	<b>Location</b>	<b>Outlet Type</b>	<b>Result (ppb)</b>
4-MHS-SF-B21	B21-Fitness Rm	Sink Faucet	16.5
18-MHS-SF-B37.6	B37 (Large Rm)	Sink Faucet	16.8
27-MHS-SF-SERVE1T	Serving Area-1 Tub (Small)	Sink Faucet	29.4
32-MHS-FO-K	Kitchen-Kettle	Faucet Outlet	31.8
39-MHS-SF-SNACK	Serving Area Snack Bar	Sink Faucet	18.0
40-MHS-SF-C100B	C100B-Snack Bar	Sink Faucet	18.5
44-MHS-SB-EXAM	Nurse's Exam	Sink Bubbler	23.4
49-MHS-DW-GIRLS	Girls' Locker Rm	Drinking Water Bubbler	93.5

We appreciate your patience during our efforts to take care of this issue. We expect a re-test of all remediated items within a month and will report back our findings from that effort as soon as they are known.