



**Office of Environmental Public Health Sciences  
Washington State Department of Health  
243 Israel Road SE, Tumwater WA 98501**

**Lead Sample Collection Information**

**DISCLAIMER: Results posted here only represent testing done by the Washington State Department of Health for the 2018-19 lead in school drinking water program. Schools have been provided these results, along with recommendations for remediation if applicable. Please contact your school to find out more about this and other testing they may have done, as well as plans for remediation.**

**Name of Sampler:** Lisa Christensen  
**Date Collected:** 10/05/2018  
**School Name:** South Whidbey Elementary  
**School Code:** 4321  
**School District Name:** South Whidbey  
**Address:** 5380 Maxwellton Rd, Langley WA 98260  
**County:** Island  
**Number of Samples Collected:** 62  
**School Point of Contact:** JJ Leuenberger  
**Title of POC:** Director of Custodial and Maintenance Services  
**Email of POC:** jleuenberger@sw.wednet.edu  
**POC Phone Number:** 360-221-6808  
**Date sent to State Lab:** 10/05/2018  
**Date Received by Lab:**  
**Shipment Tracking Number:** Hand Delivered 10/05/18

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
1.	14676	First Draw	Tap	Kitchen	3	10/09/2018	6:35AM, Sink by Oven, Used by Staff Member
2.	14719	First Draw	Tap	Kitchen	<1	10/09/2018	Tap occasionally used for food prep
3.	14720	First Draw	Bubbler	Room 206	21	10/09/2018	
4.	14721	First Draw	Tap	Room 206	11	10/09/2018	No aerator
5.	14722	First Draw	Bubbler	Room 205	9	10/09/2018	
6.	14723	First Draw	Tap	Room 205	12	10/09/2018	
7.	14724	First Draw	Bubbler	Room 204	17	10/09/2018	No aerator
8.	14725	First Draw	Tap	Room 204	17	10/09/2018	No aerator
9.	14726	First Draw	Bubbler	Room 203	TB		Cloudy Water
10.	14727	First Draw	Tap	Room 203	TB		
11.	14728	First Draw	Bubbler	Gym	5	10/09/2018	
12.	14729	First Draw	Tap	Community Room	TB		PE Room for Students
13.	14730	First Draw	Bubbler	Room 212	20	10/09/2018	
14.	14731	First Draw	Tap	Room 212	21	10/09/2018	No aerator
15.	14732	First Draw	Bubbler	Music Room	21	10/09/2018	
16.	14733	First Draw	Tap	Music Room	TB		
17.	14734	First Draw	Bubbler	Room 211	12	10/09/2018	
18.	14735	First Draw	Tap	Room 212	10	10/09/2018	No aerator

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
19.	14736	First Draw	Bubbler	Room 210	11	10/09/2018	
20.	14737	First Draw	Tap	Room 210	11	10/09/2018	Tap Drips
21.	14738	First Draw	Bubbler	Across from 210 near bathrooms	6	10/09/2018	
22.	14739	First Draw	Bubbler	Room 209	11	10/09/2018	
23.	14740	First Draw	Tap	Room 209	25	10/09/2018	
24.	14741	First Draw	Bubbler	Room 208	9	10/09/2018	
25.	14742	First Draw	Tap	Room 208	32	10/09/2018	
26.	14743	First Draw	Bubbler	Room 207	9	10/09/2018	
27.	14744	First Draw	Tap	Room 207	12	10/09/2018	
28.	14745	First Draw	Bubbler	Room 202	TB		
29.	14746	First Draw	Tap	Room 202	TB		
30.	14747	First Draw	Bubbler	Room 201	26	10/09/2018	
31.	14748	First Draw	Tap	Room 201	16	10/09/2018	
32.	14749	First Draw	Bubbler	By Front Entrance	<1	10/09/2018	
33.	14750	First Draw	Bottle Filler	By Front Entrance	<1	10/09/2018	
34.	14751	First Draw	Tap	Nurse's Station	TB		
35.	14752	First Draw	Bubbler	South Wing Drinking Fountain	6	10/09/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
36.	14753	First Draw	Bubbler	Room 101	8	10/09/2018	
37.	14754	First Draw	Tap	Room 101	4	10/09/2018	
38.	14755	First Draw	Bubbler	Room 102	17	10/09/2018	
39.	14756	First Draw	Tap	Room 102	2	10/09/2018	
40.	14757	First Draw	Bubbler	Room 105	12	10/09/2018	
41.	14758	First Draw	Tap	Room 105	16	10/09/2018	
42.	14759	First Draw	Bubbler	Room 106	8	10/09/2018	
43.	14760	First Draw	Tap	Room 106	2	10/09/2018	
44.	14761	First Draw	Bubbler	Room 107	14	10/09/2018	
45.	14762	First Draw	Tap	Room 107	13	10/09/2018	No aerator
46.	14763	First Draw	Bubbler	Room 108	10	10/09/2018	
47.	14764	First Draw	Tap	Room 108	7	10/09/2018	
48.	14765	First Draw	Bubbler	Across from Room 108	7	10/09/2018	
49.	14766	First Draw	Bubbler	Room 109	6	10/09/2018	
50.	14767	First Draw	Tap	Room 109	12	10/09/2018	
51.	14768	First Draw	Bubbler	Room 110	7	10/09/2018	
52.	14769	First Draw	Tap	Room 110	1	10/09/2018	
53.	14770	First Draw	Bubbler	Room 111	9	10/09/2018	
54.	14771	First Draw	Tap	Room 111	8	10/09/2018	

Sample number	Sample ID	Sample Type	Fixture Description	Fixture Location	Lead Content (ppb)	Date of Analysis	Notes/Comments
55.	14772	First Draw	Bubbler	Room 112	14	10/09/2018	
56.	14773	First Draw	Tap	Room 112	9	10/09/2018	
57.	14774	First Draw	Bubbler	Room 114	5	10/09/2018	
58.	14775	First Draw	Tap	Room 114	5	10/09/2018	
59.	14776	First Draw	Bubbler	Room 115	7	10/09/2018	
60.	14777	First Draw		Room 115	14	10/09/2018	No aerator
61.	14778				<1	10/09/2018	04250, near front entrance
62.	14779	First Draw	Tap	Kitchen in Portable	<1	10/09/2018	Used to wash food