

# Patuxent High School

## 2021-2022 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 5.5 ppb AL?
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	1a	DF	Bottle Filler in Lobby	FD	4/4/2022	7:30pm	4/5/2022	5:45am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	5a	DF	bottle filler outside 265	FD	4/4/2022	7:30pm	4/5/2022	6:10am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	13a	DF	bottle filler outside G05	FD	4/4/2022	7:30pm	4/5/2022	6:14am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	3	19a	DF	bottle filler fountain outside 344	FD	4/4/2022	7:30pm	4/5/2022	5:51am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	28a	DF	bottle filler outside 142	FD	4/4/2022	7:30pm	4/5/2022	5:53am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	32a	DF	bottle filler in 216	FD	4/4/2022	7:30pm	4/5/2022	5:50am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	34	CR	cold faucet in 207	FD	4/4/2022	7:30pm	4/5/2022	6:04am	4/18/2022	<b>25.7</b>	yes

Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	35	KS	cold faucet in concession stand	FD	4/4/2022	7:30pm	4/5/2022	5:46am	4/18/2022	1.2	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	36	KS	dish washer sprayer	FD	4/4/2022	7:30pm	4/5/2022	5:41am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	37	KS	sprayer by handwash sink	FD	4/4/2022	7:30pm	4/5/2022	5:41am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	38	KS	left cold faucet 3 compartment sink	FD	4/4/2022	7:30pm	4/5/2022	5:30am	4/18/2022	3.6	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	39	KS	right cold faucet 3 compartment sink	FD	4/4/2022	7:30pm	4/5/2022	5:30am	4/18/2022	2.2	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	40	KS	cold faucet on food prep table	FD	4/4/2022	7:30pm	4/5/2022	5:31am	4/18/2022	2.6	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	41	KS	sprayer by walk ins	FD	4/4/2022	7:30pm	4/5/2022	5:33am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	42	KS	cold faucet on 2 compartment sink	FD	4/4/2022	7:30pm	4/5/2022	5:34am	4/18/2022	1.3	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	43	KS	sprayer by ice machine	FD	4/4/2022	7:30pm	4/5/2022	5:34am	4/18/2022	<1.0	no
Water Testing	Patuxent High School	4/18/2022	2	44	IM	ice machine	FD	4/4/2022	7:30pm	4/5/2022	5:35am	4/18/2022	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	45	KS	cold faucet on food prep table by walk ins	FD	4/4/2022	7:30pm	4/5/2022	5:37am	4/18/2022	2.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	46	KS	dual kettle filler	FD	4/4/2022	7:30pm	4/5/2022	5:37am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	47	CR	cold faucet 274	FD	4/4/2022	7:30pm	4/5/2022	6:04am	4/18/2022	<b>11.7</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	48	CR	cold faucet 284	FD	4/4/2022	7:30pm	4/5/2022	6:08am	4/18/2022	<b>25.3</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	49	CR	cold faucet 285	FD	4/4/2022	7:30pm	4/5/2022	6:08am	4/18/2022	<b>76.9</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	50	CR	cold faucet 299	FD	4/4/2022	7:30pm	4/5/2022	6:02am	4/18/2022	<b>30.0</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	52	CR	cold faucet 216	FD	4/4/2022	7:30pm	4/5/2022	5:52am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	53	IM	fridge ice machine 216	FD	4/4/2022	7:30pm	4/5/2022	5:52am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	54	IM	ice machine 216	FD	4/4/2022	7:30pm	4/5/2022	5:53am	4/18/2022	<1.0	no

Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	55	CR	cold faucet 228	FD	4/4/2022	7:30pm	4/5/2022	5:56am	4/18/2022	<b>18.1</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	56	CR	cold faucet 229	FD	4/4/2022	7:30pm	4/5/2022	5:58am	4/18/2022	1.2	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	57	IM	ice machine 239	FD	4/4/2022	7:30pm	4/5/2022	5:58am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	3	58	CR	cold faucet 343	FD	4/4/2022	7:30pm	4/5/2022	5:46am	4/18/2022	<b>35.0</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	59	CR	cold faucet 104	FD	4/4/2022	7:30pm	4/5/2022	5:37am	4/18/2022	<b>8.2</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	60	CR	cold faucet 106	FD	4/4/2022	7:30pm	4/5/2022	5:37am	4/18/2022	<b>29.6</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	61	HE	front left cold faucet 112	FD	4/4/2022	7:30pm	4/5/2022	5:38am	4/18/2022	<b>24.8</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	62	HE	back left cold faucet 112	FD	4/4/2022	7:30pm	4/5/2022	5:38am	4/18/2022	<b>9.6</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	63	HE	middle left cold faucet 112	FD	4/4/2022	7:30pm	4/5/2022	5:39am	4/18/2022	3.3	no
Water Testing	Patuxent High School	4/18/2022	1	64	HE	middle right cold faucet 112	FD	4/4/2022	7:30pm	4/5/2022	5:39am	4/18/2022	<b>11.1</b>	yes

Laboratory of MD														
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	65	HE	back right cold faucet 112	FD	4/4/2022	7:30pm	4/5/2022	5:39am	4/18/2022	<b>26.7</b>	Yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	66	HE	front right cold faucet 112	FD	4/4/2022	7:30pm	4/5/2022	5:39am	4/18/2022	<b>20.6</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	67	TL	teacher cold faucet 112	FD	4/4/2022	7:30pm	4/5/2022	5:39am	4/18/2022	3.1	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	68	CR	left cold faucet 118	FD	4/4/2022	7:30pm	4/5/2022	5:35am	4/18/2022	<b>7.8</b>	Yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	69	CR	right cold faucet 118	FD	4/4/2022	7:30pm	4/5/2022	5:35am	4/18/2022	<b>6.5</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	70	CR	left cold faucet 120	FD	4/4/2022	7:30pm	4/5/2022	5:33am	4/18/2022	3.9	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	71	CR	right cold faucet 120	FD	4/4/2022	7:30pm	4/5/2022	5:33am	4/18/2022	<b>8.5</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	73	KS	3 compartment sink in Concession Stand	FD	4/4/2022	7:30pm	4/5/2022	6:34am	4/18/2022	<1.0	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	1	74	KS	sink in concession stand	FD	4/4/2022	7:30pm	4/5/2022	6:34am	4/18/2022	<1.0	no

Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	75	CR	Back Left cold faucet in Training Room	FD	4/4/2022	7:30pm	4/5/2022	6:17am	4/18/2022	<b>19.8</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	76	CR	Back Right cold faucet in Training Room	FD	4/4/2022	7:30pm	4/5/2022	6:17am	4/18/2022	3.5	no
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	77	CR	Front Right cold faucet in Training Room	FD	4/4/2022	7:30pm	4/5/2022	6:18am	4/18/2022	<b>6.1</b>	yes
Water Testing Laboratory of MD	Patuxent High School	4/18/2022	2	78	IM	Ice Machine in Training Room	FD	4/4/2022	7:30pm	4/5/2022	6:18am	4/18/2022	<1.0	no