



Assessment Results Exceedance Table

Of the 79 samples collected at Mamaroneck Avenue Elementary School, 2 (2.5%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Mamaroneck Avenue Elementary School - White Plains City School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/6/2021	01-106-CF-P-22	1	Class 106, CF 22	33
4/6/2021	02-215-CF-P-41	2	Class 215, CF 41	64.5