



Assessment Results Exceedance Table

Of the 57 samples collected at Post Road Elementary School, 1 (1.8%) had lead concentration that exceeded 15 ppb. The table below details the sample location and the laboratory result.

Post Road Elementary School - White Plains City School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/7/2021	01-Kitchen-KF-P-02	Ground	Kitchen, Pot filler, KF 2	23.4