



### Assessment Results Exceedance Table

Of the 42 samples collected at Eastview Middle School, 5 (11.9%) had lead concentrations that exceeded 15 ppb. The table below details the sample locations and the laboratory results.

Eastview Middle School - White Plans City School District				
Date	Sample ID	Floor	Location	Lead Level (ppb)
4/7/2021	001-125-BF-P-03	1	PT room 125, BF 03	17.8
4/7/2021	LL-LOCKER-BF-P-11	Lower Locker	Boys locker room bathroom, Left center, BF 11	150
4/7/2021	LL-LOCKER-BF-P-12	Lower Locker	Boys locker room bathroom, Right center, BF 12	30.5
4/7/2021	LL-LOCKER-BF-P-13	Lower Locker	Boys locker room bathroom, Right, BF 13	45
4/7/2021	LL-LOWER-BF-P-14	Lower Locker	Girls bathroom, BF 14	81.6