

Church Street Elementary School - White Plains City School District							
School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
001-CAFE-KF-P-05	Cafeteria, Steam tray faucet left, KF 05	Kitchen Faucet	Initial	1540	Put up signage/Not accesible for drinking	N/A	
001-CAFE-KF-P-06	Cafeteria, Steam tray faucet right, KF 06	Kitchen Faucet	Initial	151	Put up signage/Not accesible for drinking	N/A	
002-120-CF-P-34	Classroom 120, CF 34	Classroom Faucet	Initial	150	Tempered Outlets/Put up Signage	N/A	
002-123-CF-P-38	Classroom 123, CF 38	Classroom Faucet	Initial	91.1	Tempered Outlets/Put up Signage	N/A	
002-GIRLS-BF-P-18	Girls bathroom at 125, Left, BF 18	Bathroom Faucet	Initial	47.2	Tempered Outlets/Put up Signage	N/A	
02-126-BF-P-20	Classroom 126, BF 20	Bathroom Faucet	Initial	18.1	Tempered Outlets/Put up Signage	N/A	
02-133-BF-P-27	Classroom 133, BF 27	Bathroom Faucet	Initial	70.6	Tempered Outlets/Put up Signage	N/A	

Eastview Middle School - White Plains City School District							
School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
001-125-BF-P-03	PT room 125, BF 03	Bathroom Faucet	Initial	17.8	Tempered Outlets/Put up Signage	N/A	
LL-LOCKER-BF-P-11	Boys locker room bathroom, Left center, BF 11	Bathroom Faucet	Initial	150	Tempered Outlets/Put up Signage	N/A	
LL-LOCKER-BF-P-12	Boys locker room bathroom, Right center, BF 12	Bathroom Faucet	Initial	30.5	Tempered Outlets/Put up Signage	N/A	
LL-LOCKER-BF-P-13	Boys locker room bathroom, Right, BF 13	Bathroom Faucet	Initial	45	Tempered Outlets/Put up Signage	N/A	
LL-LOWER-BF-P-14	Girls bathroom, BF 14	Bathroom Faucet	Initial	81.6	Tempered Outlets/Put up Signage	N/A	

George Washington Elementary School - White Plains City School District							
School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
001-116-CF-P-01	Multipurpose room 116, CF 01	Classroom Faucet	Initial	53	POU filter and Resample	Post	ND
001-101-BF-P-10	Classroom 101, BF 10	Bathroom Faucet	Initial	46.4	Tempered Outlets/Put up Signage	N/A	
001-PE-BF-P-13	PE office, BF 13	Bathroom Faucet	Initial	58.5	Tempered Outlets/Put up Signage	N/A	
001-KIT-KF-P-02	Kitchen, Handwash sink, KF 02	Kitchen Faucet	Initial	83.5	Tempered Outlets/Put up Signage	N/A	
001-CAFE-KF-P-06	Cafeteria, Server tray outlet, KF 06	Kitchen Faucet	Initial	72	Put up signage/Not accesible for drinking	N/A	
002-223-CF-P-18	Classroom 223, CF 18	Classroom Faucet	Initial	415	POU filter and Resample	Post	ND
002-236-BF-P-34	Boys room 236, Right, BF 34	Bathroom Faucet	Initial	32.6	Tempered Outlets/Put up Signage	N/A	
002-240-CF-P-21	Classroom 240, CF 21	Classroom Faucet	Initial	38	Tempered Outlets/Put up Signage	N/A	
002-242-CF-P-22	Classroom 242, CF 22	Classroom Faucet	Initial	595	Tempered Outlets/Put up Signage	N/A	
002-248-CF-P-24	Classroom 248, CF 24	Classroom Faucet	Initial	23.6	Tempered Outlets/Put up Signage	N/A	
002-323-CF-P-35	Classroom 323, CF 35	Classroom Faucet	Initial	19	POU filter and Resample	Post	ND

Highland Middle School - White Plains City School District

School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
001-129-KF-P-04	Kitchen 129, Pot filler, KF 04	Kitchen Faucet	Initial	24.6	POU filter and Resample	Post	ND

Mamaroneck Avenue Elementary School - White Plains City School District

School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
01-106-CF-P-22	Class 106, CF 22	Classroom Faucet	Initial	33	Tempered Outlets/Put up Signage	N/A	
02-215-CF-P-41	Class 215, CF 41	Classroom Faucet	Initial	64.5	Tempered Outlets/Put up Signage	N/A	

Post Road Elementary School - White Plains City School District

School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
01-Kitchen-KF-P-02	Kitchen, Pot filler, KF 2	Kitchen Faucet	Initial	23.4	POU filter and Resample	Post	ND

Ridgeway Elementary School - White Plains City School District

School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
01-Kitchen-KF-P-02	Kitchen, Pot filler, KF 2	Kitchen Faucet	Initial	26.1	POU filter and Resample	Post	10.5
01-140-CF-P-13	Class 140, Sink by windows, CF 13	Classroom Faucet	Initial	18.9	Tempered Outlets/Put up Signage	N/A	
01-106-BF-P-13	Class 106, BF 13	Bathroom Faucet	Initial	19.1	Tempered Outlets/Put up Signage	N/A	
01-103-CF-P-39	Class 103, CF 39	Classroom Faucet	Initial	47.6	Tempered Outlets/Put up Signage	N/A	

Rochambeau High School - White Plains City School District

School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
02-Nurse-NS-P-03	Nurses office, 205C, NS 3	Nurses Sink	Initial	82.7	Tempered Outlets/Put up Signage	N/A	
03-Girls-BF-P-21	Girls bathroom by 322, BF 21 (left)	Bathroom Faucet	Initial	58.5	Tempered Outlets/Put up Signage	N/A	

03-Hall-WB-P-07	Hall by 322, WB 7	Water Bottle Filler	Initial	57.9	Change filter/Resample	Post	ND
00-B-BF-P-24	Classroom B, BF 24	Bathroom Faucet	Initial	49.3	Tempered Outlets/Put up Signage	N/A	

White Plains High School - White Plains School District

School Sample ID#	Sample Location	Outlet Description	Initial/Post Remediation	Lead Result ug/L (ppb)	Recommended Remediation Action	Post Remediation	Lead Result ug/L (ppb)
002-E211-BF-P-04	Boys Locker Room, E-211, BF 04	Bathroom Faucet	Initial	15.9	Tempered Outlets/Put up Signage	N/A	
G-E16-BF-P-09	Bathroom next to Girls Locker E-16, BF 09	Bathroom Faucet	Initial	378	Tempered Outlets/Put up Signage	N/A	
G-Girls-BF-P-10	Girls Pool Locker, BF 10	Bathroom Faucet	Initial	21.1	Tempered Outlets/Put up Signage	N/A	
G-Kit-KF-P-04	H Cafeteria Kitchen, Pot filler on column, KF 04	Kitchen Faucet	Initial	36.7	POU filter and Resample	Post	1.35