

# EHC ASSOCIATES

ENVIRONMENTAL CONSULTANTS & ABATEMENT CONTRACTORS

February 7, 2022

PA HIC #195

Mr. Glenn Davis  
c/o Lampeter-Strasburg School District  
1600 Book Road, P.O. Box 428  
Lampeter, PA 17537

Re: Lead in Water Testing Services - 2022  
Lampeter-Strasburg School District  
EHC Project No. 008735-006.2

Dear Mr. Davis:

Please review the enclosed analytical report in regard to the water samples collected from the Lampeter-Strasburg School District on January 27, 2022. The samples were analyzed for lead content by Suburban Test Laboratory using the EPA 200 Method. The following provides a summary of the results:

## LAMPETER-STRASBURG HIGH SCHOOL

<u>Sample Number/Sample Location</u>	<u>Results</u>
#1 Food Service Sink	<0.001mg/L
#2 Grand Hall Cafeteria Bottle Filler	<0.001 mg/L
#3 Nurse's Bottle Filler	<0.001 mg/L
#4 Main Office – Bottle Filler	<0.001 mg/L
#5 Room 229 – Old Fountain	<0.001 mg/L

## MARTIN MEYLIN MIDDLE SCHOOL

<u>Sample Number/Sample Location</u>	<u>Results</u>
#6 Kitchen Food Washing Sink	< 0.001 mg/L
#7 Cafeteria Bottle Filler	< 0.001 mg/L
#8 Media Center Bottle Filler	< 0.001 mg/L
#9 Room 20 – Fountain	0.008 mg/L
#10 Room 34 Sink	0.006 mg/L

2502 HORSESHOE ROAD, LANCASTER, PA 17601 ♦ 717-656-3008 ♦ FAX: 717-656-7134  
EMAIL: [OFFICE@EHCASSOCIATES.COM](mailto:OFFICE@EHCASSOCIATES.COM) ♦ [WWW.EHCASSOCIATES.COM](http://WWW.EHCASSOCIATES.COM)

Environmental Design • Consulting • Surveys • IAQ • Monitoring • Abatement & Demolition  
Specializing in the removal of Asbestos, Lead, Mold and other hazards in the built environment.

### HANS HERR ELEMENTARY SCHOOL

<u>Sample Number/Sample Location</u>	<u>Results</u>
#11 Kitchen Hand Sink	< 0.001 mg/L
#12 Kitchen Bathroom Sink	< 0.001 mg/L
#13 Kitchen 3-Bay Sink	< 0.001 mg/L
#14 Cafeteria Bottle Filler	< 0.001 mg/L
#15 Faculty Room Sink	< 0.001 mg/L

### LAMPETER ELEMENTARY SCHOOL

<u>Sample Number/Sample Location</u>	<u>Results</u>
#16 Main Office Sink	< 0.001 mg/L
#17 Nurse's Office Sink	< 0.001 mg/L
#18 Nurse's Bottle Filler	< 0.001 mg/L
#19 Music Room Sink	0.001 mg/L
#20 Cafeteria Bottle Filler	< 0.001 mg/L

Laboratory analysis indicates **the water samples collected from all of the above locations are below the recommended action level of 0.015 mg/L.**

Please review the enclosed analytical report and contact our office with questions, or if further information is needed.

Sincerely,



Mark Andrechik  
Inspector

Encl.'s: Laboratory Analysis Report  
Invoice No.: 008735-006.2



## Drinking Water Results Report

Order ID: 2A05298

EHC Associates, Inc.  
2502 Horseshoe Road  
Lancaster, PA 17601

Attn: Barb King

Project: LS- Lead in Water Testing  
LS High School

PWSID:

Sample Number: 2A05298-01

Site: 1- Food Service- Sink

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:06 MKR

Sample Number: 2A05298-02

Site: 2- Grand Hall Cafeteria Bottle Filler

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:03 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:27 MKR

Sample Number: 2A05298-03

Site: 3- Nurses- Bottle Filler

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:05 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:29 MKR

Sample Number: 2A05298-04

Site: 4- Main Office- Bottle Filler

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:07 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:30 MKR

Sample Number: 2A05298-05

Site: 5- Rm 229- Old Fountain

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:10 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:32 MKR

Report Generated On: 02/07/2022 2:42 pm  
STL\_DW\_Results Revision #1.7

2A05298  
Effective: 07/09/2014





**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Ryan F Knerr  
Project Manager II

Report Generated On: 02/07/2022 2:42 pm 2A05298  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014





2A05298  
Ryan F Knerr

TAT(Check One):  Standard  24hr  48hr  72hr  Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: EHC Associates  
Address: 2502 Horseshoe Road  
Lancaster, PA 17601  
Phone: 717-656-3008  
Email: labresults@ehcassociates.com  
Contact Name: Mark Andrechik  
P.O. Info: 008735-006.2

Project Name: LS - Lead in Water Testing  
Address: LS High School  
Regulatory ID (SDWA/Permit #): \_\_\_\_\_

Comments:

Standard TAT

sample pickup, standard X

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
(5) 250ml P X = + 30 drops of HNO <sub>3</sub> added at 20101-27-22 CB; PhL2 (SIF0339)												
X	1- Food service - Sink	1/27/22	0600	MA	1st Draw - Lead in Water	1		G	P			
X	2- Grand Hall Cafeteria <sup>Bottle Filler</sup>		0603									
X	3- Nurses - Bottle Filler		0605									
X	4- Main office - Bottle Filler		0607									
X	5- Rm 229 - Old Fountain		0610									

Relinquished By:	Count: _____	Date: <u>1/27</u>	Temp °C: _____	Sample Conditions	Matrix Key	Bottle Type Key	
Received By:	5	Date: <u>1/27/22</u>	Temp °C: <u>13.5</u>	Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	NPW = Non-Potable Water	P = Plastic	
Relinquished By:		Date: <u>1/27/22</u>	Temp °C: <u>12.1</u>	Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	G = Glass	PP = Sterile Polypropylene
Received in Lab By: <u>CB</u>	5	Date: <u>1-27-22</u>	Temp °C: <u>12.1</u>	All containers in tact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	PW = Potable Water (not for SDWA compliance)	GA = Glass Amber	PS = Sterile Polystyrene
		Date: <u>1228</u>	Temp °C: <u>12.1</u>	Tests within holding times? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	SDWA = Safe Drinking Water Act Potable Sample	VOA = 40mL G or GA	HDPE = High Density Polyethylene
		Date: <u>1228</u>	Temp °C: <u>12.1</u>	40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Sample Type Key	Preservative Key	
					G = Grab	A = Ascorbic Acid	OH = NaOH
					C = Composite	C = HCl	S = H <sub>2</sub> SO <sub>4</sub>
					8HC = 8 Hr. Composite	H = HNO <sub>3</sub>	O = Other
					24HC = 24 Hr. Composite	N = Sodium Thiosulfate	NA = None Required

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.











### Drinking Water Results Report

Order ID: 2A05300

EHC Associates, Inc.  
2502 Horseshoe Road  
Lancaster, PA 17601

Attn: Barb King

Project: LS- Lead in Water Testing  
Herr Elementary

PWSID:

Sample Number: 2A05300-01

Site: 11- Kitchen- Hand Sink

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:38 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:46 MKR

Sample Number: 2A05300-02

Site: 12- Kitchen Bathroom Sink

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:39 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:48 MKR

Sample Number: 2A05300-03

Site: 13- Kitchen- 3-Bay Sink

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:40 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:49 MKR

Sample Number: 2A05300-04

Site: 14- Cafeteria- Bottle Filler

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:43 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:51 MKR

Sample Number: 2A05300-05

Site: 15- Faculty Room- Sink

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:45 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead < 0.001 mg/L EPA 200.8 0.015 Pass 0.001 02/03/22 MKR 02/03/22 13:52 MKR

Report Generated On: 02/07/2022 2:41 pm  
STL\_DW\_Results Revision #1.7

2A05300  
Effective: 07/09/2014





**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Ryan F Knerr  
Project Manager II

Report Generated On: 02/07/2022 2:41 pm 2A05300  
STL\_DW\_Results Revision #1.7 Effective: 07/09/2014





# SUBURBAN TESTING LABS



2A05300  
Ryan F Knerr

TAT(Check One):  Standard  24hr  48hr  72hr  Other \_\_\_\_\_  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: EHC Associates  
Address: 2502 Horseshoe Road Phone: 717-656-3008  
Lancaster, PA 17601 Email: labresults@ehcassociates.com  
Contact Name: Mark Andrechik P.O. Info: 008735-006.2

Project Name: LS - Lead in Water Testing  
Address: Herr Elementary  
Regulatory ID (SDWA/Permit #): \_\_\_\_\_

Comments:

## Standard TAT

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
(5) 250ml P X = +30 drops of HNO3 added at 2:10 1-27-22 cb. Ph 4.2 (SIF0339)											
X	11- Kitchen - Hand Sink	1/27/22	638	MA	1st Draw - Lead in Water	1		G	P		
X	12- Kitchen Bathroom Sink		639								
X	13- Kitchen - 3-bay Sink		640								
X	14- Cafeteria - Bottle Filler		643								
X	15- Faculty Room - Sink		645								

Relinquished By:	Count	Date: <u>1/27</u> Time: <u>6:00</u>	Temp °C: _____	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass GA = Glass Amber VOA = 40mL G or GA PP = Sterile Polypropylene PS = Sterile Polystyrene HDPE = High Density Polyethylene O = Other
Received By:	5	Date: <u>1/27/22</u> Time: <u>11:05</u>	Temp °C: <u>13.5</u> Acceptable: <input checked="" type="checkbox"/> N	Number of containers match number on COC? <input checked="" type="checkbox"/> N	Sample Type Key G = Grab C = Composite 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence
Relinquished By:		Date: <u>1/27/22</u> Time: <u>12:28</u>	Temp °C: <u>12.1</u> Acceptable: <input checked="" type="checkbox"/> N	All containers in tact? <input checked="" type="checkbox"/> N		
Received in Lab By:	5	Date: <u>1-27-22</u> Time: <u>12:28</u>	Temp °C: <u>12.1</u> Acceptable: <input checked="" type="checkbox"/> N	Tests within holding times? <input checked="" type="checkbox"/> N		

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.



### Drinking Water Results Report

Order ID: 2A05301

EHC Associates, Inc.  
2502 Horseshoe Road  
Lancaster, PA 17601

Attn: Barb King

Project: LS- Lead in Water Testing  
Lampeter Elementary

PWSID:

Sample Number: 2A05301-01

Site: 16- Main Office- Sink

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:47 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/03/22	MKR	02/03/22 13:59	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 2A05301-02

Site: 17- Nurses Office- Sink

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:49 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/03/22	MKR	02/03/22 14:00	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 2A05301-03

Site: 18- Nurses- Bottle Filler

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:50 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/03/22	MKR	02/03/22 14:02	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 2A05301-04

Site: 19- Music Room- Sink

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:52 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/03/22	MKR	02/03/22 14:04	MKR
------	-------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Sample Number: 2A05301-05

Site: 20- Cafe- Bottle Filler

Sample ID:

Collector: MA

Collect Date: 01/27/2022 6:55 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	MCL	Pass/Fail	R.L.	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	-----	-----------	------	-----------	----	---------------	----

Metals

Lead	< 0.001	mg/L	EPA 200.8	0.015	Pass	0.001	02/01/22	MKR	02/02/22 11:39	MKR
------	---------	------	-----------	-------	------	-------	----------	-----	----------------	-----

Report Generated On: 02/07/2022 2:41 pm  
STL\_DW\_Results Revision #1.7

2A05301  
Effective: 07/09/2014





**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

MCL: Maximum Contaminant Level based on 40CFR part 141 and 143. MCL and Pass/Fail are provided for reference only.

RL: Reporting Limit. The lowest concentration reported for this sample. Results below the RL are considered Non-Detected.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Ryan F Knerr  
Project Manager II


Report Generated On: 02/07/2022 2:41 pm  
STL\_DW\_Results Revision #1.7

2A05301  
Effective: 07/09/2014





**SUBURBAN TESTING LABS**



2A05301  
Ryan F. Knerr

TAT (Check One):  Standard  24hr  48hr  72hr  Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: EHC Associates

Address: 2502 Horseshoe Road  
Lancaster, PA 17601

Phone: 717-656-3008

Email: labresults@ehcassociates.com

Contact Name: Mark Andrechik

P.O. Info: 008735-006.2

Project Name: LS - Lead in Water Testing

Address: Lampeter Elementary

Regulatory ID (SDWA/Permit #): \_\_\_\_\_

Comments:

**Standard TAT**

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
(5) 250ml P X= #30 drops of HNO3 added at 20:16 1-27-22; Ph 6.2 CB (5IF0339)												
X	16 - Main office - Sink	1/27/22	647	MA	1st Draw - Lead in Water	1		G	P			
X	17 - Nurse's office - Sink		649									
X	18 - Nurse's - Bottle Filler		650									
X	19 - Music Room - Sink		652									
X	20 - Cafe - Bottle Filler		655									

Relinquished By:	Count: _____	Date: <u>1/27</u>	Temp °C: _____	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass GA = Glass Amber VOA = 40mL G or GA O = Other
Received By:	5	Date: <u>1/27/22</u>	Temp °C: <u>12.5</u>			
Relinquished By:		Date: <u>1/27/22</u>	Temp °C: <u>12.1</u>	All containers in tact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Sample Type Key G = Grab C = Composite 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence
Received in Lab By: <u>CB</u>	5	Date: <u>1-27-22</u>	Temp °C: <u>12.1</u>	Tests within holding times? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		
			Acceptable: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	40 mL VOA vials free of headspace? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		OH = NaOH S = H2SO4 O = Other NA = None Required

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.