

May 3, 2022

**SOLICITATION ADDENDUM NO. 1**  
**RFP 21-0001**  
**District-Wide Alarm Monitoring Services RFP**

**THE FOLLOWING CHANGES/ADDITIONS TO THE ABOVE CITED SOLICITATION ARE ANNOUNCED:**

This addendum modifies the Request for Proposal (RFP) document(s) only to the extent indicated herein. All other areas not changed or otherwise modified by this addendum shall remain in full force and effect. This addendum is hereby made an integral part of the RFP document. Proposers must be responsive to any requirements of this addendum as if the requirements were set forth in the RFP. Failure to do so may result in proposal rejection. See the RFP regarding requests for clarification or change and protests of this addendum, and the deadlines for the foregoing.

This addendum is to be acknowledged in the space provided on the Proposer Certification Form supplied in the solicitation document. Failure to acknowledge receipt of this addendum may be cause to reject your proposal.

The closing date is changed to: **May 11, 2022 at 2:00 PM Pacific Time**

**CLARIFICATIONS:**

1. Q: Will the district be providing the make and model of the fire alarm equipment at each location?  
A: **4100U, 4100ES, 4010, 4005**
2. Q: Will the district be providing the make and model number of external communication equipment i.e. cellular dialer or AES radio equipment or the current method of communication?  
A: **Our fire alarm systems using DSC T-LINK 25/300 Internet Fire Alarm Communicator to monitoring station**
3. Q: Will the district be providing the make and model of the security equipment at each location?  
A: **Yes, Bosch D9412GV2, D9412GV3, D9412GV4 and B9512G**
4. Q: Will the district be providing the make and model number of external communication equipment i.e. cellular dialer or AES radio equipment or the current method of communication?  
A: **for Intrusion – current communication is IP based or POTS**
5. Q: Can the district provide the cutover date and timeline to have all systems transferred?  
A: **Yes, within 1 to 2 months of contract award**
6. Q: Will access be granted if the above information is not being made available to survey and inventory each location for assistance in pricing?  
A: **No**

7. Q: What version of Bosch Panels are you on?  
A: **Bosch D9412GV2, D9412GV3, D9412GV4 and B9512G**
8. Q: What version of Bosch software are you on?  
A: **RPS 6.05.008**
9. Q: Do we need installer codes? Will ADT be able to program the panels with CSM?  
A: **No installer codes and ADT will not be able to program with CSM**
10. Q: What is security dispatch for the fire alarm system?  
a. What do you mean by security dispatch?  
b. What does security dispatch look like to you?  
  
A: **Please refer to RFP, section 2, “Description of Service” for dispatch protocols**
11. Q: What is security dispatch for the intrusion alarm system?  
a. What do you mean by security dispatch?  
b. What does security dispatch look like to you?  
  
A: **Please refer to RFP, section 2, “Description of Service” for dispatch protocols**
12. Q: What is security dispatch for the environmental alarms?  
a. What do you mean by security dispatch?  
b. What does security dispatch look like to you?  
  
A: **Please refer to RFP, section 2, “Description of Service” for dispatch protocols**
13. Q: Provide dispatch response to alarms in accordance with District protocols. What are the district’s protocols?  
  
A: **Please refer to RFP, section 2, “Description of Service” for dispatch protocols**
14. Q: Do you have zone lists for each panel?  
  
A: **Yes**
15. Q: Can you provide zone lists for the intrusion, fire, and environmental monitoring at each site?  
  
A: **Yes, that will be provided to the awarded proposer**

**-END of Addendum**