



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

Laboratory Report

Blue Point School
174 Pine Point Road
Scarborough, ME 04074

Date Printed: 05/23/2022
Work Order #: 2204-03060
Client Job #: 432
Date Received: 04/20/2022
Sample collected in: Maine

Attached please find results for the analysis of the samples received on the date referenced above.

Unless otherwise noted in the attached report, the analyses performed met the requirements of the analyzing laboratory's Quality Assurance Plan, Standard Operating Procedures and State Accreditation. This certificate shall not be reproduced, except in full, without the written approval of the analyzing laboratory. The results presented in this report relate to the samples listed on the following pages in the condition in which they were received. Accreditation for each analyte is identified by the * symbol following the analyte name. Location of our analyzing laboratory is identified by the code in the Analyst Column.

A & L Laboratory:
Identified by ME in Analyst Column
155 Center Street, Auburn, Maine 04210
www.allaboratory.com

Granite State Analytical Services LLC:
Identified by NH in Analyst Column
22 Manchester Road, Derry, NH 03038
www.granitestateanalytical.com

ANALYSIS RELATED NOTES:

- RL: "Reporting limit" means the lowest level of an analyte that can be accurately recovered from the matrix of interest.
- A & L Laboratory / Granite State Analytical Services LLC / Nashoba Analytical LLC. accreditation lists can be found on our websites listed above.
- Subcontracted samples will be identified by the Accreditation number of the subcontract laboratory in the analyst field for each analyte and the appropriate laboratory will be listed here. **None**
- Data Qualifiers (DQ) Flags provide additional information in regards to the receipt, analysis or quality control of a sample. These are indicated under the DQ Flags Column on your report and listed here if necessary: **Data Qualifier (DQ) Flags: None**

SAMPLE STATE SPECIFIC NOTES:

- The thermal preservation requirement of 4°C for nitrate & nitrite has been waived by the Maine CDC for all samples submitted to the Drinking Water Program.

Additional Narrative or Comments: **None**

We appreciate the opportunity to provide you with laboratory services. If you have any questions regarding the enclosed report, please contact the laboratory and we will be happy to assist you.

Rebecca L. Labranche
Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
 Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/23/2022
CLIENT NAME: Blue Point School
CLIENT ADDRESS: 174 Pine Point Road
 Scarborough, ME 04074
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 04/20/2022 10:30AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 13° CELSIUS
CLIENT JOB #: 432

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2204-03060-001	Kitchen 3-bay sink	I	KF	04/15/2022 04:52AM	1.8	ppb			DG-NH	05/21/2022 11:32AM
2204-03060-002	Gym Fountain	I	DWF	04/15/2022 04:55AM	<1	ppb			DG-NH	05/21/2022 11:35AM
2204-03060-003	Gym Bottle Filler	I	DWF	04/15/2022 04:55AM	<1	ppb			DG-NH	05/21/2022 11:39AM
2204-03060-004	Clinic Sink	I	OT	04/15/2022 04:57AM	4.5	ppb			DG-NH	05/21/2022 11:43AM
2204-03060-005	Clinic Fountain	I	DWF	04/15/2022 04:57AM	14.4	ppb			DG-NH	05/21/2022 11:46AM
2204-03060-006	Room 1 Sink	I	OT	04/15/2022 04:59AM	5.7	ppb			DG-NH	05/21/2022 11:50AM
2204-03060-007	Room 1 Fountain	I	DWF	04/15/2022 04:59AM	5.3	ppb			DG-NH	05/21/2022 12:01PM
2204-03060-008	Room 2 Sink	I	OT	04/15/2022 05:00AM	1.2	ppb			DG-NH	05/21/2022 12:04PM
2204-03060-009	Room 2 Fountain	I	DWF	04/15/2022 05:00AM	6.5	ppb			DG-NH	05/21/2022 12:08PM
2204-03060-010	Room 3 Sink	I	OT	04/15/2022 05:03AM	3.4	ppb			DG-NH	05/21/2022 12:11PM
2204-03060-011	Room 3 Fountain	I	DWF	04/15/2022 05:03AM	6.8	ppb			DG-NH	05/21/2022 12:22PM
2204-03060-012	Room 4 Sink	I	OT	04/15/2022 05:04AM	2.5	ppb			DG-NH	05/21/2022 12:26PM
2204-03060-013	Room 4 Fountain	I	DWF	04/15/2022 05:04AM	3.1	ppb			DG-NH	05/21/2022 12:29PM
2204-03060-014	Room 5 Sink	I	OT	04/15/2022 05:05AM	3.2	ppb			DG-NH	05/21/2022 12:33PM
2204-03060-015	Room 5 Fountain	I	DWF	04/15/2022 05:05AM	3.5	ppb			DG-NH	05/21/2022 12:47PM
2204-03060-016	Room 6 Sink	I	OT	04/15/2022 05:07AM	5.7	ppb			DG-NH	05/21/2022 12:51PM
2204-03060-017	Room 6 Fountain	I	DWF	04/15/2022 05:07AM	10.0	ppb			DG-NH	05/21/2022 12:54PM
2204-03060-018	Mid Hall Fountain	I	DWF	04/15/2022 05:10AM	<1	ppb			DG-NH	05/21/2022 12:58PM
2204-03060-019	Mid Hall Bottle Filler	I	DWF	04/15/2022 05:10AM	<1	ppb			DG-NH	05/21/2022 01:01PM
2204-03060-020	Library Sink	I	OT	04/15/2022 05:12AM	18.1	ppb			DG-NH	05/20/2022 09:16PM
2204-03060-021	Teacher Break Room Sink	I	OT	04/15/2022 05:14AM	<1	ppb			DG-NH	05/21/2022 01:05PM
2204-03060-022	Room 13 Sink	I	OT	04/15/2022 05:16AM	23.8	ppb			DG-NH	05/21/2022 01:16PM
2204-03060-023	Room 13 Fountain	I	DWF	04/15/2022 05:16AM	7.7	ppb			DG-NH	05/21/2022 01:19PM
2204-03060-024	Room 14 Sink	I	OT	04/15/2022 05:18AM	2.8	ppb			DG-NH	05/21/2022 01:30PM
2204-03060-025	Room 14 Fountain	I	DWF	04/15/2022 05:18AM	1.9	ppb			DG-NH	05/21/2022 01:34PM
2204-03060-026	Room 15 Sink	I	OT	04/15/2022 05:20AM	1.3	ppb			DG-NH	05/21/2022 01:37PM

Rebecca L. Labranche
 Laboratory Director



A & L LABORATORY

A DIVISION OF GRANITE STATE ANALYTICAL SERVICES, LLC.

155 Center Street, Building C, Auburn, Maine 04210
Phone (207) 784-5354 website www.allaboratory.com

CERTIFICATE OF ANALYSIS FOR DRINKING WATER

DATE PRINTED: 05/23/2022
CLIENT NAME: Blue Point School
CLIENT ADDRESS: 174 Pine Point Road
Scarborough, ME 04074
METHOD: EPA 200.8
EPA ACTION LEVEL: 15 ppb
MAINE GUIDELINE: 4 ppb
REPORTING LIMIT: 1 ppb

Legend	
Lead Above 4 ppb	
Lead Above 15 ppb	

DATE AND TIME RECEIVED: 04/20/2022 10:30AM
ANALYSIS PACKAGE: Maine Schools-Lead
RECEIPT TEMPERATURE: 13° CELSIUS
CLIENT JOB #: 432

Sample ID #	Location	Sample Type	Outlet Type	Date - Time Water Sampled	Result	Test Units	Pass /Fail	DQ Flag	Analyst	Date - Time Analyzed
2204-03060-027	Room 15 Fountain	I	DWF	04/15/2022 05:20AM	1.2	ppb			DG-NH	05/21/2022 01:41PM
2204-03060-028	Room 16 Sink	I	OT	04/15/2022 05:21AM	1.3	ppb			DG-NH	05/21/2022 01:44PM
2204-03060-029	Room 16 Fountain	I	DWF	04/15/2022 05:21AM	7.1	ppb			DG-NH	05/20/2022 09:23PM
2204-03060-030	Room 17 Sink	I	OT	04/15/2022 05:23AM	2.5	ppb			DG-NH	05/21/2022 01:48PM
2204-03060-031	Room 17 Fountain	I	DWF	04/15/2022 05:23AM	1.4	ppb			DG-NH	05/21/2022 01:52PM
2204-03060-032	Room 18 Sink	I	OT	04/15/2022 05:26AM	2.3	ppb			DG-NH	05/21/2022 01:55PM
2204-03060-033	Room 18 Fountain	I	DWF	04/15/2022 05:26AM	<1	ppb			DG-NH	05/21/2022 02:17PM
2204-03060-034	Room 19 Sink	I	OT	04/15/2022 05:27AM	2.2	ppb			DG-NH	05/21/2022 02:20PM
2204-03060-035	Room 19 Fountain	I	DWF	04/15/2022 05:27AM	30.4	ppb			DG-NH	05/21/2022 02:24PM
2204-03060-036	Room 20 Sink	I	OT	04/15/2022 05:28AM	<1	ppb			DG-NH	05/21/2022 02:28PM
2204-03060-037	Room 20 Fountain	I	DWF	04/15/2022 05:28AM	1.6	ppb			DG-NH	05/21/2022 02:31PM
2204-03060-038	Room 21 Sink	I	OT	04/15/2022 05:29AM	1.7	ppb			DG-NH	05/21/2022 02:35PM
2204-03060-039	Room 21 Fountain	I	DWF	04/15/2022 05:29AM	1.5	ppb			DG-NH	05/21/2022 02:38PM
2204-03060-040	Room 22 Bath Sink	I	OT	04/15/2022 05:31AM	<1	ppb			DG-NH	05/21/2022 02:42PM
2204-03060-041	Room 23 Bath Sink	I	OT	04/15/2022 05:32AM	<1	ppb			DG-NH	05/21/2022 02:46PM
2204-03060-042	Room 24 Bath Sink	I	OT	04/15/2022 05:33AM	31.7	ppb			DG-NH	05/20/2022 09:26PM
2204-03060-043	Room 25 Bath Sink	I	OT	04/15/2022 05:34AM	<1	ppb			DG-NH	05/21/2022 02:49PM

Rebecca L. Labranche
Laboratory Director