

Career and Technology Academy 2021-2022 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Sample Tap/Outlet Description/Location	Sample Type (Code)	Date Water Last Used	Time Water Last Used	Date Sample Collected	Time Sample Collected	Analysis Date	Lead Sample Result (ppb)	≥ 5.5 ppb AL?
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	1a	DF	Bottle filler outside culinary arts	FD	4/25/22	5:00pm	4/26/22	5:32am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	10	TL	cold faucet in staff lounge	FD	4/25/22	5:00pm	4/26/22	5:33am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	11	HE	cold faucet in food prep classroom	FD	4/25/22	5:00pm	4/26/22	5:34am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	12	HE	left cold faucet by culinary arts walk in freezer	FD	4/25/22	5:00pm	4/26/22	5:35am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	13	HE	right cold faucet by culinary arts walk in freezer	FD	4/25/22	5:00pm	4/26/22	5:35am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	14	HE	cold faucet in advanced cooking	FD	4/25/22	5:00pm	4/26/22	5:37am	04/29/2022	2.4	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	15	HE	left cold faucet across from dish washer	FD	4/25/22	5:00pm	4/26/22	5:37am	04/29/2022	1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	16	HE	right cold faucet across from dish washer	FD	4/25/22	5:00pm	4/26/22	5:37am	04/29/2022	<1.0	no

Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	17	CR	cold faucet next to cosmetology dispensary	FD	4/25/22	5:00pm	4/26/22	5:39am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	18	CR	cold faucet next to eye wash station	FD	4/25/22	5:00pm	4/26/22	5:39am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	19	CR	cold faucet next to cosmetology planning	FD	4/25/22	5:00pm	4/26/22	5:41am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	20	CR	cold faucet in manicure/pedicure area	FD	4/25/22	5:00pm	4/26/22	5:41am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	21	CR	cold faucet in networking where cool beans coffee is	FD	4/25/22	5:00pm	4/26/22	5:42am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	23	CR	cold faucet in first aid	FD	4/25/22	5:00pm	4/26/22	5:44am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	24	TL	cold faucet in mail room	FD	4/25/22	5:00pm	4/26/22	5:44am	04/29/2022	1.3	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	25	CR	cold faucet in electronics lab	FD	4/25/22	5:00pm	4/26/22	5:35am	04/29/2022	1.1	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	26	CR	cold faucet in engineering lab	FD	4/25/22	5:00pm	4/26/22	5:36am	04/29/2022	<1.0	no
Water Testing	Career and Technology Academy	5/16/22	1	27	CR	left cold faucet in pre-nursing lab	FD	4/25/22	5:00pm	4/26/22	5:38am	04/29/2022	<1.0	no

Laboratory of MD														
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	28	CR	middle cold faucet in pre-nursing	FD	4/25/22	5:00pm	4/26/22	5:38am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	29	CR	right cold faucet in pre-nursing lab	FD	4/25/22	5:00pm	4/26/22	5:39am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	30	CR	cold faucet in exam room 1	FD	4/25/22	5:00pm	4/26/22	5:40am	04/29/2022	1.9	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	31	CR	cold faucet in exam room 3	FD	4/25/22	5:00pm	4/26/22	5:41am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	32	CR	cold faucet in exam room 4	FD	4/25/22	5:00pm	4/26/22	5:41am	04/29/2022	1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	33	CR	cold faucet in exam room 5	FD	4/25/22	5:00pm	4/26/22	5:42am	04/29/2022	1.4	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	34	CR	cold faucet in exam room 6	FD	4/25/22	5:00pm	4/26/22	5:42am	04/29/2022	<1.0	no
Water Testing	Career and Technology Academy	5/16/22	1	35	CR	left cold faucet in medical assistant lab	FD	4/25/22	5:00pm	4/26/22	5:43am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	36	CR	right cold faucet in medical assistant lab	FD	4/25/22	5:00pm	4/26/22	5:43am	04/29/2022	<1.0	no

Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	37	CR	cold faucet in medical assistant lab	FD	4/25/22	5:00pm	4/26/22	5:44am	04/29/2022	1.8	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	38	CR	cold faucet in CAD lab	FD	4/25/22	5:00pm	4/26/22	5:44am	04/29/2022	<1.0	no
Water Testing Laboratory of MD	Career and Technology Academy	5/16/22	1	39	IM	ice machine in culinary arts	FD	4/25/22	5:00pm	4/26/22	5:38am	04/29/2022	<1.0	no