

Report of Analysis

Name:	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	Sample ID#:	285105
		Sample Type:	Drinking Water
		Sampler:	PD
		PWS ID:	CT0570212
Sample Date:	5/4/2022 6:35 AM		
Receipt Date:	5/4/2022 2:20 PM		
Report Date:	6/13/2022		
Sample Site:	ENTRY POINT		

Parameter	Sample Result	Units	Method	RL	Analysis Date	Analyst
Organic Compounds						
PCB	ND	mg/L	EPA 508.1	0.0002	6/1/2022 12:00	EML
Synthetic Organic Chemicals Phase						
Butachlor	ND	mg/L	EPA 508.1	0.001	6/1/2022 12:00	EML
Metribuzin	ND	mg/L	EPA 508.1	0.0005	6/1/2022 12:00	EML
Propachlor	ND	mg/L	EPA 508.1	0.001	6/1/2022 12:00	EML
Synthetic Organic Chemicals Phase						
Dalapon	ND	mg/L	EPA 552.2	0.002	5/11/2022 12:00	EML
Synthetic Organic Compounds						
2,4,5-TP	ND	mg/L	EPA 555	0.0004	5/12/2022 12:00	EML
2,4-D	ND	mg/L	EPA 555	0.0002	5/12/2022 12:00	EML
3-Hydroxycarbofuran	ND	mg/L	EPA 531.1	0.002	5/24/2022 12:00	EML
Alachlor	ND	mg/L	EPA 508.1	0.0004	6/1/2022 12:00	EML
Aldicarb	ND	mg/L	EPA 531.1	0.001	5/24/2022 12:00	EML
Aldicarb Sulfoxide	ND	mg/L	EPA 531.1	0.001	5/24/2022 12:00	EML
Aldicarb Sulfoxone	ND	mg/L	EPA 531.1	0.0017	5/24/2022 12:00	EML
Aldrin	ND	mg/L	EPA 508.1	0.0005	6/1/2022 12:00	EML
Atrazine	ND	ug/L	EPA 508.1	0.0002	6/1/2022 12:00	EML
Benzo (A) Pyrene	ND	mg/L	EPA 525.2	0	5/30/2022 12:00	EML
Carbaryl	ND	mg/L	EPA 531.1	0.004	5/24/2022 12:00	EML
Carbofuran	ND	mg/L	EPA 531.1	0.0019	5/24/2022 12:00	EML
Chlordane	ND	mg/L	EPA 508.1	0.0004	6/1/2022 12:00	EML
Di (2-ethylhexyl) adipate	ND	mg/L	EPA 525.2	0.001	5/30/2022 12:00	EML
Di (2-ethylhexyl) phthalates	ND	mg/L	EPA 525.2	0.001	5/30/2022 12:00	EML
Dibromochloropropane(DBCP)	ND	mg/L	EPA 504.1	0	5/12/2022 12:00	EML
Dicamba	ND	mg/L	EPA 555	0.0008	5/12/2022 12:00	EML

Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
 * = Above Specified Limit



CT Lic PH-0787

NY Lic 11706

AquaEnvLab.com
 YorkLab.com
 203 270 9973

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.

Report of Analysis

Name:	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	Sample ID#:	285105
		Sample Type:	Drinking Water
		Sampler:	PD
		PWS ID:	CT0570212
Sample Date:	5/4/2022 6:35 AM		
Receipt Date:	5/4/2022 2:20 PM		
Report Date:	6/13/2022		
Sample Site:	ENTRY POINT		

Parameter	Sample Result	Units	Method	RL	Analysis Date	Analyst
Synthetic Organic Compounds						
Dieldrin	ND	mg/L	EPA 508.1	0	6/1/2022 12:00	EML
Dinoseb	ND	mg/L	EPA 555	0.0004	5/12/2022 12:00	EML
Diquat	ND	mg/L	EPA 549.2	0.0008	5/19/2022 12:00	EML
Endrin	ND	mg/L	EPA 508.1	0	6/1/2022 12:00	EML
Ethylene Dibromide(EDB)	ND	mg/L	EPA 504.1	0	5/12/2022 12:00	EML
Glyphosphate	ND	mg/L	EPA 547	0.01	5/9/2022 12:00	EML
Heptachlor	ND	mg/L	EPA 508.1	0.0001	6/1/2022 12:00	EML
Heptachlor Epoxide	ND	mg/L	EPA 508.1	0.0002	6/1/2022 12:00	EML
Hexachlorobenzene	ND	mg/L	EPA 508.1	0.0002	6/1/2022 12:00	EML
Hexachlorocyclopentadiene	ND	mg/L	EPA 508.1	0.0002	6/1/2022 12:00	EML
Lindane	ND	mg/L	EPA 508.1	0.0002	6/1/2022 12:00	EML
Methomyl	ND	mg/L	EPA 531.1	0.004	5/24/2022 12:00	EML
Methoxychlor	ND	mg/L	EPA 508.1	0.001	6/1/2022 12:00	EML
Metolachlor	ND	mg/L	EPA 508.1	0.001	6/1/2022 12:00	EML
Oxamyl (Vydate)	ND	mg/L	EPA 531.1	0.004	5/24/2022 12:00	EML
Pentachlorophenol	ND	mg/L	EPA 555	0.0001	5/12/2022 12:00	EML
Picloram	ND	mg/L	EPA 555	0.0002	5/12/2022 12:00	EML
Simazine	ND	mg/L	EPA 508.1	0.0001	6/1/2022 12:00	EML
Toxaphene	ND	mg/L	EPA 508.1	0.002	6/1/2022 12:00	EML

Comments: Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706
 Lab Director

AquaEnvLab.com
 YorkLab.com
 203 270 9973

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.