



*Anthony Lo Franco, CPA  
Business Administrator /  
Board Secretary*

*Michelle Ferraro  
Administrative Assistant*

*Morris School District  
Office of the Business Administrator  
31 Hazel Street  
Morristown, NJ 07960  
973-292-2300 ext 2021  
Fax: 973-387-7605*

*Joan Frederick, CPA  
Assistant Business  
Administrator / Assistant  
Board Secretary*

*Gregory Sumski  
Assistant Business  
Administrator for  
Operations*

June 17, 2022

Morris School District  
Frelinghuysen Middle School  
Morriston, NJ

Dear Frelinghuysen Middle School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Morris School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Frelinghuysen Middle School will implement immediate remedial measures for any drinking water outlet with a result greater than the Maximum Contamination Level of 0.015 micrograms per liter (0.015 mg/l). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

#### Testing Results

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within The Morris School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 24 samples taken, all but 1 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (0.015 mg/L).

The table below identifies the drinking water outlets that tested above the 0.015 mg/L for lead, the actual lead level, and what temporary remedial action Morris School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in mg/l</b>	<b>Remedial Action</b>
Water Fountain by Wood Shop	0.0204 mg/L	Water fountain removed on 5/18/22. A new fountain with a filter will be ordered and installed.

## Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

## Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

## For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at <https://bit.ly/39vRw1q>. For more information about water quality in our schools, contact Anthony Lo Franco at Central Office, 973-292-2300 x2021.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,



Anthony Lo Franco  
Business Administrator / Board Secretary