



Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

April 11, 2022

Debby Blinn
East Lyme Public Schools
165 Boston Post Road
P.O. Box 220
East Lyme, CT 06333-0176

Re: Radon 5-year Testing East Lyme Public Schools (3/15-18/22)

Locations: East Lyme Highschool, East Lyme Middle School,
Niantic Center School, Flanders Elementary School,
Lillie B. Haynes Elementary School

Dear Debby:

As requested, Mystic Air Quality Consultants, Inc. conducted radon testing at the location above on March 15th & 18th, 2022. The kits were placed in their respective locations at your facilities, then picked up and mailed to Airchek lab, where Mystic Air Quality arranged for analytical services.

The results for radon in air are summarized below:

A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation.

<u>Location</u>	<u>Radon Test Kit #</u>	<u>Result (pCi/L)</u>
East Lyme Highschool -1st Floor		
A121	7348876	<0.3
Blank	7348886	<0.3
Ad Office	7351614	<0.3
B109	7351621	<0.3
A121	7351622 (dup)	<0.3
D130	7351627	<0.3
Custodian Office	7351630	<0.3
A108	7351631	<0.3
Main Office	7351632	<0.3
A117	7351633	<0.3
B106	7351634	<0.3



Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

A concentration of 4.0 picocuries of radon per liter of air (pCi/L) is the threshold at which the US EPA recommends further testing and consideration of remediation.

Location	Radon Test Kit #	Result (pCi/L)
----------	------------------	----------------

East Lyme Middle School -1st Floor

Main Office	7348878 (dup)	<0.3
Main Office	7348879	<0.3
46	7348880	<0.3
28	7348881	0.8 ± 0.3
19	7348882	0.8 ± 0.3
26	7348883	0.6 ± 0.3
109	7348884	<0.3
Bay House Office	7348885	<0.3
Blank	7348887	<0.3
31	9731326	1.8 ± 0.3
154	9731361	1.0 ± 0.3
Room 106	9731366	<0.3

Niantic Center School -1st Floor

Room 100	9731322	0.9 ± 0.3
Main Office	9731323 (dup)	1.0 ± 0.3
Main Office	9731324	1.0 ± 0.3
Blank	9731370	<0.3

Flanders Elementary School -1st Floor

Main Office	7348875	1.0 ± 0.3
Blank	7348888	<0.3
A03a	7349992	0.6 ± 0.3
C70a	7351605	<0.3
C29a	7351611	0.8 ± 0.3
Main Office	7351613 (dup)	1.7 ± 0.3
C23a	7351615	<0.3
C17a	7351625	<0.3



Mystic Air Quality Consultants, Inc.

1204 North Road, Groton, Connecticut 06340

www.mysticair.com

maq2@aol.com

800 247-7746

Lillie B. Haynes Elementary School -1st Floor

Main Office	7348877	<0.3
10	7349998	<0.3
17	7349999	<0.3
57	7350000	0.8 ± 0.3
52	7350004	<0.3
47 North	7350005	<0.3
41	7351608	<0.3
Blank	7351626	<0.3
25	7351628	<0.3
47 North	7351629 (dup)	<0.3

We thank you for selecting Mystic Air Quality to perform these industrial hygiene services.

Sincerely,

A handwritten signature in cursive script, appearing to read "C. Eident".

Christopher J. Eident CIH, CSP, RS
CEO

Enclosure 1: School Radon Testing Report Form

Enclosure 2: Laboratory Analysis Report

Enclosure 3: Inspector's Sampling Roster



STATE OF CONNECTICUT
 DEPARTMENT OF PUBLIC HEALTH
 RADON PROGRAM
SCHOOL RADON TESTING REPORT FORM

Nov. 2005

The following form must be submitted to the Connecticut Department of Public Health Radon Program within five (5) working days of providing a final written report of radon measurement activities to school personnel. Submit the original, signed copy of this form to the Radon Program at the address listed below:

Attn: School Radon Testing Program
 CT Department of Public Health Radon Program
 410 Capitol Avenue, MS #51 RAD
 Hartford, CT 06134-0308

Name of School: EAST LYME HIGH SCHOOL

Address: 30 CHESTERFIELD ROAD
 (Street, town, zip code) EAST LYME, CT 06333

Dates of Testing: 03-15 / 18 - 2022

NEHA/NRSB Tester: Christopher Muller
 (or qualified school personnel)

NEHA/NRSB Certification #: 6SS0019

Please provide the following summary information:

Total # of Rooms Tested: 9

Total # of Rooms Requiring Re-Testing: 0

Total # of Rooms Where Average Results Were At or Above 4.0 pCi/L: 0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christopher Muller
 Signature of Radon Measurement Professional
 (or designated school authority)

4/12/22
 Date



Phone: (860) 509-7367
 Telephone Device for the Deaf (860) 509-7191
 450 Capitol Avenue - MS # 51RAD
 P.O. Box 340308 Hartford, CT 06134
 An Equal Opportunity Employer

Attention:

Kit #: 7348876 Result: < 0.3 pCi/l
Location: 1st Floor A121
East Lyme High
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 4.4% 70°F

Kit #: 7348886 Result: < 0.3 pCi/l
Location: 1st Floor Blank
East Lyme High Blan
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 2.0% 70°F

Kit #: 7351614 Result: < 0.3 pCi/l
Location: 1st Floor Ad Office
East Lyme High Ad
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 4.3% 70°F

Kit #: 7351621 Result: < 0.3 pCi/l
Location: 1st Floor B109
East Lyme High B109
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 3.5% 70°F

Kit #: 7351622 Result: < 0.3 pCi/l
Location: 1st Floor A121
East Lyme High A121
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 2.8% 70°F

Kit #: 7351627 Result: < 0.3 pCi/l
Location: 1st Floor D130
East Lyme High D130
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 4.3% 70°F

Attention:

Kit #: 7351630 Result: < 0.3 pCi/l
Location: 1st Floor Custodian Office
East Lyme High Co
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 3.6% 70°F

Kit #: 7351631 Result: < 0.3 pCi/l
Location: 1st Floor A108
East Lyme High A108
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 4.3% 70°F

Kit #: 7351632 Result: < 0.3 pCi/l
Location: 1st Floor Main Office
East Lyme High Mo
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 3.6% 70°F

Kit #: 7351633 Result: < 0.3 pCi/l
Location: 1st Floor A117
East Lyme High A117
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 2.8% 70°F

Kit #: 7351634 Result: < 0.3 pCi/l
Location: 1st Floor B106
East Lyme High B105
30 Chesterfield Rd
East Lyme, CT 06333-1201

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 7:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 73 hours 3.6% 70°F



STATE OF CONNECTICUT
 DEPARTMENT OF PUBLIC HEALTH
 RADON PROGRAM
SCHOOL RADON TESTING REPORT FORM

Nov. 2005

The following form must be submitted to the Connecticut Department of Public Health Radon Program within five (5) working days of providing a final written report of radon measurement activities to school personnel. Submit the original, signed copy of this form to the Radon Program at the address listed below:

Attn: School Radon Testing Program
 CT Department of Public Health Radon Program
 410 Capitol Avenue, MS #51 RAD
 Hartford, CT 06134-0308

Name of School: EAST LYME MIDDLE SCHOOL

Address: 31 SOCIETY ROAD
 (Street, town, zip code) EAST LYME, CT 06333

Dates of Testing: 03-15 / 18 - 2022

NEHA/NRSB Tester: Christopher Muller
 (or qualified school personnel)

NEHA/NRSB Certification #: 6550019

Please provide the following summary information:

Total # of Rooms Tested: 10

Total # of Rooms Requiring Re-Testing: 0

Total # of Rooms Where Average Results Were At or Above 4.0 pCi/L: 0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christopher Muller
 Signature of Radon Measurement Professional
 (or designated school authority)

4/12/22
 Date



Phone: (860) 509-7367
 Telephone Device for the Deaf (860) 509-7191
 450 Capitol Avenue - MS # 51RAD
 P.O. Box 340308 Hartford, CT 06134
 An Equal Opportunity Employer

Attention:

Kit #: 7348878 Result: < 0.3 pCi/l
Location: 1st Floor Main Office
Elms Main Office
31 Society Rd
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 4.4% 70°F

Kit #: 7348879 Result: < 0.3 pCi/l
Location: 1st Floor Main Office
Elms Main Office
31 Society Rd
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 4.4% 70°F

Kit #: 7348880 Result: < 0.3 pCi/l
Location: 1st Floor 46
Elms 46
31 Society Rd #46
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 4.3% 70°F

Kit #: 7348881 Result: 0.8 ± 0.3 pCi/l
Location: 1st Floor 28
Elms 28
31 Society Rd # 28
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 3.7% 70°F

Kit #: 7348882 Result: 0.8 ± 0.3 pCi/l
Location: 1st Floor 19
Elms 19
31 Society Rd # 19
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 4.3% 70°F

Kit #: 7348883 Result: 0.6 ± 0.3 pCi/l
Location: 1st Floor 26
Elms 26
31 Society Rd # 26
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 3.6% 70°F

Attention:

Kit #: 7348884 Result: < 0.3 pCi/l
Location: 1st Floor 109
Elms 109
31 Society Rd # 109
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 4.4% 70°F

Kit #: 7348885 Result: < 0.3 pCi/l
Location: 1st Floor Bay House Office
Elms Bay House Off
31 Society Rd
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 3.6% 70°F

Kit #: 7348887 Result: < 0.3 pCi/l
Location: 1st Floor Blank
Elms Blank
31 Society Rd
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 1.2% 70°F

Kit #: 9731326 Result: < 0.3 pCi/l
Location: 1st Floor
Elms Room 31
31 Society Rd # 31
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 5.2% 70°F

Kit #: 9731361 Result: 0.6 ± 0.3 pCi/l
Location: 1st Floor
Elms Room 154
31 Society Rd # 154
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 6.6% 70°F

Kit #: 9731366 Result: < 0.3 pCi/l
Location: 1st Floor
Elms Room 106
31 Society Rd # 106
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 9:00 am
Ended : 2022-03-18 at 9:00 am
Hours/MST% : 72 hours 9.0% 70°F

EAST LYME, CT

MIDDLE SCHOOL

DETECTOR IDENTIFICATION	SAMPLE LOCATION	START TIME	END TIME	NOTES
✓ 7348879	MAIN OFFICE	03/15 0900	03/18 0900	
✓ 7348878 (dup.)	↓ ↓			
✓ 9731366	106			
✓ 7348884	109			
✓ 9731361	154			
✓ 7348880	46			
✓ 9731326	31			
✓ 7348883	26			
✓ 7348885	BAH HOUSE OFFICE			
✓ 7348882	19			
✓ 7348881	28			
7348887	BLANK			
DUP.				

East Lyme Middle School
Main Office
Christopher Muller
03/18/22 8:52 AM
VISITOR



East Lyme Middle School
Main Office
Christopher Muller
03/18/22 8:52 AM
VISITOR



STATE OF CONNECTICUT
 DEPARTMENT OF PUBLIC HEALTH
 RADON PROGRAM
SCHOOL RADON TESTING REPORT FORM

Nov. 2005

The following form must be submitted to the Connecticut Department of Public Health Radon Program within five (5) working days of providing a final written report of radon measurement activities to school personnel. Submit the original, signed copy of this form to the Radon Program at the address listed below:

Attn: School Radon Testing Program
 CT Department of Public Health Radon Program
 410 Capitol Avenue, MS #51 RAD
 Hartford, CT 06134-0308

Name of School: NIANTIC CENTER SCHOOL

Address: 7 WEST MAIN STREET
 (Street, town, zip code) NIANTIC, CT 06357

Dates of Testing: 03-15 / 18 - 2022

NEHA/NRSB Tester: Christopher Muller
 (or qualified school personnel)

NEHA/NRSB Certification #: 6550019

Please provide the following summary information:

Total # of Rooms Tested: 2

Total # of Rooms Requiring Re-Testing: 0

Total # of Rooms Where Average Results Were At or Above 4.0 pCi/L: 0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christopher Muller
 Signature of Radon Measurement Professional
 (or designated school authority)

4/12/22
 Date



Phone: (860) 509-7367
 Telephone Device for the Deaf (860) 509-7191
 450 Capitol Avenue - MS # 51RAD
 P.O. Box 340308 Hartford, CT 06134
 An Equal Opportunity Employer

Attention:

Kit #: 9731322 Result: 0.9 ± 0.3 pCi/l
Location: 1st Floor
Niantic Ctr Room 100
7 W Main St
Niantic, CT 06357-2319

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 10:00 am
Hours/MST% : 74 hours 5.2% 70°F

Kit #: 9731323 Result: 1.0 ± 0.3 pCi/l
Location: 1st Floor
Niantic Ctr Main Office
7 W Main St
Niantic, CT 06357-2319

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 10:00 am
Hours/MST% : 74 hours 5.1% 70°F

Kit #: 9731324 Result: 1.0 ± 0.3 pCi/l
Location: 1st Floor
Niantic Ctr Main Office
7 W Main St
Niantic, CT 06357-2319

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 10:00 am
Hours/MST% : 74 hours 5.1% 70°F

Kit #: 9731370 Result: < 0.3 pCi/l
Location: 1st Floor
Blank
7 W Main St
Niantic, CT 06357-2319

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 10:00 am
Hours/MST% : 74 hours 4.4% 70°F

EAST LYME, CT

NIANTIC CENTER

DETECTOR IDENTIFICATION	SAMPLE LOCATION	START TIME	END TIME	NOTES
9731324	MAIN OFFICE	03/15 0800	03/18 1000	
9731323	↓ ↓ (dup)	↓	↓	
9731322	100	↓	↓	
9731370	BEANK	↓	↓	
DUP.				
DUP.				



STATE OF CONNECTICUT
 DEPARTMENT OF PUBLIC HEALTH
 RADON PROGRAM
SCHOOL RADON TESTING REPORT FORM

Nov. 2005

The following form must be submitted to the Connecticut Department of Public Health Radon Program within five (5) working days of providing a final written report of radon measurement activities to school personnel. Submit the original, signed copy of this form to the Radon Program at the address listed below:

Attn: School Radon Testing Program
 CT Department of Public Health Radon Program
 410 Capitol Avenue, MS #51 RAD
 Hartford, CT 06134-0308

Name of School: FLANDERS ELEMENTARY SCHOOL

Address: 167 BOSTON POST ROAD
 (Street, town, zip code) EAST LYME, CT 06333

Dates of Testing: 03-15 / 18 - 2022

NEHA/NRSB Tester: Christopher Muller
 (or qualified school personnel)

NEHA/NRSB Certification #: 6550019

Please provide the following summary information:

Total # of Rooms Tested: 6

Total # of Rooms Requiring Re-Testing: 0

Total # of Rooms Where Average Results Were At or Above 4.0 pCi/L: 0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christopher Muller
 Signature of Radon Measurement Professional
 (or designated school authority)

4/12/22
 Date



Phone: (860) 509-7367
 Telephone Device for the Deaf (860) 509-7191
 450 Capitol Avenue - MS # 51RAD
 P.O. Box 340308 Hartford, CT 06134
 An Equal Opportunity Employer

Attention:Kit #: 7348875 Result: 1.0 ± 0.3 pCi/l

Location: 1st Floor Main Office

Flander Elem Mo

167 Boston Post Rd

East Lyme, CT 06333-1605

Analysis Note :

Analyzed : 2022-03-21 at 11:00 am

Started : 2022-03-15 at 8:00 am

Ended : 2022-03-18 at 9:00 am

Hours/MST% : 73 hours 4.4% 70°F

Kit #: 7348888 Result: < 0.3 pCi/l

Location: 1st Floor Blank

Flanders Elem Blank

167 Boston Post Rd

East Lyme, CT 06333-1605

Analysis Note :

Analyzed : 2022-03-21 at 11:00 am

Started : 2022-03-15 at 8:00 am

Ended : 2022-03-18 at 9:00 am

Hours/MST% : 73 hours 1.2% 70°F

Kit #: 7349992 Result: 0.6 ± 0.3 pCi/l

Location: 1st Floor A03a

Flanders Elem A03a

167 Boston Post Rd

East Lyme, CT 06333-1605

Analysis Note :

Analyzed : 2022-03-21 at 12:00 pm

Started : 2022-03-15 at 8:00 am

Ended : 2022-03-18 at 9:00 am

Hours/MST% : 73 hours 2.9% 70°F

Kit #: 7351605 Result: < 0.3 pCi/l

Location: 1st Floor C70a

Flanders Elem C70a

167 Boston Post Rd

East Lyme, CT 06333-1605

Analysis Note :

Analyzed : 2022-03-21 at 12:00 pm

Started : 2022-03-15 at 8:00 am

Ended : 2022-03-18 at 9:00 am

Hours/MST% : 73 hours 2.8% 70°F

Kit #: 7351611 Result: 0.8 ± 0.3 pCi/l

Location: 1st Floor C29a

Flanders Elem C29a

167 Boston Post Rd

East Lyme, CT 06333-1605

Analysis Note :

Analyzed : 2022-03-21 at 11:00 am

Started : 2022-03-15 at 8:00 am

Ended : 2022-03-18 at 9:00 am

Hours/MST% : 73 hours 3.6% 70°F

Kit #: 7351613 Result: 1.7 ± 0.3 pCi/l

Location: 1st Floor Main Office

Flanders Elem Mo

167 Boston Post Rd

East Lyme, CT 06333-1605

Analysis Note :

Analyzed : 2022-03-21 at 11:00 am

Started : 2022-03-15 at 8:00 am

Ended : 2022-03-18 at 9:00 am

Hours/MST% : 73 hours 3.6% 70°F

Attention:

Kit #: 7351615 Result: < 0.3 pCi/l

Location: 1st Floor C23a

Flanders Elem C23a

167 Boston Post Rd

East Lyme, CT 06333-1605

Analysis Note :

Analyzed : 2022-03-21 at 12:00 pm

Started : 2022-03-15 at 8:00 am

Ended : 2022-03-18 at 9:00 am

Hours/MST% : 73 hours 3.5% 70°F

Kit #: 7351625 Result: < 0.3 pCi/l

Location: 1st Floor C17a

Flanders Elem C17a

167 Boston Post Rd

East Lyme, CT 06333-1605

Analysis Note :

Analyzed : 2022-03-21 at 12:00 pm

Started : 2022-03-15 at 8:00 am

Ended : 2022-03-18 at 9:00 am

Hours/MST% : 73 hours 2.8% 70°F

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

EAST LYME, CT
FLANDERS ELEM.

DETECTOR IDENTIFICATION	SAMPLE LOCATION	START TIME	END TIME	NOTES		
		03/15 0800	03/18 0900			
✓ 7348875	MAIN OFFICE	↓	↓			
✓ (DUP.) 7351613	MAIN OFFICE					
✓ 7351605	C07A					
✓ 7349992	A03A					
✓ 7351625	C17A					
✓ 7351615	C23A					
✓ 7351611	C29A					
✓ 7348888	BLANK			▽	▽	
DUP.						



STATE OF CONNECTICUT
 DEPARTMENT OF PUBLIC HEALTH
 RADON PROGRAM
SCHOOL RADON TESTING REPORT FORM

Nov. 2005

The following form must be submitted to the Connecticut Department of Public Health Radon Program within five (5) working days of providing a final written report of radon measurement activities to school personnel. Submit the original, signed copy of this form to the Radon Program at the address listed below:

Attn: School Radon Testing Program
 CT Department of Public Health Radon Program
 410 Capitol Avenue, MS #51 RAD
 Hartford, CT 06134-0308

Name of School: LILLIE B. HAYNES ELEMENTARY SCHOOL

Address: 29 SOCIETY ROAD
 (Street, town, zip code) NIANTIC, CT 06357

Dates of Testing: 03-15 / 18 - 2022

NEHA/NRSB Tester: Christopher Muller
 (or qualified school personnel)

NEHA/NRSB Certification #: 6550019

Please provide the following summary information:

Total # of Rooms Tested: 8

Total # of Rooms Requiring Re-Testing: 0

Total # of Rooms Where Average Results Were At or Above 4.0 pCi/L: 0

Radon measurement activities were carried out in accordance with United States Environmental Protection Agency protocols and the Connecticut Department of Public Health Radon Program's *School Radon Testing Guidance* at the location described above.

Christopher Muller
 Signature of Radon Measurement Professional
 (or designated school authority)

4/12/22
 Date



Phone: (860) 509-7367
 Telephone Device for the Deaf (860) 509-7191
 450 Capitol Avenue - MS # 51RAD
 P.O. Box 340308 Hartford, CT 06134
 An Equal Opportunity Employer

Attention:

Kit #: 7348877 Result: < 0.3 pCi/l
Location: 1st Floor Main Office
Lillie B Haynes Mo
29 Society Rd # Ofc
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 4.3% 70°F

Kit #: 7349998 Result: < 0.3 pCi/l
Location: 1st Floor 10
Lillie B Hayne 10
29 Society Rd # 10
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 4.4% 70°F

Kit #: 7349999 Result: < 0.3 pCi/l
Location: 1st Floor 17
Lillie B Hayne 17
29 Society Rd #17
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 3.6% 70°F

Kit #: 7350000 Result: 0.8 ± 0.3 pCi/l
Location: 1st Floor 57
Lillie B Hayne 57
29 Society Rd # 57
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 3.6% 70°F

Kit #: 7350004 Result: < 0.3 pCi/l
Location: 1st Floor 52
Lillie B Hayne 52
29 Society Rd # 52
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 4.4% 70°F

Kit #: 7350005 Result: < 0.3 pCi/l
Location: 1st Floor 47 North
Lillie B Hayne 47n
29 Society Rd # 47 North
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 3.6% 70°F

Attention:

Kit #: 7351608 Result: < 0.3 pCi/l
Location: 1st Floor 41
Lillie B Haynes 41
29 Society Rd # 41
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 3.5% 70°F

Kit #: 7351626 Result: < 0.3 pCi/l
Location: 1st Floor Blank
Blank
29 Society Rd
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 2.0% 70°F

Kit #: 7351628 Result: < 0.3 pCi/l
Location: 1st Floor 25
Lillie B Haynes 25
29 Society Rd # 25
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 11:00 am
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 3.6% 70°F

Kit #: 7351629 Result: < 0.3 pCi/l
Location: 1st Floor 47 North
Lillie B Haynes 47n
29 Society Rd # 47 North
East Lyme, CT 06333-1525

Analysis Note :
Analyzed : 2022-03-21 at 12:00 pm
Started : 2022-03-15 at 8:00 am
Ended : 2022-03-18 at 8:00 am
Hours/MST% : 72 hours 2.8% 70°F
