




PRODUCT APPROVAL GUIDELINES

The implementation of the new Florida Product Approval system on October 1, 2003 is causing a lot of confusion to everyone affected by the new law. This has, in turn, caused different interpretations by local jurisdictions as to what has to be done at the local level. This guide will hopefully answer those questions and provide guidance to all local jurisdictions for a more consistent enforcement of the law.

BUILDING OFFICIALS ASSOCIATION OF FLORIDA
705 H West S.R. 434, LONGWOOD, FL, 32750
(407) 265-9009 <http://www.boaf.net>

BOAF Product Approval Guidelines

December 5, 2003

What are the options under the new law?

- Local product approval, which means that the product is approved only for that particular jurisdiction or for a specific project.
- Statewide product approval can be obtained under the optional statewide product approval program. The choice to seek an optional statewide approval is at the discretion of the manufacturer.

What products are covered by the Florida Product Approval system?

The covered products are those that affect the structural integrity of buildings. They are:

- Windows
- Skylights
- Exterior doors
- Shutters
- Roofing
- Panel walls
- Structural components
- New and innovative building envelope products

Exceptions:

Structural components covered by the United States Department of Commerce Product Standards [such as softwood lumber, plywood, and structural wood panels]; and

Structural components comprised of materials or products that are assembled or placed in the field [such as concrete/masonry] and are subject to standardized field testing procedures contained within nationally recognized standards adopted within the Code may demonstrate compliance by a batch ticket or bill of lading made available at the site of assembly or placement.

These categories of products must be approved using the standardized Florida Product Approval System *either by the local building department for local use, or by the Florida Building Commission for statewide use.*

Is product approval required for every single product used in a building?

As stated above, categories of products covered by the Florida Product Approval System must be approved using the methods prescribed in the Florida Product Approval System, either by the local building department for local use, or by the Florida Building Commission for statewide use. Other products must demonstrate compliance with the Florida Building Code through the normal plans review process. In both cases, materials and/or components that are used in the installation of these products would not, as long as these materials and/or components are provided and installed as specified by the manufacturer of the product.

Some examples of these are:

- **Roofing systems:** The system would receive the product approval, and the components such as nails, screws, adhesives and the like would be accepted as part of the overall system approval, as long as they were provided and installed as specified by the roofing system manufacturer.

BOAF Product Approval Guidelines

December 5, 2003

- **Connectors:** Nails used to attach truss joists, hurricane clips, wall studs, and the like, would be accepted as part of the connector approval, as long as they were provided and installed as specified by the connector manufacturer.
- **Panel Walls:** Nails, screws, adhesives, and other fasteners used to attach siding, soffits, EIFS, storefronts, and the like, would be accepted as part of the overall system approval, as long as they were provided and installed as specified by the panel wall manufacturer.

How is the new product approval program different for what was done before?

Previously, independent monitoring (Quality Assurance) of the manufacture of a product was only required where the Code required a product to be “listed” or “labeled” by an approved agency, such as Underwriters Laboratories.

Now, products in the eight categories identified above must also have independent monitoring of their manufacturing in addition to those products the Code requires to be “listed” or “labeled”.

Previously building officials would accept test and evaluation reports and listings from “nationally recognized” entities and licensed engineers.

Now, for the eight products, only entities such as evaluation entities, testing laboratories, certification agencies, quality assurance agencies, approved by the Florida Building Commission may be used by a manufacturer to demonstrate compliance with the Code. Additionally, Florida licensed engineers and architects may issue evaluation reports.

Does each product approval application have to be submitted with proof of an audited quality assurance program?

No. Products that have an approved certification mark or listing do not require proof of an audited quality assurance program because this requirement must be met in order to get the certification mark or listing.

What about quality assurance for those products not covered by the Florida Product Approval System?

Since the Commission will only approve entities for the evaluation of the eight categories of products that are covered by the law, it is up to the local jurisdiction to approve all other products for use in their jurisdiction, but they can use similar approval criteria.

What is required for local approval?

A completed “Application for Local Product Approval” must be submitted to the local jurisdiction (See Attachment 1), along with the following required product information:

- Product Name and model number (if any)
- Name, address, reports, and report numbers from at least one of the applicable entities:
 -)Approved Testing Entity with proof of a third party quality assurance program
 -)Approved Evaluation Entity with proof of a third party quality assurance program
 -)Approved Certification Entity
- Evaluation Report from a Florida registered engineer or architect with proof of a third party quality assurance program
- List of the code sections and reference standards with which the product complies
- List of limitations on the product’s compliance and use
- Installation instruction for the product

BOAF Product Approval Guidelines
December 5, 2003

What are local jurisdictions required to do now?

It depends on whether the product has a statewide approval or local approval.

- **Products with Statewide Product Approval:**

The product can be accepted through the plans review process upon confirmation of statewide approval through a listing on the BCIS product approval website (www.floridabuilding.org) and that the product is being used in accordance with its limitations of use.

- **Products without Statewide approval:**

Products without optional Statewide approval have four different options for local approval. (see below). The role of the local jurisdiction is to verify competent proof of compliance with the Code, making sure the product is being used consistent with the limitations of use established by the evaluation. The review of documentation is only to verify the following:

- It is a report in good standing (not rescinded, suspended or revoked).
- That the entity that evaluated the product is independent of the manufacturer and properly accredited/approved.
- That the standard the product is evaluated to is correct, and that there is a statement of compliance with the standard included in the report.

1. Products submitted with a certification mark or listing.

This category requires documentation showing the following information:

- A certification mark or a listing from an approved certification agency.
- A certification that the product complies with the standards adopted by the Code.

This category does not require any evaluation or test reports, or proof of an audited quality assurance program.

2. Products submitted with test reports.

This category requires documentation showing the following information:

- A product test report from an approved testing lab showing which products are covered by the report.
- Verifiable documentation that the product complies with the Code.
- Proof that the product is manufactured under an audited quality assurance program.

3. Products submitted with an evaluation report from an Evaluation Entity.

This category requires documentation showing the following information:

- A product evaluation report from an approved evaluation entity, based on testing or comparative rational analysis, or a combination of both.
- The report indicates that the product is in compliance with the intent of the Code, or equivalent to that required by the Code.
- Proof that the product is manufactured under an audited quality assurance program.

BOAF Product Approval Guidelines

December 5, 2003

4. Products submitted with an evaluation report from a Florida registered architect or engineer.

This category requires documentation showing the following information:

- A signed and sealed product evaluation report based on testing or comparative rational analysis, or a combination of both.
- The report indicates that the product is in compliance with the intent of the Code, or equivalent to that required by the Code.
- Proof that the product is manufactured under an audited quality assurance program.

.How will these product approval requirements affect local plan review approval?

All products in the eight categories must be approved using the uniform Florida Product Approval System, either optional statewide approval or local approval, in order to obtain plan approval. Ensure that the product is being used in accordance within its conditions of use. This is required in order to be in compliance with the product approval requirements.

Will plans submitted prior to October 1, 2003, but not yet approved, be affected by these product approval requirements?

No. Plans submitted for approval prior to October 1, 2003 are not affected by the new requirements. The effective date of the new requirements is October 1, 2003. Therefore, all plans submitted for approval after October 1, 2003, must be designed with products that meet the product approval requirements.

Will permits issued after October 1, 2003, whose plans were approved prior to October 1, 2003, be affected by these product approval requirements?

No. If the plans were approved prior to October 1, 2003, then permits issued for that project after October 1, 2003, will not be affected by the new requirements.

Where can one find a list of the approved agencies?

The list of approved agencies in each category can be printed from the Department of Community Affairs Florida Building Code web page at www.floridabuilding.org.

- Click on the Product Approval link on the left side of the page, and then click on organization search.
- Once the organization is located, click on its name to determine its scope of accreditation.
- For example, a certification agency that has been accredited by ANSI to perform certification of fenestration products only should not be used to certify trusses.
- Similarly, not all testing laboratories can perform all tests. The scope of accreditation will list the tests for which the laboratory is approved.

Who has to submit the required information to the local jurisdiction for approval?

The product manufacturer or the design professional can submit the required application for local approval. Once a product has received local approval, whether it is from a submittal from the manufacturer or the design professional, the application does not have to be repeated.

If an application for product approval is tailored for a site specific project, the required information must be resubmitted for a general local approval or another site specific approval.

BOAF Product Approval Guidelines
December 5, 2003

Is an application for local product approval needed for each product?

No. A manufacturer can submit one application for each product subcategory and then attach a list of the products being submitted for approval. It is important, however, to group the products according to the product subcategory, and to indicate the supporting documentation is a certification mark or listing, a test report, an evaluation report from an evaluation entity, or an evaluation report from a Florida registered architect or engineer.

What is the best way to provide the product approval information to the local jurisdiction, once the product has been approved, either locally or by the State?

For statewide approval, consult the Florida Building Code website: www.floridabuilding.org. If a local jurisdiction does not have computer access, call the Department of Community Affairs at 850-487-1824.

For local approval, each jurisdiction will determine the applicability of the available information.

These guidelines are intended as another building department tool for understanding and applying the Florida Product Approval processes. Although the information contained herein is believed to be accurate and correct, BOAF does not warrant it as such. The only true guidelines are published in the applicable Florida Statutes and Rule.

BOAF Product Approval Guidelines
December 5, 2003

Attachment 1

Form No.: 9B-72.130(4)

August 2003

Florida Building Commission

Application for Local Product Approval

Note: This application is only for approval by local jurisdictions for the following categories of products: panel walls, exterior doors, roofing, skylights, windows, shutters and structural components or for products comprising a building's envelope introduced as a result of new technology.

1. Application for Approval by Method 1 / Method 2 (circle one) for the following category of product: _____

2. Name of Applicant (Company) _____

3. Mailing Address _____

4. Telephone No. (____) _____ Fax No. (____) _____

5. E-Mail Address _____

6. Name and title of applicant's technical representative (if any) _____

Address (if different from address of applicant) _____

Telephone No. (____) _____ Fax No. (____) _____

E-Mail Address _____

Florida Professional Registration No. (if any) _____

Florida Professional Firm Registration number (if any) _____

7. Name of approved third party quality assurance entity _____

Address _____

Telephone No. (____) _____ Fax No. (____) _____

E-Mail Address _____

Name of authorized representative _____

Florida Professional Registration No. (if any) _____

Florida Professional Firm Registration number (if any) _____

BOAF Product Approval Guidelines
December 5, 2003

Florida Building Commission
Application for Local Product Approval
Page Two

8. Provide the following information on a separate sheet:

- Product name and model number (if any)
- Name, address, reports, and applicable report numbers of:
 - (a) Testing entity
 - (b) Evaluation entity
 - (c) Certification entity
- List of requirements the product complies with including Code section numbers and reference standards
- List of limitations on product's compliance and use
- Installation instructions for the product

9. Other information:

Give any other information that may be of assistance to the local jurisdiction in considering this application. (Attach a separate sheet, if needed.)

10. Name and title of person authorized to sign on behalf of applicant

Signature _____

Date _____

RULE 9B-72 State Product Approval

9B-72.005 Scope.

(1) Products in the following categories as defined by subcategories of subsection 9B-72.010(31), F.A.C., shall be available for approval by the Commission pursuant to Rule 9B-72.090, F.A.C., for use in the state:

- (a) Panel Walls;
- (b) Exterior Doors;
- (c) Roofing Products;
- (d) Skylights;
- (e) Windows;
- (f) Shutters; and
- (g) Structural components.

(2) This rule applies to approval of products and systems, which comprise the building envelope and structural frame, for compliance with the structural requirements of the Florida Building Code.

Specific Authority 553.842(1) FS. Law Implemented 553.842(5) FS. History—New 11-22-06.

9B-72.010 Definitions.

The following terms have the meanings indicated.

- (1) Accreditation means a procedure by which a Commission approved body gives formal recognition that a body or person is competent to carry out specific tasks.
- (2) Approved accreditation entity body means a Commission approved, third party entity, which initially accredits and subsequently monitors, on a continuing basis, the competency and performance of an agency related to carrying out specific tasks.
- (3) Approved certification agency means an organization approved by the Commission pursuant to subsection 9B-72.100(4), F.A.C., to certify products.
- (4) Approved product evaluation entity means an organization recognized by Florida law or approved by the Commission pursuant to subsection 9B-72.100(1), F.A.C., to evaluate products, for compliance with the Code or intent of the Code or the standards referenced therein resulting in the issuance of an evaluation report.
- (5) Approved testing laboratory means a laboratory approved by the Commission pursuant to subsection 9B-72.100(3), F.A.C., to test products for compliance with the standards specified in the Code.
- (6) Approved quality assurance entity means an entity approved by the Commission pursuant to subsection 9B-72.100(5), F.A.C., to provide oversight and determine that the product or system is being manufactured or assembled, per the submitted description, test results, or calculations to establish continual product performance.
- (7) Approved validation entity means a third party entity approved by the Commission pursuant to subsection 9B-72.100(2), F.A.C., which shall certify to the Commission the product's compliance with the standards specified in the Code or intent of the Code for use in state approval.
- (8) Category of products means the type of products identified in Rule 9B-72.060, F.A.C.
- (9) Certification means the act of certifying.
- (10) Certification mark means a protected mark, applied or issued under the rules of a certification system, indicating that confidence is provided that the relevant product, process or service is in compliance with a specific standard or other normative document.
- (11) Certify means the act of providing a written statement or labeling or listing confirming that a standard or criteria is met.
- (12) Code means the Florida Building Code.
- (13) Commission means the Florida Building Commission.
- (14) Comparative analysis means an engineering analysis that may include interpolation based on testing of a product.
- (15) Evaluation means an assessment of product conformance to the Code by comparing against standards or intent of the Code using testing or comparative analysis or rational analysis or a combination thereof.
- (16)(a) Evaluation report means a report based upon testing or comparative or rational analysis, or a combination thereof, from an approved product evaluation entity or a licensed Florida professional engineer or architect indicating that the product

was evaluated to be in compliance with the Code or the intent of the Code and that the product complies with the Code or is, for the purpose intended, at least equivalent to that required by the Code.

- (b) Legacy report means an evaluation report that was originally issued by the National Evaluation Service (NES), Building Official Council of America Evaluation Services (BOCA ES), International Council of Building Officials Evaluation Service (ICBO ES), or Southern Building Code Congress International Incorporated Public Safety Testing and Evaluation Services (SBCCI PST & ES), and that was in good standing at the time these organizations came together to form the International Code Council Evaluation Services (ICC ES); or an evaluation report issued as a result of an application received by one of the above-noted organizations prior to March 1, 2003, with the application being approved by March 1, 2004.
- (17) Inspection means conformity evaluation to the applicable Code section by observation and judgement accompanied as appropriate by measurement, testing or gauging or any other method that will allow for determination of compliance with the Code.
- (18) Intent of the Code means required performance by the code where no standardized method for evaluating compliance by test; or comparative analysis or rational analysis; or a combination thereof is specified by the code.
- (19) Labeled means devices, equipment or materials to which have been affixed a label, seal, symbol or other identifying mark of a nationally recognized testing laboratory, inspection agency or other organization concerned with product evaluation that maintains periodic inspection of the production of the above labeled items and by whose label the manufacturer attests to compliance with applicable nationally recognized standards.
- (20) Listed means equipment or materials included in a list published by a nationally recognized testing laboratory, inspection agency or other organization concerned with product evaluation that maintains periodic inspection of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner. The means for identifying listed equipment may vary for each testing laboratory, inspection agency or other organization concerned with product evaluation, some of which do not recognize equipment as listed unless it is also labeled. The building official should use the system employed by the listing organization to identify a listed product.
- (21) Panel (part of a structure) means the section of a floor, wall or roof comprised between the supporting frame of two adjacent rows of columns and girders or column bands of floor or roof construction.
- (22) Product means any individual type of manufactured goods, system or method of construction.
- (23) Product Approval: State product approval means the approval of a product or system of construction by the Commission for acceptance of a product on a state or regional basis consistent with an evaluation conducted pursuant to Rule 9B-72.070, F.A.C.
- (24) Product Model means a method of identification of products that is more specific than its subcategory or individual units as utilized in the field.
- (25) Program System Administrator means a public or private entity qualified to review product approval and product entity documentation for compliance with this rule.
- (26) Rational analysis means a standardized or non-standardized method by which a Florida Registered Architect or a licensed Florida Professional Engineer or approved evaluation entity uses mathematical or scientific analysis to evaluate the product behavior and to demonstrate that the product evaluated complies with the code for which the evaluation or engineering report is issued. Rational analysis shall be performed in accordance with well-established principles of mechanics and sound engineering practices.
- (27) Scope of Accreditation means the specific standard test method, calibration services or other functions for which the organization is accredited.
- (28) Standard means a prescribed set of rules, conditions, or requirements concerning: definition of terms; classification of components; specification of materials, performance, or operation; delineation of procedures for measure the quantity or quality of materials, products, systems, services, or practices referenced in the Code.
- (29) Standard test method means a specified technical procedure for performing a test.
- (30) Structural component means any part or assembly of buildings that comprises the main wind force resisting system and components or cladding.
- (31) Sub-category of product or construction system means a specific functionality:
 - (a) For exterior door: 1. exterior door assemblies: roll-up, sectional, sliding, swinging, automatic; pre-engineered roof

- access hatches; and products introduced as a result of new technology, 2. exterior door components and products introduced as a result of new technology;
- (b) For windows: awning, casement, dual action, double hung, single hung, fixed, horizontal slider, projected, pass through, mullions, and products introduced as a result of new technology;
 - (c) For panel walls: siding, soffits, exterior insulation finish system (EIFS), storefronts, curtain walls, wall louver, glass block, and products introduced as a result of new technology;
 - (d) For roofing products: built up roofing, modified bitumen roof system, single ply roof systems, spray applied polyurethane roof system, roofing fasteners, roofing insulation, asphalt shingles, wood shingles and shakes, roofing slate, roof tile adhesives, cements-adhesives-coatings, liquid applied roof systems, underlayments, metal roofing, roofing tiles, waterproofing, roofing accessories that are an integral part of the roofing system and products introduced as a result of new technology;
 - (e) For shutters: accordion, Bahama, storm panels, colonial, roll-up, pre-engineered equipment, protection, and products introduced as a result of new technology;
 - (f) For skylights: skylight, and products introduced as a result of new technology; and
 - (g) For structural components: truss plates, wood connectors, anchors, exterior coolers-freezers, insulation form systems, engineered lumber, pre-engineered air conditioner stands, structural wall components, and roof deck, and products introduced as a result of new technology.
- (32) Test means a technical operation that consists of the determination of one or more characteristics of a given product, process or service according to a specified procedure.
- (33) Test report means a report from an approved testing laboratory which provides performance data showing compliance with a code requirement as determined by a referenced standard test method or equivalent standard test method pursuant to Rule 9B-72.180, F.A.C., and which identifies products covered by the report and limitations on the products' use.
- (34) Third party means an entity independent of the manufacturer (first Party) and the buyer (second party) certified in accordance with Rule 9B-72.110, F.A.C.
- (35) Validation means determination of compliance pursuant to Rule 9B-72.080, F.A.C., for state approval.

Specific Authority 553.842(1) FS. Law Implemented 553.842(1) FS. History--New 5-5-02, Amended 9-4-03, 11-22-06.

9B-72.030 Exceptions.

Products listed in Rule 9B-72.005, F.A.C., shall be approved according to the provisions of this rule.

- (1) Prescriptive. Products that have prescriptive specification standards and are manufactured under quality assurance procedures as specified in the Code will be deemed approved. Such products shall include but not be limited to the following:
 - (a) Structural components covered by United States Department of Commerce Product Standards;
 - (b) Structural components comprised of products that are assembled or placed in the field and are subject to standardized field testing procedures contained within nationally recognized standards adopted within the Code may demonstrate compliance by a batch ticket or bill of lading made available at the site of assembly or placement; and
 - (c) Custom (one of a kind) pre-engineered buildings.
- (2) Performance. Products, methods and systems of construction specifically addressed in the code through performance criteria shall demonstrate compliance pursuant to Rule 9B-72.070, F.A.C., and shall be approved pursuant to Rule 9B-72.090, F.A.C.

Specific Authority 553.842(1) FS. Law Implemented 553.842(5), (7) FS. History--New 5-5-02, Amended 9-4-03, 3-9-04, 11-22-06.

9B-72.040 Product Evaluation and Quality Assurance for Local Approval.

Specific Authority 553.842(1) FS. Law Implemented 553.842(5), (6), (8) FS. History--New 5-5-02, Amended 9-4-03, Repealed 11-22-06.

9B-72.060 Optional Statewide Approval Generally.

State approval of products listed in Rule 9B-72.005, F.A.C., and not covered by subsection 9B-72.030(1), F.A.C., or revisions to existing statewide product approvals require evaluation of product compliance with the Code by a method listed in Rule 9B-72.070, F.A.C., validation of the evaluation as required by Rule 9B-72.080, F.A.C., and approval per Rule 9B-72.090, F.A.C. Validation of

compliance with the Code shall be performed by approved Validation Entities. Approval shall be performed by the Commission. All products used in construction covered by the Code shall comply with the provisions or standards contained therein or with the intent of the Code.

Specific Authority 553.842(1) FS. Law Implemented 553.842(6) FS. History--New 5-5-02, Amended 9-4-03, 11-22-06.

9B-72.070 Product Evaluation and Quality Assurance for State Approval.

- (1) Method 1. Products specifically addressed in the code through performance criteria and standard test methods or standard comparative or rational analysis methods, which cannot be approved through the plan review and inspection process, shall demonstrate compliance with the Code through one of the following:
 - (a) A certification mark or listing from an approved certification agency indicating that the product is in compliance with the Code. Indication of compliance shall be by certification to standards adopted by the Code.
 - (b) A test report from an approved testing laboratory, which identifies which products are covered by the test report and provides verifiable documentation indicating the product tested complies with the Code.
 - (c) An evaluation report from an approved product evaluation entity that covers the subject product and, based upon standard tests or standard comparative or rational analysis, or a combination thereof, indicates that the product was evaluated to be in compliance with the Code and that the product is, for the purpose intended, at least equivalent to that required by the Code.
 - (d) An evaluation report from a Florida Registered Architect or a licensed Florida Professional Engineer developed and signed and sealed, based upon standard tests or standard comparative or rational analysis, or a combination thereof and indicates that the product was evaluated to be in compliance with the Code and that the product is, for the purpose intended, at least equivalent to that required by the Code.
 - (e) Rational engineering analysis cannot be used in lieu of a standard test required by the Code for approval of products within the scope of the standard, except that project specific approval by the local authorities having jurisdiction in accordance with alternate methods and materials authorized in the Code.
 - (f) A legacy report from a nationally recognized model code organization may be used if the report demonstrates compliance with the Code.
- (2) Method 2. Products for which there are no specific standardized tests or comparative or rational analysis methods of evaluation established as required by the Code shall demonstrate compliance with the intent of the Code through one of the following:
 - (a) An evaluation report from an approved product evaluation entity and provides verifiable documentation indicating the product complies with the intent of the Code.
 - (b) An evaluation report from a Florida Registered Architect or a licensed Florida Professional Engineer based on testing or comparative or rational analysis or combination thereof, which provides verifiable documentation indicating the product complies with the intent of the Code.
 - (c) Rational engineering analysis cannot be used in lieu of a standard test required by the Code for approval of products within the scope of the standard, except that project specific approval by the local authorities having jurisdiction in accordance with alternate methods and materials authorized in the Code.
 - (d) A legacy report from a nationally recognized model code organization may be used if the report demonstrates compliance with the code.
- (3) Products listed in Rule 9B-72.005, F.A.C., shall be manufactured under a quality assurance program audited by an approved quality assurance entity.
- (4) Evaluation Report and Test Report Documentation Requirements. All reports and documentation required in subsections 9B-72.070(1) and (2), F.A.C., shall contain the information listed below. Design drawings submitted for permitting purposes are not to be construed to be an evaluation report and do not require this information. When the Code requires a standard test as a component of a product approval using the evaluation methods, the test lab must be accredited by an approved accreditation body for the test performed. The entity issuing the evaluation report or certification is responsible to ensure that the test lab is accredited.
 - (a) Name and address of the manufacturer, evaluation entity, engineer or architect or testing laboratory.
 - (b) Statement of compliance with the appropriate section or standard of the Code.

- (c) Complete description of the product, including all drawings, manufacturer's product designations and materials, except materials specifications identified as proprietary.
 - (d) Technical documentation, including all substantiating data, supporting the compliance statement. Substantiating data shall include all test reports and calculations which may be referenced within the evaluation report.
 - (e) Installation requirements. Installation instructions including attachments shall be developed by an evaluation entity, test lab or by the manufacturer's licensed design professional.
 - (f) Limitations and conditions of use.
 - (g) Certification of independence in conformance with Rule 9B-72.110, F.A.C.
 - (h) Name, title and signature of person authorized to sign on behalf of entity or signature, registration number and seal in the case of architects and engineers.
- (5) The following documents shall be submitted for approval of listed products or products bearing a certification mark or an approved certification agency as complying with the standards established by the Code:
- (a) Name and address of manufacturer and certification agency.
 - (b) Manufacturer's product model number or identifier and product description.
 - (c) Indication of the standard the product was tested to.
 - (d) Performance level of the product and conditions or limitations of use.
 - (e) Installation requirements.
 - (f) Agency certificate designating product certification.
- (6) Review and verification of installation instructions required under paragraph 9B-72.070(4)(e), F.A.C. Prior to posting installation instructions, including anchorage requirements, on the Building Codes Information System on the Internet, www.floridabuilding.org, they shall be reviewed or verified by the evaluation entity, test lab, the architect or engineer of record, or by a manufacturer's licensed design professional.
- (7) Review and verification of installation instructions required under paragraph 9B-72.070(5)(e), F.A.C. Prior to posting installation instructions, including anchorage requirements, on the Building Codes Information System, www.floridabuilding.org, they shall be reviewed or verified by the certification agency or by a manufacturer's licensed design professional.

Specific Authority 553.842(1) FS. Law Implemented 553.842(6) FS. History—New 5-5-02, Amended 9-4-03, 11-22-06.

9B-72.080 Product Validation by Approved Validation Entity for State Approval.

Validation of compliance with the Code shall be performed by approved validation entities through the following steps:

- (1) Verification that the testing, evaluation and quality assurance requirements established by Rule 9B-72.070, F.A.C., are met and that all documentation is in order.
- (2) Validation of the method of compliance using the validation checklist in subsection 9B-72.130(3), F.A.C.
- (3) Certification to the Commission that the documentation submitted for the product indicates the product complies with the Code.
- (4) Products listed by approved certification agencies as complying with standards established by the Code shall be approved by the Commission absent compliance with this section.

Specific Authority 553.842(1) FS. Law Implemented 553.842(1) FS. History—New 5-5-02, Amended 11-22-06.

9B-72.090 Product Approval by the Commission.

- (1) Approval of a product or system of construction for state acceptance shall be performed by the Commission through the following steps:
 - (a) A product manufacturer or owner of a proprietary system or method of construction, or its designee (applicant) shall apply to the Commission for approval by filing an application in accordance with subsection 9B-72.130(2), F.A.C., validated in accordance with Rule 9B-72.080, F.A.C., and submitting fees pursuant to subsection 9B-72.090(2), F.A.C. Application shall be made through the Building Codes Information System on the Internet, www.floridabuilding.org, and payment shall be by credit card or electronic check.
 - (b) The applicant submits all documentation required and fees in accordance with Rule 9B-72.070 and subsection 9B-72.090(2), F.A.C., respectively.

- (c) Upon Commission acceptance of the required documentation pursuant to Rule 9B-72.070, F.A.C., and validation of compliance with the Code pursuant to Rule 9B-72.080, F.A.C., the Commission may approve the product for use statewide in accordance with its approval and limitations of use unless credible evidence is provided questioning the validity of the documentation submitted in support of the application for approval.
 - (d) Approval shall be valid until such time as the product changes decreasing the product's performance the standards or provisions of the Code affecting the product change, or the approval is otherwise suspended, revoked, or superseded by a Commission approved revision to the approval. Changes to the Code shall not be construed as voiding the approval of products previously installed in existing buildings provided such products met building code requirements at the time the product was installed.
 - (e) When a new edition of the Code does not require a material or substantive change for an approved product, the manufacturer of the approved product shall affirm that his or her approved product meets the new edition of the Code. Self-affirmation is subject to review and verification by the Program Administrator.
 - (f) Manufacturer or the manufacturer's designee shall notify the Commission if it makes changes to the product which decrease the product's performance.
 - (g) Manufacturer shall notify the Commission when the quality assurance requirements of subsection 9B-72.070(3), F.A.C., are no longer in place.
- (2) Fees for state approval of products.
- (a) Fee for approval, Three Hundred Dollars (\$300.00) per sub category or product. The Commission shall review annually and adjust fees accordingly.
 - (b) Fee for reinstatement after suspension, Fifty Dollars (\$50.00) per product, plus billable staff hours at Fifty Dollars (\$50.00) per hour, plus consultant fees.
 - (c) Fees for approval of evaluation entities, certification agencies, testing laboratories and validation entities; for first time approval, Five Hundred Dollars (\$500.00), annual renewal fee, One Hundred Dollars (\$100.00), revision fee, One Hundred Dollars (\$100.00).
 - (d) Fee for revision of an existing approval, Three Hundred Dollars (\$300.00) for a revision that results in a material change to the performance of a product or product design specification or both, and which may include addition of products within the same subcategory.
 - (e) Fee for editorial revisions of an existing product approval that does not result in material change to the performance of a product or product design specification or both, One Hundred Dollars (\$100.00).
 - (f) Fee for affirmation of an existing product approval for compliance with a new edition of the standards adopted by the Code, Fifty Dollars (\$50.00).
- (3) Applications, affirmations and revisions shall be made through the Building Codes Information System on the Internet, www.floridabuilding.org, and payment shall be by credit card or electronic check.

Specific Authority 553.77(1)(i), 553.842(1) FS. Law Implemented 553.842(1) FS. History--New 5-5-02, Amended 9-4-03, 11-22-06.

9B-72.100 Approval of Product Evaluation Entities, Product Validation Entities, Testing Laboratories, Certification Agencies, Quality Assurance Agencies and Accreditation Bodies.

- (1) Approved Product Evaluation Entities. Approval by the Commission is limited to the scope established by Section 553.842, F.S.
- (a) The following entities are approved evaluation entities:
 1. The National Evaluation Service (NES);
 2. The International Conference of Building Officials Evaluation Services (ICBO ES);
 3. The Building Officials and Code Administrators International Evaluation Services (BOCA ESI);
 4. The Southern Building Code Congress International Evaluation Services (PST ESI);
 5. The Miami-Dade County Building Code Compliance Office Product Control Division (MDCBCCOPCD); and
 6. The International Code Council, International Evaluation Services (IES).
 - (b) Architects and engineers licensed in this state are also approved to conduct product evaluation.
 - (c) Evaluation entities, other than architects and engineers registered in this state, shall apply to the Commission for approval as an evaluation entity by filing an application in accordance with subsections 9B-72.130(1) and 9B-

72.090(3), F.A.C., including a Certificate of Independence in accordance with Rule 9B-72.110, F.A.C., and submitting fees pursuant to subsection 9B-72.090(2), F.A.C.

(2) Approved Validation Entities.

- (a) An entity shall be approved by the Commission as a validation entity if it is a Commission approved evaluation entity, testing laboratory or certification agency and it certifies to the Commission compliance with standards established by the Code or intent of the Code. Architects and engineers licensed in this state are also approved to conduct validation for the state approval. Validation by an approved testing laboratory acting as a validation entity shall be limited to the scope for which they are accredited.
- (b) An entity may be approved as a validation entity after applying to the Commission for approval. Applications must be submitted in accordance with subsections 9B-72.130(1) and 9B-72.090(3), F.A.C., including a Certificate of Independence in accordance with Rule 9B-72.110, F.A.C., and fees submitted pursuant to subsection 9B-72.090(2), F.A.C. Application shall be made through the Building Codes Information System on the Internet, www.floridabuilding.org, and payment shall be by credit card or electronic check.
- (c) Approvals shall be valid until such time as Commission approval requirements change, the entity no longer qualifies under current requirements or the approval is suspended or revoked.

(3) Approved Testing Laboratory Criteria. Approval by the Commission is limited to the scope of accreditation established by approved accreditation entities.

- (a) An entity shall be approved by the Commission as an approved testing laboratory if it complies with one of the following. Approval shall be limited to those procedures listed on the certificate of accreditation or accreditation listing issued by the accreditation body.
 - 1. Testing laboratories accredited by American Association for Laboratory Accreditation (A2LA) that meet the requirements of the International Organization for Standardization/International Electrotechnical Commission (ISO/IEC) Guide 17025: General Requirements for the Competence of Calibration and Testing Laboratories or other standard certified as equivalent by the accrediting entity pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.
 - 2. Testing laboratories accredited by National Voluntary Laboratory Accreditation Program (NVLAP) that meet the requirements of ISO/IEC Guide 17025: General Requirements for the Competence of Calibration and Testing Laboratories or other standard certified as equivalent by the accrediting entity pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.
 - 3. Testing laboratories accredited by approved product evaluation entities that meet the requirements of ISO/IEC Guide 17025: General Requirements for the Competence of Calibration and Testing Laboratories or other standard certified as equivalent by the accrediting entity pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.
 - 4. Testing laboratories accredited by other approved accreditation bodies that meet the requirements of ISO/IEC Guide 17025: General Requirements for the Competence of Calibration and Testing Laboratories or other standard certified as equivalent by the accrediting entity pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.
- (b) Testing laboratories shall apply to the Commission for approval by filing and application in accordance with subsections 9B-72.130(1) and subsection 9B-72.090(3), F.A.C., including a Certificate of Independence in accordance with Rule 9B-72.110, F.A.C., and submitting fees pursuant to subsection 9B-72.090(2), F.A.C.
- (c) Approvals shall be valid until such time as Commission approval requirements change, the testing laboratory no longer qualifies under current requirements; the accreditation expires, or is removed, or is both expired and removed; or the approval is suspended or revoked.

(4) Approved Certification Agency Criteria. Approval by the Commission is limited to the scope of accreditation established by approved accreditation entities.

- (a) An entity shall be approved by the Commission as a certification agency if it complies with one of the following. Approval shall be limited to those procedures listed on the certificate of accreditation or accreditation listing issued by the accreditation body:
 - 1. Certification Agencies accredited by ANSI that meet the requirements of ISO/IEC Guide 65: General Requirements

for Bodies Operating Product Certification Systems or other standard certified as equivalent by the accrediting entity pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.

2. Certification Agencies accredited as meeting the requirements of ISO/IEC Guide 65: General Requirements for Bodies Operating Product Certification Systems or other standard certified as equivalent by the accrediting entity pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.
 3. Lumber grading or inspection agencies approved by the American Lumber Standards Committee (ALSC) or other agency approved by the Commission as equivalent, in accordance with United States Department of Commerce "Voluntary Product Standard: DOC PS 20-99," "American Softwood Lumber Standard."
- (b) Certification Agencies shall apply to the Commission for approval by filing an application as provided by subsections 9B-72.130(1) and 9B-72.090(3), F.A.C., including a Certificate of Independence in accordance with Rule 9B-72.110, F.A.C., and submitting fees pursuant to subsection 9B-72.090(2), F.A.C.
- (c) Approvals shall be valid until such time as Commission approval requirements change, the certification agency no longer qualifies under current requirements; the accreditation expires, or is removed, or is both expired and removed; or the approval is suspended or revoked.
- (5) Approved Quality Assurance Agency Criteria. Approval by the Commission is limited to the scope of accreditation established by approved accreditation entities.
- (a) An entity shall be approved by the Commission as a quality assurance agency if it complies with one of the following. Approval shall be limited to those procedures listed on the certificate of accreditation issued by the accreditation body. Architects and engineers licensed in this state are exempt from the requirements for independent audits of financial accounts and records required by ISO/IEC Guide TR 17020.
1. Quality assurance agencies accredited as meeting the requirements of ISO/IEC Guide TR 17020: 1998, General Criteria for the Operation of Various Types of Bodies Performing Inspection or other standard certified as equivalent by an approved product evaluation entity pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.
 2. Quality assurance agencies accredited as meeting the requirements of ISO/IEC Guide TR 17020: 1998, General Criteria for the Operation of Various Types of Bodies Performing Inspection or other standard certified as equivalent by an approved certification agency pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.
 3. Quality assurance agencies accredited as meeting the requirements of ISO/IEC Guide TR 17020: 1998, General Criteria for the Operation of Various Types of Bodies Performing Inspection or other standard certified as equivalent by an approved accreditation body pursuant to Rule 9B-72.180, F.A.C., and approved by the Commission.
- (b) Quality assurance agencies shall apply to the Commission for approval by filing an application in accordance with subsections 9B-72.130(1) and 9B-72.090(3), F.A.C., including a Certificate of Independence in accordance with Rule 9B-72.110, F.A.C., and submitting fees pursuant to subsection 9B-72.090(2), F.A.C. Application shall be made through the Building Codes Information System on the Internet, www.floridabuilding.org, and payment shall be by credit card or electronic check.
- (c) Approvals shall be valid until such time as Commission approval requirements change, the quality assurance agency no longer qualifies under current requirements; the accreditation expires, or is removed, or is both expired and removed; or the approval is suspended or revoked.
- (d) Quality assurance agencies shall audit the quality assurance program of manufacturers and audit production quality of products. Auditing of a quality assurance program shall be by one or more of the following methods: visits to manufacturing facilities, inspection of products at construction sites, inspection of products at state distribution facilities or testing of regular production items. Such auditing shall be performed at intervals not to exceed 12 months.
- (e) Commission approved certification agencies are also approved as quality assurance entities for the products covered by their certification program.
- (6) Approved Accreditation Body Criteria.
- (a) The following are recognized by the Commission as approved accreditation bodies for accrediting testing laboratories, certification programs and quality assurance program auditors/inspection bodies:
1. Entities accrediting testing laboratories, certification agencies and quality assurance agencies pursuant to subsections

9B-72.100(3), (4) and (5), F.A.C.

2. Bodies operating acceptance/accreditation programs for testing bodies pursuant to ISO/IEC Guide 58, Calibration and Testing Laboratory Accreditation Systems – General Requirements for Operation and Recognition.
 3. Bodies operating acceptance/accreditation programs for certification programs pursuant to ISO/IEC Guide 61, General Requirements for Assessment and Accreditation of Certification/Registration Bodies.
 4. Bodies operating acceptance/accreditation programs for quality assurance/inspection bodies pursuant to ISO/IEC Guide TR 17010: 1998, General Requirements for Bodies Providing Accreditation of Inspection Bodies.
- (b) Where accrediting bodies utilize standards other than the ISO accreditation standards referenced in Rule 9B-72.100, F.A.C., they shall provide a certification of equivalence pursuant to Rule 9B-72.180, F.A.C., to the Commission for approval pursuant to subsection 9B-72.180(2), F.A.C.
- (c) Approvals shall be valid until such time as Commission approval requirements change, the accreditation body no longer qualifies under current requirements or the approval is suspended or revoked.
- (d) A Commission approved accreditation body shall not perform the functions of a testing body.

Specific Authority 553.842(9) FS. Law Implemented 553.842(9) FS. History--New 5-5-02, Amended 9-4-03, 3-9-04, 11-22-06.

9B-72.110 Criteria for Certification of Independence.

A certification of independence shall be provided by a Florida registered architect or licensed professional engineer as applicable or by an officer of the entity, agency or laboratory who is responsible for operation of said entity, agency or laboratory that attests to the following:

- (1) The entity, agency or laboratory does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products tested or labeled by the agency.
- (2) The entity, agency or laboratory is not owned, operated or controlled by any company manufacturing or distributing products it tests or labels.
- (3) The Florida registered architect or licensed professional engineer performing an evaluation does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the reports are being issued.
- (4) The Florida registered architect or licensed professional engineer performing an evaluation does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

Specific Authority 553.842(1) FS. Law Implemented 553.842(1), (8) FS. History--New 5-5-02, Amended 11-22-06.

9B-72.120 List of Approved Product Evaluation Entities, Validation Entities, Testing Laboratories, Certification Agencies, Quality Assurance Agencies and Accreditation Bodies.

The Commission shall make available a current list of approved product evaluation entities, testing laboratories, certification agencies, quality assurance agencies and accreditation bodies on its website, the Building Codes Information System, www.floridabuilding.org.

Specific Authority 553.842(13) FS. Law Implemented 553.842(13) FS. History--New 5-5-02, Amended 11-22-06.

9B-72.130 Forms.

The following forms are adopted for use in reference to the Product Evaluation and Approval System. Copies of these forms are available from the Department of Community Affairs, Codes and Standards Section, 2555 Shumard Oak Boulevard, Tallahassee, Florida 32399, and via the Building Codes Information System on the Internet, www.floridabuilding.org.

- (1) Florida Building Commission, Application for Organization/Entity Approval, Form No. 9B-72.130(1), updated October 11, 2005 (electronic version).
- (2) Florida Building Commission, Application for State Product Approvals, Form No. 9B-72.130(2), updated October 11, 2005 (electronic version).
- (3) Validation Checklist for State Approval, Form No. 9B-72.130(3), updated September 4, 2003 (electronic version).

Specific Authority 553.842(1) FS. Law Implemented 553.842(1) FS. History--New 5-5-02, Amended 9-4-03, 11-22-06.

9B-72.135 Revisions to Product Approvals or Entity Approvals.

Approval of revisions to state approved products or approved entities shall be performed by the Commission as follows:

- (1) A product manufacturer or approved entity shall submit a revision for approval by filing an application in accordance with subsection 9B-72.130(2), F.A.C., validated in accordance with Rule 9B-72.080, F.A.C., and submitting fees pursuant to subsection 9B-72.090(2), F.A.C. Revisions shall be made through the Building Codes Information System on the Internet, www.floridabuilding.org, and payment shall be by credit card or electronic check. The revision will carry the same Florida Product Approval number as the original approval with the addition of a revision number assigned, R1, R2, as applicable.
- (2) Revisions to all data will be allowed.
- (3) Once a revision is approved by the Commission, the approved revision will supersede the original approval.

Specific Authority 553.842(1) F.S. Law Implemented 553.842(6) F.S. History--New 11-22-06.

9B-72.160 Revocation or Modification of Product Approvals and Entity Certifications.

(1) Product Approval Revocation or Suspension.

(a) Any product approval shall be revoked or suspended for any of the following reasons:

1. Failure to maintain certification, evaluation reports or testing in good standing with a Commission approved entity which conducted the testing or comparative or rational analysis, or combination thereof on which the product approval is based.
2. Suspension or revocation of the certification, evaluation report or testing report issued by a Commission approved entity on which the approval is based, for just cause.
3. Failure to maintain quality assurance programs for the manufacture of the approved products as required by this document.
4. Failure to correct manufacturing deficiencies required to bring the product within specifications of the originally approved product or alternatively to demonstrate in a manner consistent with this document, that the product's performance complies with the standards established by the Code.
5. Advertising and sales of the product for uses not consistent with conditions or limitations of its approval.
6. Determination that the product was approved based on misrepresentations in the application for approval.
7. Failure of the manufacturer to cooperate with a Commission ordered investigation.

(b) The Commission may suspend the approval of a product based on any provision of subsection 9B-72.160(1), F.A.C., until such time as the manufacturer demonstrates the product is currently in compliance with this document.

(c) The Commission shall initiate an investigation based on a written complaint containing substantial material evidence by any substantially affected party.

(d) The Commission shall clearly post the status of product approvals, denials, or suspensions on its website, the Florida Building Codes Information System, www.floridabuilding.org.

(2) Revocation or suspension of evaluation entity, certification agency, testing laboratory, validation entity, quality assurance agencies or accreditation body approval.

(a) The Commission shall revoke or suspend the approval of any evaluation entity, certification agency, testing laboratory, quality assurance agency, or validation entity other than those specifically identified in Section 553.842(9)(a), F.S., for one or more of the following reasons:

1. Failure to maintain accreditation by a Commission approved accreditation body.
2. Suspension or revocation of accreditation by a Commission approved accreditation body for failure to meet Commission accreditation standards or equivalent pursuant to Rules 9B-72.100 and 9B-72.180, F.A.C.
3. Determination by the Commission that any requirement set forward in this document has been violated.
4. Determination that the criteria for independence from any manufacturer set forth in Rule 9B-72.110, F.A.C., has been violated.
5. Determination that the entity is not independent pursuant to Rule 9B-72.110, F.A.C., of any competing manufacturer of the manufacturer to whom the entity provided services on which Florida jurisdictions' product approval is based.
6. An entity has misrepresented its accreditations or other material information on its application for approval.
7. Failure to conduct investigations of products authorized by Rule 9B-72.170, F.A.C.

553.8425 Local product approval.--

- (1) For local product approval, products or systems of construction shall demonstrate compliance with the structural windload requirements of the Florida Building Code through one of the following methods:
 - (a) A certification mark, listing, or label from a commission-approved certification agency indicating that the product complies with the code;
 - (b) A test report from a commission-approved testing laboratory indicating that the product tested complies with the code;
 - (c) A product-evaluation report based upon testing, comparative or rational analysis, or a combination thereof, from a commission-approved product evaluation entity which indicates that the product evaluated complies with the code;
 - (d) A product-evaluation report or certification based upon testing or comparative or rational analysis, or a combination thereof, developed and signed and sealed by a Florida professional engineer or Florida registered architect, which indicates that the product complies with the code;
 - (e) A statewide product approval issued by the Florida Building Commission; or
 - (f) Designation of compliance with a prescriptive, material standard adopted by the commission by rule under s. 553.842(16).
- (2) For product-evaluation reports that indicate compliance with the code based upon a test report from an approved testing laboratory and rational or comparative analysis by a Florida registered architect or Florida professional engineer, the testing laboratory or the evaluating architect or engineer must certify independence from the product manufacturer.
- (3) Local building officials may accept modifications to approved products or their installations if sufficient evidence is submitted to the local building official to demonstrate compliance with the code or the intent of the code, including such evidence as certifications from a Florida registered architect or Florida professional engineer.
- (4) Products demonstrating compliance shall be manufactured under a quality assurance program audited by an approved quality assurance entity.
- (5) Products bearing a certification mark, label, or listing by an approved certification agency require no further documentation to establish compliance with the code.
- (6) Upon review of the compliance documentation, and a finding that the product complies with the code, the authority having jurisdiction or a local building official shall deem the product approved for use in accordance with its approval and limitation of use.
- (7) Approval shall be valid until such time as the product changes and decreases in performance; the standards of the code change, requiring increased performance; or the approval is otherwise suspended or revoked. Changes to the code do not void the approval of products previously installed in existing buildings if such products met building code requirements at the time the product was installed.

History.--s. 19, ch. 2005-147.

equivalent to ASTM E 330-84, ASTM E 1886-97 and ASTM E 1996-99 except for the High Velocity Hurricane Zone (HVHZ).

- (2) Standards which meet or exceed standards referenced by the 2004 edition of the Code and recognized as equivalent for determining Code compliance are:
 - (a) AAMA/CSA/WDMA 101/I.S. 2/A440-05 is equivalent to AAMA/WDMA/101/I.S./NAFS-02 and AAMA/WDMA 1600/I.S. 7-00 for skylights only;
 - (b) ASTM D 5055-2000 is equivalent to ASTM D 5055-02;
 - (c) AAMA 501-94 is equivalent to AAMA 501-05; and
 - (d) AAMA 103.3-83 is equivalent to AAMA 103.3-05.
- (3) Equivalence of product standards for specific product application. Standards which meet or exceed standards referenced by the Code and certified as equivalent for determining code compliance by one of the following entities shall be considered as equivalent by the Commission:
 - (a) An approved certification agency;
 - (b) An approved test lab;
 - (c) An approved evaluation entity;
 - (d) Florida licensed professional engineer or architect; or
 - (e) A nationally recognized standard writing organization.
- (4) Equivalence of accreditation standards. Where approved evaluation entities and accreditation bodies accredit testing laboratories, certification agencies and quality assurance agencies to standards other than the referenced ISO standards in Rule 9B-72.100, F.A.C., the accrediting body shall certify to the Commission that its standard is equivalent to the ISO standard. Such certification shall contain:
 - (a) A sworn statement by the officer of the accrediting body; and
 - (b) A comparison of the accrediting body's standard to each criteria of the ISO reference standard with an explanation of why it is considered equivalent.
- (5) Organizations:
 - (a) ANSI – American National Standards Institute;
 - (b) AAMA – American Architectural Manufacturers Association;
 - (c) ASTM – American Society of Testing and Materials;
 - (d) DASMA – Door Access Systems Manufacturers Association; and
 - (e) NWWDA – National Wood Window and Door Association.

Specific Authority 553.842(1) FS. Law Implemented 553.842(2) FS. History—New 5-5-02, Amended 3-9-04, 11-22-06.

9B-72.190 Reference Standards.

- (1) International Organization for Standardization/International Electrotechnical Commission ISO/IEC Guide 61, General Requirements for Assessment and Accreditation of Certification/Registration Bodies.
- (2) International Organization for Standardization/International Electrotechnical Commission (ISO/IEC) Guide 65: 1996, General Requirements for Bodies Operating Product Certification Systems.
- (3) International Organization for Standardization/International Electrotechnical Commission ISO/IEC Guide TR 17010: 1998, General Requirements for Bodies Providing Accreditation of Inspection Bodies.
- (4) International Organization for Standardization/International Electrotechnical Commission ISO/IEC Guide TR 17020: 1998, General Criteria for the Operation of Various Types of Bodies Performing Inspection.
- (5) International Organization for Standardization/International Electrotechnical Commission (ISO/IEC) Guide 17025: 1999, General Requirements for the Competence of Testing and Calibration Laboratories.
- (6) International Organization for Standardization/International Electrotechnical Commission ISO/IEC Guide 58, Calibration and Testing Laboratory Accreditation Systems – General Requirements for Operation and Recognition.

Specific Authority 553.842(1) FS. Law Implemented 553.842(2) FS. History—New 5-5-02.

- (b) The Commission may revoke or suspend the approval of any approved accreditation body for failure to maintain accreditation programs which comply with subsection 9B-72.100(6), F.A.C., or any material misrepresentation of its independence or substantive information on its capabilities or policies and procedures and failure to cooperate in investigations of those it accredits.
 - (c) Commission suspensions under subsection 9B-72.160(2), F.A.C., shall remain in effect until such time as the entity demonstrates to the Commission that it is in compliance with said requirement.
 - (d) The Commission shall initiate an investigation based on a written complaint providing substantial material evidence provided by any substantially affected party.
 - (e) The Commission shall clearly post the status of approved evaluation entity, certification agency, testing laboratory, validation entity, quality assurance agency and accreditation body approval, suspension or revocation on its website list of approved entities.
- (3) Incomplete Product Approval or Entity applications. Any application that has no activity and is not complete within 180 days from the date of initial filing shall be denied.

Specific Authority 553.842(15) FS. Law Implemented 553.842(15) FS. History—New 5-5-02, Amended 11-22-06.

9B-72.170 Investigations.

- (1) Investigation of approved product non-compliance.
 - (a) The Commission shall initiate an investigation of product non-compliance on the basis of a written complaint including substantial material evidence.
 - (b) Investigation of product deficiencies shall be conducted by the manufacturer's certification agency, evaluation entity or test laboratory and the validation entity which certified compliance with the code standards to the Commission.
 - (c) The manufacturer's certification agency, evaluation entity or test laboratory and the validation entity may conduct investigations independent of the Commission initiation and report findings to the Commission on which suspension or revocation action is based.
 - (d) Substantially affected party complaints shall be based on one or more of the provisions of Rule 9B-72.160, F.A.C.
- (2) Investigation of approved certification agency, evaluation entity, test laboratory or validation entity non-compliance.
 - (a) The Commission shall initiate an investigation of approved certification agency, evaluation entity, test laboratory, quality assurance agency or validation entity non-compliance on the basis of a written complaint including substantial material evidence provided by an substantially affected party.
 - (b) Investigation of approved certification agency, evaluation entity, test laboratory, quality assurance agency or validation entity deficiencies shall be conducted by its accrediting body.
 - (c) The Commission shall conduct investigations of non-compliance where the accrediting body is not capable.
 - (d) The Commission shall conduct investigations of non-compliance of approved accrediting bodies.
 - (e) Substantially affected party complaints shall be based on one or more of the provisions of subsection 9B-72.160(2), F.A.C., as applicable.

Specific Authority 553.842(15) FS. Law Implemented 553.842(15) FS. History—New 5-5-02.

9B-72.180 Equivalence of Standards.

- (1) Equivalence of product standards. Where conformance to the Code is based on standards, then product evaluation shall rely on national and international consensus standards referenced in the Code. Other standards which meet or exceed standards referenced by the 2001 edition of the Code and recognized as equivalent for determining Code compliance are:
 - (a) ASTM E 330-97 equivalent to ASTM E 330-84;
 - (b) ASTM E 330-02 equivalent to ASTM E 330-84;
 - (c) ANSI/AAMA/NWDA 101/I.S.2/NAFS-02 equivalent to ANSI/AAMA/NWDA 101/I.S.2-97;
 - (d) DASMA 108-02 Standard Method for Testing Sectional Garage Doors equivalent to ASTM E 330-84, ASTM E 330-97, and ASTM E 330-02; and
 - (e) ANSI 250.13 Testing and Rating of Severe Wind-Storm Resistant Components for Swinging Doors Assemblies