



March 2, 2016

## Certification of Compliance



Mr. Gary Bowman  
California Montessori Project  
5330A Gibbons Drive  
Carmichael, CA 95608

**Project:** Montessori School (California Montessori Project)  
**Application #:** 02-112659  
**File Id #:** (09)34-CMP  
**Scope:** Construction of 2-Classroom Buildings (Relocatable), 1-Multi-purpose Building

Dear Mr. Gary Bowman:

The Department of General Services' records indicate that the construction of the referenced project has been completed in accordance with design documents approved by the Department, and that all the Verified Reports covering the construction have been received. Therefore, the Department of General Services Certifies as follows:

This project is in compliance with California State regulations as to the safety of design and construction of public schools, and for the accommodation of persons with disabilities.

For relocatable buildings, which have been granted a waiver of durability for foundations, the owner should periodically inspect for, and correct, deterioration in order to maintain safe conditions. This certification is not valid if the buildings are moved to a site location other than shown on the approved plans.

This project was designed to support the snow load indicated in this project scope. The owner should require and provide for snow removal to ensure that the weight of snow does not exceed that design limit.

Snow Load 20# psf

As stated in our letter approving the plans and specifications for this project, the Department does not review design documents or construction for compliance with the electrical, mechanical, or plumbing regulations. It is the responsibility of the professional consultants named on the application to verify compliance with appropriate parts of the California Building Code, and to submit Verified Reports documenting compliance.

Sincerely,

Chester "Chet" Widom, FAIA  
State Architect  
Division of the State Architect  
CW: cr

cc: School Board  
Architect/Engineer -  
File