



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Gannett Fleming, Inc.

Eric Buzza
Foster Plaza III, Suite 200, 601 Holiday Drive
Pittsburgh, PA 15220

Project Name: BASD - Summit Elementary

Project / PO Number: N/A
Received: 11/15/2017
Reported: 11/27/2017

Project Special Information

5100445

Analytical Testing Parameters

Client Sample ID: Kitchen Sink
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-01

Collected By: Eric Buzza
Collection Date: 11/15/2017 8:08

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.648	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Gym Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-02

Collected By: Eric Buzza
Collection Date: 11/15/2017 8:15

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.790	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Phys Ed Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-03

Collected By: Eric Buzza
Collection Date: 11/15/2017 8:20

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.876	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID: Unmarked bottle, discard per Eric B.

Sample Matrix: Drinking Water

Lab Sample ID: 17K1611-04

Collected By: Eric Buzza

Collection Date: 11/15/2017 8:25

Office	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method:							
No Sample Available	0			N/A			11/16/17 0923

Client Sample ID: Library Sink

Sample Matrix: Drinking Water

Lab Sample ID: 17K1611-05

Collected By: Eric Buzza

Collection Date: 11/15/2017 8:31

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.270	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Room 2 Sink

Sample Matrix: Drinking Water

Lab Sample ID: 17K1611-06

Collected By: Eric Buzza

Collection Date: 11/15/2017 8:35

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.521	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Room 1 Sink

Sample Matrix: Drinking Water

Lab Sample ID: 17K1611-07

Collected By: Eric Buzza

Collection Date: 11/15/2017 8:40

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.480	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID: Room 4 Sink
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-08

Collected By: Eric Buzza
Collection Date: 11/15/2017 8:44

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.529	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Room 3 Sink
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-09

Collected By: Eric Buzza
Collection Date: 11/15/2017 8:49

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.457	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Room 6 Sink
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-10

Collected By: Eric Buzza
Collection Date: 11/15/2017 8:54

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.590	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Room 5 Sink
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-11

Collected By: Eric Buzza
Collection Date: 11/15/2017 8:58

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.492	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID:	Room 8 Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 9:04
Lab Sample ID:	17K1611-12		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.638	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID:	Room 7 Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 9:08
Lab Sample ID:	17K1611-13		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.559	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID:	Room 9 Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 9:14
Lab Sample ID:	17K1611-14		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.684	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID:	Boys Room Far Sink 1	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 9:21
Lab Sample ID:	17K1611-15		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.455	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID: Boys Room Far Sink 2
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-16

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:23

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.447	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Boys Room Far Sink 3
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-17

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:25

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.417	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Boys Room Far Sink 4
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-18

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:26

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.494	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: Janitors Slop Sink Far End
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-19

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:28

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.486	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	0.002	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID: Girls Rm Far End Sink 1
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-20

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:32

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.583	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 0830	11/17/17 1233

Client Sample ID: unmarked bottle, discard per Eric B.
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-21

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:34

Office	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method:							
No Sample Available	0			N/A			11/16/17 0923

Client Sample ID: Girls Rm Far End Sink3
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-22

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:36

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.251	1.30 AL	0.010	mg/L		11/17/17 0855	11/20/17 1447
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID: Girls Rm Far End Sink 4
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-23

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:37

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.255	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID:	Fountain by Room 17	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 9:39
Lab Sample ID:	17K1611-24		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.559	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Room 17 Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017
Lab Sample ID:	17K1611-25		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.280	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Room 15 Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 9:50
Lab Sample ID:	17K1611-26		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.579	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Room 16 Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 9:53
Lab Sample ID:	17K1611-27		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.669	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID: Room 13 Sink
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-28

Collected By: Eric Buzza
Collection Date: 11/15/2017 9:57

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.607	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID: Room 14 Sink
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-29

Collected By: Eric Buzza
Collection Date: 11/15/2017 10:07

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.622	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID: Room 11 Sink
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-30

Collected By: Eric Buzza
Collection Date: 11/15/2017 10:13

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.488	1.30 AL	0.010	mg/L		11/17/17 0905	11/21/17 1944
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID: Room 11 Sink 2
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-31

Collected By: Eric Buzza
Collection Date: 11/15/2017 10:14

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.161	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID:	Room 12 Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 10:18
Lab Sample ID:	17K1611-32		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.678	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Room 10 Restroom	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 10:23
Lab Sample ID:	17K1611-33		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.446	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Room 10 Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 10:24
Lab Sample ID:	17K1611-34		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.485	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Nurses Exam Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 10:27
Lab Sample ID:	17K1611-35		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.527	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID:	Nurses Restroom	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 10:31
Lab Sample ID:	17K1611-36		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.382	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Office Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 10:34
Lab Sample ID:	17K1611-37		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.870	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Faculty Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 10:38
Lab Sample ID:	17K1611-38		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.551	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID:	Womens Faculty Restroom	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/15/2017 10:45
Lab Sample ID:	17K1611-39		

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.388	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID: Mens Faculty Restroom
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-40

Collected By: Eric Buzza
Collection Date: 11/15/2017 10:47

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.296	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID: Main Hall Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-41

Collected By: Eric Buzza
Collection Date: 11/15/2017 10:50

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.233	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1200	11/17/17 1526

Client Sample ID: Girls Rm Main Hall Sink 1
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-42

Collected By: Eric Buzza
Collection Date: 11/15/2017 10:54

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.549	1.30 AL	0.010	mg/L		11/17/17 0905	11/20/17 1744
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1348	11/17/17 1813

Client Sample ID: Girls Rm Main Hall Sink 2
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-43

Collected By: Eric Buzza
Collection Date: 11/15/2017 11:01

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.431	1.30 AL	0.010	mg/L		11/17/17 0913	11/20/17 1921
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1348	11/17/17 1813



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID: Girls Rm Main Hall Sink 3
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-44

Collected By: Eric Buzza
Collection Date: 11/15/2017 11:05

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.559	1.30 AL	0.010	mg/L		11/17/17 0913	11/20/17 1921
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1348	11/17/17 1813

Client Sample ID: Boys Rm Main Hall Sink1
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-45

Collected By: Eric Buzza
Collection Date: 11/15/2017 11:07

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.356	1.30 AL	0.010	mg/L		11/17/17 0913	11/20/17 1921
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1348	11/17/17 1813

Client Sample ID: Boys Rm Main Hall Sink 2
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-46

Collected By: Eric Buzza
Collection Date: 11/15/2017 11:08

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.379	1.30 AL	0.010	mg/L		11/17/17 0913	11/20/17 1921
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1348	11/17/17 1813

Client Sample ID: Boys Rm Main Hall Sink 3
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-47

Collected By: Eric Buzza
Collection Date: 11/15/2017 11:09

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.426	1.30 AL	0.010	mg/L		11/17/17 0913	11/20/17 1921
Method: SM 3113 B-04							
Lead	<0.001	0.015 AL	0.001	mg/L		11/17/17 1348	11/17/17 1813



Microbac Laboratories, Inc. - Erie

CERTIFICATE OF ANALYSIS

17K1611

Client Sample ID: Boys Rm Main Hall Sink 4
Sample Matrix: Drinking Water
Lab Sample ID: 17K1611-48

Collected By: Eric Buzza
Collection Date: 11/15/2017 11:06

Metals, Total	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
Method: EPA 200.7, Rv. 4.4							
Copper	0.349	1.30 AL	0.010	mg/L		11/17/17 0913	11/20/17 1921
Method: SM 3113 B-04							
Lead	0.001	0.015 AL	0.001	mg/L		11/17/17 1348	11/17/17 1813

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level
RL: Reporting Limit
SMCL: US EPA Secondary Maximum Contaminant Level

Project Requested Certification(s)

Microbac Laboratories, Inc. - Erie
PA DEP# 25-00067

PA Department of Environmental Protection
PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Carolyn Vollenentine

Project Manager

Reported: 11/27/2017 09:48



CHAIN OF CUSTODY

Microbac Erie Division
1962 Wager Road
Erie, PA 16509
814-825-8533

eriemmm@microbac.com

Page ____ of ____

17K1611 Gannett Fleming, Inc.



Analyses

Client/Company Name: <u>Gannett Fleming</u>		Contact Name: <u>Eric Buzza</u>										
Address: <u>Foster Plaza B Suite 400</u>		Bill To/PO#: <u>BA50</u>										
City/State/Zip: <u>Pittsburgh PA 15220</u>		Potential Hazards: Non-Hazard ☒ Hazard ☐ Radioactive ☐										
Phone: <u>412 937 5575</u>	Email/Fax: <u>abuzz@gnf.net</u>	Disposal: Dispose of ☒ Return ☐ Retain ☐										
Project Name/ID: <u>BA50 Summit Elementary</u>		Compliance Sample: Yes ☐ No ☒										
Sampled By: <u>Eric Buzza</u>		State: <u>PA</u>										
Shipped By: <u>Sdayturner</u>		Monitoring Period:										
Type Code: <u>G-Grab C-Composite</u>	Comp. Start:	Comp. Stop:										
Matrix Code: <u>DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other</u>												
Sample Identification	Date Taken	Time Taken	Type	Matri x	Tot # Cont.	None	HNO3	H2SO4	NaOH	HCl	Thio	Other
			G									
<u>Hitchcock Sink</u>	<u>11/15/17</u>	<u>0208</u>	☒	<u>OW 1</u>	<u>1</u>	☒						
<u>Coyne Fountain</u>		<u>0915</u>	☒									
<u>Play Ball Fountain</u>		<u>0920</u>	☒									
<u>Boiler Room no sample received</u>		<u>0925</u>	☒									
<u>Library Sink</u>		<u>0931</u>	☒									
<u>Room 2 Sink</u>		<u>0935</u>	☒									
Instructions/Comments:												
Relinquished By: <u>BYR</u> Date/Time: <u>11/15/17 12:15</u> Received By: <u>Thomas Bortol</u> Date/Time: <u>11/15/17 12:15</u> Temp: <u>30.2°C</u>												
Relinquished By: <u>Thomas Bortol</u> Date/Time: <u>11/15/17 14:45</u> Received By: <u>Eric Buzza</u> Date/Time: <u>11/15/17 14:45</u> Intact: <u>Y</u>												
Relinquished By: <u>Eric Buzza</u> Date/Time: <u>11/15/17 16:45</u> Received By: <u>Eric Buzza</u> Date/Time: <u>11/15/17 16:45</u> Intact: <u>N</u>												

Samples, Containers & COC
Verified as per Sample Receiving Checklist
INITIALS: CAN DATE: 11-16-17

Lead + Copper



CHAIN OF CUSTODY

Microbac Erie Division
1962 Wager Road
Erie, PA 16509
814-825-8533
eriemm@microbac.com

Page ____ of ____

17K1611 Gannett Fleming, Inc.



Client /Company Name: <u>Gannett Fleming</u>		Contact Name: <u>Erie Buzza</u>											
Address: <u>Foster Plaza B Suite 400</u>		Bill To/PO#: <u>BA50</u>											
City/State/Zip: <u>Pittsburgh PA 15220</u>													
Phone: <u>412 972 5575</u>	Email/Fax: <u>abuzza@fngt.com</u>	Potential Hazards: Non-Hazard ☒ Hazard ☐ Radioactive ☐											
Project Name/ID: <u>BA50 Summit Elementary</u>		Dispose of ☒ Return ☐ Retain ☐											
Sampled By: <u>Erie Buzza</u>		Due Date: <u>5 day turnaround</u>											
Shipped By: <u>Erie Buzza</u>		Tracking #: <u></u>											
Type Code: <u>G-Grab C-Composite</u>	Comp. Start: <u></u>	Comp. Stop: <u></u>	Monitoring Period: <u></u>										
Matrix Code: <u>DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other</u>													
Sample Identification	Date Taken	Time Taken	Type	Matri	Tot. #	None	HNO3	H2SO4	NaOH	HCl	Thio	Other	
			G										C
Room 1 sink	11/13/17	840	✓	OW 1	✓								
Room 4 sink		844											
Room 3 sink		849											
Room 6 sink		854											
Room 5 sink		858											
Room 2 sink		904											
Instructions/Comments: <u>Samples, Containers & COC Verified as per Sample Receiving Checklist</u>													
INITIALS: <u>CANV</u> DATE: <u>11-16-17</u>													
Relinquished By: <u>Erie Buzza</u>		Date/Time: <u>11/15/17 12:15</u>	Received By: <u>Shirley Foster</u>		Date/Time: <u>11/15/17 12:15</u>	Temp: <u>20.2°C</u>							
Relinquished By: <u>Shirley Foster</u>		Date/Time: <u>11/15/17 12:15</u>	Received By: <u>Shirley Foster</u>		Date/Time: <u>11/15/17 12:15</u>	Intact: <u>Y</u>							
Relinquished By: <u>Shirley Foster</u>		Date/Time: <u>11/15/17 12:15</u>	Received By: <u>Shirley Foster</u>		Date/Time: <u>11/15/17 12:15</u>	Intact: <u>N</u>							



CHAIN OF CUSTODY

Microbac Erie Division
1962 Wager Road
Erie, PA 16509
814-825-8533
eriemm@microbac.com


Page ____ of ____

17K1611 Gannett Fleming, Inc.



Client/Company Name: <u>Gannett Fleming</u>		Contact Name: <u>Erie Buzza</u>				
Address: <u>Post Office Box 400</u>		Bill To/PO#: <u>BA50</u>				
City/State/Zip: <u>Pittsburgh PA 15200</u>		Potential Hazards: Non-Hazard ☒ Hazard ☐ Radioactive ☐				
Phone: <u>412 972 5575</u> Email/Fax: <u>abuzza@gannett.com</u>		Disposal: Dispose of ☒ Return ☐ Retain ☐				
Project Name/ID: <u>BA50 Summit Elementary</u>		Compliance Sample: Yes ☐ No ☒				
Sampled By: <u>Erie Buzza</u>		Due Date: <u>5 day temporary</u>				
Shipped By: <u>Erie Buzza</u>		Tracking #: <u>5 day temporary</u>				
Type Code: G-Grab C-Composite		Comp. Start: <u> </u> Comp. Stop: <u> </u>				
Matrix Code: DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other		Preservatives				
Sample Identification	Date Taken	Time Taken	Type G C	Matrix x	Tot. # Cont.	None HNO3 H2SO4 NaOH HCl Thio Other
Room 7 Sink	11/15/17	908			1	
Room 9 Sink		914				
Boys Room Far Sink 1		921				
Boys Room Far Sink 2		923				
Boys Room Far Sink 3		925				
Boys Room Far Sink 4		928				
Instructions/Comments:						
Relinquished By: <u>BPP</u> Date/Time: <u>11/15/17 12:15</u> Received By: <u>James Barber</u> Date/Time: <u>11/15/17 12:15</u> Temp: <u>102.2</u> °C						
Relinquished By: <u>James Barber</u> Date/Time: <u>11/15/17 12:15</u> Received By: <u>James Barber</u> Date/Time: <u>11/15/17 12:15</u> Intact: <u>Y</u>						
Relinquished By: <u>James Barber</u> Date/Time: <u>11/15/17 12:15</u> Received By: <u>James Barber</u> Date/Time: <u>11/15/17 12:15</u> Intact: <u>N</u>						
Relinquished By: <u>James Barber</u> Date/Time: <u>11/15/17 12:15</u> Received By: <u>James Barber</u> Date/Time: <u>11/15/17 12:15</u> Intact: <u>N</u>						

Samples, Containers & COC
Verified as per Sample Receiving Checklist
INITIALS: Cmc DATE: 11-16-17



17K1611 Gannett Fleming, Inc.


Analyses

Bill To/PO#: PA30

Bill To/PO#: PA30

1001

Page 17 of 21



Page of



Page 18 of 21

Client /Company Name: <u>Summit Flaming</u>										Contact Name: <u>Eric Butza</u>																																							
Address: <u>Forster Plaza 8 Suite 400</u>										Bill To/PO#: <u>BA50</u>																																							
City/State/Zip: <u>Pittsburgh PA 15200</u>																																																	
Phone: <u>412 922 5575</u>					Email/Fax: <u>abuzza@summit.com</u>					Potential Hazards: Non-Hazard ☒ Hazard ☐ Radioactive ☐																																							
Project Name/ID: <u>BA50 Summit Elementary</u>										Disposition: Dispose of ☒ Return ☐ Retain ☐																																							
Sampled By: <u>Eric Butza</u>										Due Date: <u>5 days turnaround</u>																																							
Shipped By: <u>Eric Butza</u>										Tracking #: <u></u>																																							
Type Code: G-Grab C-Composite					Comp. Start:					Comp. Stop:																																							
Matrix Code: DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other										Preservatives																																							
Sample Identification					Date Taken		Time Taken		Type		Matrix		Tot. #		None		HNO3		H2SO4		NaOH		HCl		Thio		Other																						
Room 17 sink					11/13/17		943		✓		OM 1		✓																																				
Room 15 sink							950																																										
Room 16 sink							953																																										
Room 13 sink							957																																										
Room 14 sink							1007																																										
Room 11 sink							1013																																										
Instructions/Comments: <u>Samples, Containers & COC</u> <u>Verified as per Sample Receiving Checklist</u> <u>INITIALS: CMV DATE: 11-16-17</u>																																																	
Relinquished By: <u>BPR</u>										Date/Time: <u>11/15/17 12:15</u>										Received By: <u>Eric Butza</u>										Date/Time: <u>11/15/17 12:15</u>										Temp: <u>20.2°C</u>									
Relinquished By: <u>Shirley Berlin</u>										Date/Time: <u></u>										Received By: <u>Shirley Berlin</u>										Date/Time: <u>11/15/17 1445</u>										Intact: <u>Y</u>									
Relinquished By: <u>Eric Butza</u>										Date/Time: <u>11/15/17</u>										Received By: <u>Eric Butza</u>										Date/Time: <u>11/15/17 1645</u>										Intact: <u>Y</u>									
Relinquished By: <u></u>										Date/Time: <u></u>										Received By: <u></u>										Date/Time: <u></u>										Intact: <u>Y</u>									



CHAIN OF CUSTODY

17K1611 Gannett Fleming, Inc.

Microbac Erie Division
1962 Wager Road
Erie, PA 16509
814-825-8533
eriemm@microbac.com

Page ____ of ____



Client /Company Name: <u>Gannett Fleming</u>		Contact Name: <u>E. Buzza</u>		Analyses									
Address: <u>Post Office Box 8 Suite 400</u>		Bill To/PO#: <u>BA50</u>											
City/State/Zip: <u>Pittsburgh PA 15220</u>													
Phone: <u>412 922 5575</u>		Email/Fax: <u>abuzza@fngm.com</u>											
Project Name/ID: <u>BA50 Summit of Elementary</u>		Potential Hazards: Non-Hazard ☒ Hazard ☐ Radioactive ☐											
Sampled By: <u>Erie Buzza</u>		Due Date: <u>5 day turnaround</u>		Disposal: ☒ Return ☐ Retain ☐		Compliance Sample: ☒ Yes ☐ No ☐		State: <u>PA</u>					
Shipped By: <u>Erie Buzza</u>		Tracking #: <u></u>		PWSID#: <u></u>		Monitoring Period: <u></u>							
Type Code: <u>G-Grab C-Composite</u>		Comp. Start: <u></u>		Comp. Stop: <u></u>									
Matrix Code: <u>DW-Potable water</u>		<u>WW-Nonpotable water</u>		<u>SS-Soil/Sediment</u>		<u>F-Food</u>		<u>S-Swab</u>		<u>O-Other</u>			
Sample Identification		Date Taken		Time Taken		Type G C		Matri x		Tot. # Cont.		None HNO3 H2SO4 NaOH HCl Thio Other	
<u>Room 11 Sink 2</u>		<u>11/5/17</u>		<u>1014</u>		☒		<u>OW 1</u>		☒		<u>Lead + Copper</u>	
<u>Room 12 Sink</u>				<u>1018</u>		☐							
<u>Room 10 Rest room</u>				<u>1023</u>		☐							
<u>Room 10 Sink</u>				<u>1024</u>		☐							
<u>Room 345 Exam Sink</u>				<u>1027</u>		☐							
<u>Near East room</u>				<u>1031</u>		☐							
Instructions/Comments: <u>Samples, Containers & COC Verified as per Sample Receiving Checklist</u> <u>INITIALS: CMV DATE: 11-16-17</u>													
Relinquished By: <u>B. B. B.</u>		Date/Time: <u>11/5/17 12:15</u>		Received By: <u>Michael Barber</u>		Date/Time: <u>11/5/17 12:15</u>		Temp: <u>20.3°C</u>		Intact: <u>Y</u>			
Relinquished By: <u>Michael Barber</u>		Date/Time: <u>11/5/17 14:45</u>		Received By: <u>Michael Barber</u>		Date/Time: <u>11/5/17 14:45</u>		Intact: <u>Y</u>					
Relinquished By: <u>Michael Barber</u>		Date/Time: <u>11/5/17 14:45</u>		Received By: <u>Michael Barber</u>		Date/Time: <u>11/5/17 14:45</u>		Intact: <u>Y</u>					
Relinquished By: <u>Michael Barber</u>		Date/Time: <u>11/5/17 14:45</u>		Received By: <u>Michael Barber</u>		Date/Time: <u>11/5/17 14:45</u>		Intact: <u>Y</u>					



CHAIN OF CUSTODY

Microbac Erie Division
1962 Wager Road
Erie, PA 16509
814-825-8533

eriemm@microbac.com

Page ____ of ____

17K1611 Gannett Fleming, Inc.



Client /Company Name: <u>Gannett Fleming</u>		Contact Name: <u>Erie Buzza</u>										
Address: <u>Foster Plaza B Suite 400</u>		Bill To/PO#: <u>BA50</u>										
City/State/Zip: <u>Pittsburgh PA 15220</u>												
Phone: <u>412 932 5575</u>	Email/Fax: <u>abuzza@gannett.com</u>	Potential Hazards: Non-Hazard ☒ Hazard ☐ Radioactive ☐										
Project Name/ID: <u>BA50 Summit Elementary</u>		Dispose of ☒ Return ☐ Retain ☐										
Sampled By: <u>Erie Buzza</u>		Due Date: <u>5 day turnaround</u>										
Shipped By: <u>Erie Buzza</u>		Tracking #: <u>5 day turnaround</u>										
Type Code: <u>G-Grab C-Composite</u>	Comp. Start:	Comp. Stop:	Monitoring Period:									
Matrix Code: <u>DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other</u>												
Sample Identification	Date Taken	Time Taken	Type	Matri	Tot. #	None	HNO3	H2SO4	NaOH	HCl	Thio	Other
			G									
<u>Office Sink</u>	<u>11/13/17</u>	<u>1034</u>	☒	<u>OW</u>	<u>1</u>	☒						
<u>Faculty Sink</u>		<u>1038</u>										
<u>Womens Faculty Restroom</u>		<u>1045</u>										
<u>Mans Faculty Restroom</u>		<u>1047</u>										
<u>Main Hall Fountain</u>		<u>1050</u>										
<u>Gir's Rm Main Hall Sink 1</u>		<u>1054</u>										
Instructions/Comments:												
Relinquished By: <u>Erie Buzza</u> Date/Time: <u>11/15/17 12:15</u> Received By: <u>Amelia Porter</u> Date/Time: <u>11/15/17 12:15</u> Temp: <u>20.2°C</u>												
Relinquished By: <u>Amelia Porter</u> Date/Time: <u>11/15/17 14:45</u> Received By: <u>Amelia Porter</u> Date/Time: <u>11/15/17 14:45</u> Intact: <u>Y</u>												
Relinquished By: <u>Amelia Porter</u> Date/Time: <u>11/15/17 16:45</u> Received By: <u>Amelia Porter</u> Date/Time: <u>11/15/17 16:45</u> Intact: <u>Y</u>												

Samples, Containers & CDC
Verified as per Sample Receiving Checklist
INITIALS: CMV DATE: 11-16-17

Lead + Copper



CHAIN OF CUSTODY

Put bar code here

Microbac Erie Division
1962 Wager Road
Erie, PA 16509
814-825-8533

eriemm@microbac.com

Page ____ of ____

17K1611 Gannett Fleming, Inc.



Client /Company Name: <u>Gannett Fleming</u>		Contact Name: <u>Eric Buzza</u>									
Address: <u>Foster Plaza 8 Suite 400</u>		Bill To/PO#: <u>PA50</u>									
City/State/Zip: <u>Pittsburgh PA 15200</u>		Potential Hazards: Non-Hazard ☒ Hazard ☐ Radioactive ☐									
Phone: <u>412 972 5575</u>	Email/Fax: <u>abuzza@gnf.net com</u>	Disposal: Dispose of ☒ Return ☐ Retain ☐									
Project Name/ID: <u>PA50 Summit Elementary</u>		Compliance Sample: Yes ☐ No ☒									
Sampled By: <u>Eric Buzza</u>		Due Date: <u>5 day turnaround</u>									
Shipped By: <u>Eric Buzza</u>		Tracking #: <u></u>									
Type Code: <u>G-Grab C-Composite</u>	Comp. Start: <u></u>	Comp. Stop: <u></u>	Monitoring Period: <u></u>								
Matrix Code: <u>DW-Potable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other</u>											
Sample Identification	Date Taken	Time Taken	Type	Matri x	Tot. # Cont.	Preservatives					
			G C			None HNO3 H2SO4 NaOH HCl Thio Other					
<u>Girls Em Main Hall Sink 1</u>	<u>11/15/17</u>	<u>1103</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>
<u>Boys Em Main Hall Sink 1</u>	<u>11/15/17</u>	<u>1103</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>
<u>Boys Em Main Hall Sink 2</u>	<u>11/15/17</u>	<u>1103</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>
<u>Boys Em Main Hall Sink 3</u>	<u>11/15/17</u>	<u>1103</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>
<u>Girls Em Main Hall Sink 4</u>	<u>11/15/17</u>	<u>1103</u>	<u>1</u>	<u>1</u>	<u>1</u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>	<u></u>
Instructions/Comments: <u>Lead + Copper</u>											
Relinquished By: <u>Eric Buzza</u> Date/Time: <u>11/15/17 12:15</u> Received By: <u>Anna Foster</u> Date/Time: <u>11/15/17 12:15</u> Temp: <u>20.2°C</u>											
Relinquished By: <u>Anna Foster</u> Date/Time: <u>11/15/17 14:45</u> Received By: <u>Eric Buzza</u> Date/Time: <u>11/15/17 14:45</u> Intact: <u>Y N</u>											
Relinquished By: <u>Anna Foster</u> Date/Time: <u>11/15/17 14:45</u> Received By: <u>Eric Buzza</u> Date/Time: <u>11/15/17 14:45</u> Intact: <u>Y N</u>											

Samples, Containers & COC
Verified as per Sample Receiving Checklist
INITIALS: CMV DATE: 11-16-17