



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2034918

GANNETT FLEMING, INC.

Project Name: Emily Britton Elem

ERIC BUZZA
FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE
PITTSBURGH, PA 15220

Project / PO Number: N/A
Received: 03/30/2022
Reported: 04/05/2022

Analytical Testing Parameters

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date. Values include Cafeteria Prep Sink, Drinking Water, 2034918-01, Eric Buzza, 03/30/2022 9:33.

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result <0.000400.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date. Values include Faculty Rm Sink, Drinking Water, 2034918-02, Eric Buzza, 03/30/2022 9:37.

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result <0.000400.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date. Values include Nurses Exam Sink, Drinking Water, 2034918-03, Eric Buzza, 03/30/2022 9:40.

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.00160.

Table with 2 columns: Client Sample ID, Sample Matrix, Lab Sample ID and Collected By, Collection Date. Values include Art Room Sink 2, Drinking Water, 2034918-04, Eric Buzza, 03/30/2022 9:45.

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.00375.

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- mg/L: Milligrams per Liter
RL: Reporting Limit



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2034918

**Project Requested Certification(s)**

Microbac Laboratories Inc., Pittsburgh Division  
02-00257

PA Department of Environmental Protection  
PADEP Accreditation by Rule

---

**Report Comments**

*Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.*

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.***

**Reviewed and Approved By:**

A handwritten signature in blue ink that reads "Carolyn M. Vollentine". The signature is written in a cursive style and is contained within a light yellow rectangular box.

Carolyn Vollentine  
Service Center Manager  
Reported: 04/05/2022 14:01

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | [www.microbac.com](http://www.microbac.com)

Microbac Erie Division 814.825.8533  
 1962 Wager Road eriemn@microbac.com  
 Erie, PA 16509

Page \_\_\_\_ of \_\_\_\_



PM: Carolyn Volentine

Client/Company Name: BASO GF

Contact Name: Eric Buzza

Analyses

Address:

Bill To/PO#:

505 Star Place 8 Suite, 400 730 Holiday Dr

Pittsburgh PA 15120

Potential Hazards: Non-Hazard [ ] Hazard [ ] Radioactive [ ]

Phone: 412 922 5575 Email/Fax: edwiza@gnfnet.com

Disposal: Dispose of [ ] Return [ ] Retain [ ]

Project Name/ID: Emily Brittain Elom

Compliance Sample: Yes [ ] No [ ]

State:

Sampled By: Eric Buzza

Due Date:

PWSID#:

Monitoring Period:

Shipped By:

Tracking #:

Comp. Start:

Comp. Stop:

Matrix Code: DW-Portable water WW-Nonpotable water SS-Soil/Sludge F-Food S-Swab O-Other

Preservatives

Sample Identification	Date Taken	Time Taken	Type		Matrix	Tot. # Cont.	None	HNO3	H2SO4	NaOH	HCl	Thio	Other	Notes
			G	C										
Cafeteria Prep Sink	3/30/12	933	✓		BW	1	✓							lead + <del>Asbestos</del>
Faculty Rm Sink		937	✓			1	✓							
Nurses Exam Sink		940	✓			1	✓							
Aut Room Sink 2		945	✓			1	✓							

HNO3 Preserved  
 Date: 12/20/12  
 Time: 12:05  
 Initials: MSK

Instructions/Comments:

Relinquished By:

Date/Time:

Received By:

Date/Time:

Temp °C

Relinquished By:

Date/Time:

Received By:

Date/Time:

Temp °C

Relinquished By:

Date/Time:

Received By:

Date/Time:

Temp °C