



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9072600

GANNETT FLEMING, INC.

ERIC BUZZA
FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE
PITTSBURGH, PA 15220

Project Name: BASD - Middle School

Project / PO Number: N/A
Received: 07/10/2019
Reported: 07/19/2019

Project Special Information

5100445

Analytical Testing Parameters

Client Sample ID: Middle School Nurse's Office
Sample Matrix: Drinking Water
Lab Sample ID: 9072600-01

Collected By: Client
Collection Date: 07/10/2019 8:38

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.008	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0656	JYH

Client Sample ID: Middle School Fitness Rm Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 9072600-02

Collected By: Client
Collection Date: 07/10/2019 8:43

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0706	JYH

Client Sample ID: Middle School Rm 104 Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 9072600-03

Collected By: Client
Collection Date: 07/10/2019 8:41

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0709	JYH



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9072600

Client Sample ID: Middle School Rm 114 Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-04

Collected By: Client

Collection Date: 07/10/2019 8:36

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0712	JYH

Client Sample ID: Middle School Rm 147 Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-05

Collected By: Client

Collection Date: 07/10/2019 8:18

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0728	JYH

Client Sample ID: Middle School Rm 140 Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-06

Collected By: Client

Collection Date: 07/10/2019 8:16

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.007	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0731	JYH

Client Sample ID: Middle School Food Service Sink 1

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-07

Collected By: Client

Collection Date: 07/10/2019 8:27

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.017	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0735	JYH



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9072600

Client Sample ID: Middle School Faculty Cafe Sink

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-08

Collected By: Client

Collection Date: 07/10/2019 8:23

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.003	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0738	JYH

Client Sample ID: Middle School Choral Rm Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-09

Collected By: Client

Collection Date: 07/10/2019 8:49

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.007	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0741	JYH

Client Sample ID: Middle School Rm 204 Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-10

Collected By: Client

Collection Date: 07/10/2019 8:32

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0744	JYH

Client Sample ID: Middle School Rm 214 Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-11

Collected By: Client

Collection Date: 07/10/2019 8:30

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0747	JYH



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9072600

Client Sample ID: Middle School Rm 245

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-12

Collected By: Client

Collection Date: 07/10/2019 8:20

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0754	JYH

Client Sample ID: Middle School Gyn Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-13

Collected By: Client

Collection Date: 07/10/2019 8:46

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0757	JYH

Client Sample ID: Middle School Choral Sink

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-14

Collected By: Client

Collection Date: 07/10/2019 8:49

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	<0.001	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0807	JYH

Client Sample ID: Middle School Food Service Sink 2

Sample Matrix: Drinking Water

Lab Sample ID: 9072600-15

Collected By: Client

Collection Date: 07/10/2019 8:27

Analyses Subcontracted to: Microbac Laboratories Inc., - Marietta, OH

Total Metals - ICP/MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4								
Lead	0.044	0.015 AL	0.001	mg/L		07/15/19 1214	07/18/19 0810	JYH

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

AL: US EPA Action Level

RL: Reporting Limit

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com

Page 4 of 17



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

9072600

Project Requested Certification(s)

Microbac Laboratories Inc., - Marietta, OH

68-01670

Microbac Laboratories Inc., Pittsburgh Division

02-00257

PA Department of Environmental Protection

PA Department of Environmental Protection

PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Carolyn Vollentine

Service Center Manager

Reported: 07/19/2019 12:24

Microbac Erie Division
1962 Wager Road
Erie, PA 16509
814.825.8533
eriemm@microbac.com

Page ____ of ____

Work Order #.

[illegible]

BASD Lead Sampling 2019

Facility	Location	Date	Time
Middle School	Nurse's Office	7/10/19	8:38 AM
Middle School	Fitness Rm Fountain	7/10/19	8:43 AM
Middle School	Rm 104 Fountain	7/10/19	8:41 AM
Middle School	Rm 114 Fountain	7/10/19	8:36 AM
Middle School	Rm 147 Fountain	7/10/19	8:18 AM
Middle School	Rm 140 Fountain	7/10/19	8:16 AM
Middle School	Food Service Sink 1	7/10/19	8:27 AM
Middle School	Faculty Café Sink	7/10/19	8:23 AM
Middle School	Choral Rm Fountain	7/10/19	8:49 AM
Middle School	Rm 204 Fountain	7/10/19	8:32 AM
Middle School	Rm 214 Fountain	7/10/19	8:30 AM
Middle School	Rm 245 Fountain	7/10/19	8:20 AM
Middle School	Rm 314 Fountain	7/10/19	
Middle School	3rd Flr Band Fountain	7/10/19	
Middle School	Rm 304 Fountain	7/10/19	

Discolored

13 Middle School Gym Fountain 7/10/19 8:46 AM
 Middle School Choral Sink 7/10/19 8:49 AM
 15 Middle School Food Service Sink 2 7/10/19 8:27 AM Discolored



9 0 7 2 6 0 0

GANNETT FLEMING, INC.

PM: Carolyn Vollentine



Microbac Laboratories Inc., - Marietta, OH

CERTIFICATE OF ANALYSIS

M9G0876

Microbac Laboratories, Inc. - Pittsburgh

Project Name: 9072600

Carolyn Vollentine
100 Marshall Drive
Pittsburgh, PA 15086

Project / PO Number: N/A
Received: 07/12/2019
Reported: 07/18/2019

Sample Summary Report

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
9072600-01 (Middle School Nurse's Office)	M9G0876-01	Drinking Water	Grab		07/10/19 08:38	07/12/19 09:50
9072600-02 (Middle School Fitness Rm Fountain)	M9G0876-02	Drinking Water	Grab		07/10/19 08:43	07/12/19 09:50
9072600-03 (Middle School Rm 104 Fountain)	M9G0876-03	Drinking Water	Grab		07/10/19 08:41	07/12/19 09:50
9072600-04 (Middle School Rm 114 Fountain)	M9G0876-04	Drinking Water	Grab		07/10/19 08:36	07/12/19 09:50
9072600-05 (Middle School Rm 147 Fountain)	M9G0876-05	Drinking Water	Grab		07/10/19 08:18	07/12/19 09:50
9072600-06 (Middle School Rm 140 Fountain)	M9G0876-06	Drinking Water	Grab		07/10/19 08:16	07/12/19 09:50
9072600-07 (Middle School Food Service Sink 1)	M9G0876-07	Drinking Water	Grab		07/10/19 08:27	07/12/19 09:50
9072600-08 (Middle School Faculty Cafe Sink)	M9G0876-08	Drinking Water	Grab		07/10/19 08:23	07/12/19 09:50
9072600-09 (Middle School Choral Rm Fountain)	M9G0876-09	Drinking Water	Grab		07/10/19 08:49	07/12/19 09:50
9072600-10 (Middle School Rm 204 Fountain)	M9G0876-10	Drinking Water	Grab		07/10/19 08:32	07/12/19 09:50
9072600-11 (Middle School Rm 214 Fountain)	M9G0876-11	Drinking Water	Grab		07/10/19 08:30	07/12/19 09:50
9072600-12 (Middle School Rm 245)	M9G0876-12	Drinking Water	Grab		07/10/19 08:20	07/12/19 09:50
9072600-13 (Middle School Gyn Fountain)	M9G0876-13	Drinking Water	Grab		07/10/19 08:46	07/12/19 09:50
9072600-14 (Middle School Choral Sink)	M9G0876-14	Drinking Water	Grab		07/10/19 08:49	07/12/19 09:50
9072600-15 (Middle School Food Service Sink 2)	M9G0876-15	Drinking Water	Grab		07/10/19 08:27	07/12/19 09:50



Microbac Laboratories Inc., - Marietta, OH

CERTIFICATE OF ANALYSIS

M9G0876

Analytical Testing Parameters

Client Sample ID: 9072600-01 (Middle School Nurse's Office)

Sample Matrix: Drinking Water

Lab Sample ID: M9G0876-01

Collected By: Client

Collection Date: 07/10/2019 8:38

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	0.008		0.001	mg/L	1		07/15/19 1214	07/18/19 0656	JYH

Client Sample ID: 9072600-02 (Middle School Fitness Rm Fountain)

Sample Matrix: Drinking Water

Lab Sample ID: M9G0876-02

Collected By: Client

Collection Date: 07/10/2019 8:43

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0706	JYH

Client Sample ID: 9072600-03 (Middle School Rm 104 Fountain)

Sample Matrix: Drinking Water

Lab Sample ID: M9G0876-03

Collected By: Client

Collection Date: 07/10/2019 8:41

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	<0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0709	JYH

Client Sample ID: 9072600-04 (Middle School Rm 114 Fountain)

Sample Matrix: Drinking Water

Lab Sample ID: M9G0876-04

Collected By: Client

Collection Date: 07/10/2019 8:36

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	<0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0712	JYH

Client Sample ID: 9072600-05 (Middle School Rm 147 Fountain)

Sample Matrix: Drinking Water

Lab Sample ID: M9G0876-05

Collected By: Client

Collection Date: 07/10/2019 8:18

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	<0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0728	JYH



Microbac Laboratories Inc., - Marietta, OH

CERTIFICATE OF ANALYSIS

M9G0876

Client Sample ID: 9072600-06 (Middle School Rm 140 Fountain)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-06

Collected By: Client
Collection Date: 07/10/2019 8:16

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	0.007		0.001	mg/L	1		07/15/19 1214	07/18/19 0731	JYH

Client Sample ID: 9072600-07 (Middle School Food Service Sink 1)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-07

Collected By: Client
Collection Date: 07/10/2019 8:27

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	0.017		0.001	mg/L	1		07/15/19 1214	07/18/19 0735	JYH

Client Sample ID: 9072600-08 (Middle School Faculty Cafe Sink)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-08

Collected By: Client
Collection Date: 07/10/2019 8:23

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	0.003		0.001	mg/L	1		07/15/19 1214	07/18/19 0738	JYH

Client Sample ID: 9072600-09 (Middle School Choral Rm Fountain)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-09

Collected By: Client
Collection Date: 07/10/2019 8:49

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	0.007		0.001	mg/L	1		07/15/19 1214	07/18/19 0741	JYH

Client Sample ID: 9072600-10 (Middle School Rm 204 Fountain)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-10

Collected By: Client
Collection Date: 07/10/2019 8:32

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	<0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0744	JYH



Microbac Laboratories Inc., - Marietta, OH

CERTIFICATE OF ANALYSIS

M9G0876

Client Sample ID: 9072600-11 (Middle School Rm 214 Fountain)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-11

Collected By: Client
Collection Date: 07/10/2019 8:30

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	<0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0747	JYH

Client Sample ID: 9072600-12 (Middle School Rm 245)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-12

Collected By: Client
Collection Date: 07/10/2019 8:20

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	<0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0754	JYH

Client Sample ID: 9072600-13 (Middle School Gyn Fountain)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-13

Collected By: Client
Collection Date: 07/10/2019 8:46

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	<0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0757	JYH

Client Sample ID: 9072600-14 (Middle School Choral Sink)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-14

Collected By: Client
Collection Date: 07/10/2019 8:49

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	<0.001		0.001	mg/L	1		07/15/19 1214	07/18/19 0807	JYH

Client Sample ID: 9072600-15 (Middle School Food Service Sink 2)
Sample Matrix: Drinking Water
Lab Sample ID: M9G0876-15

Collected By: Client
Collection Date: 07/10/2019 8:27

Total Metals - ICP/MS	Result	MDL	RL	Units	Dilution	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4									
Lead	0.044		0.001	mg/L	1		07/15/19 1214	07/18/19 0810	JYH



Microbac Laboratories Inc., - Marietta, OH

CERTIFICATE OF ANALYSIS

M9G0876

Definitions

AL: US EPA Action Level
RL: Reporting Limit

Cooler Receipt Log

Cooler ID: Default Cooler Temp: 22.4°C

Cooler Inspection Checklist

Ice Present or not required?	Yes	Shipping containers sealed or not required?	Yes
Custody seals intact or not required?	Yes	Chain of Custody (COC) Present?	Yes
COC includes customer information?	Yes	Relinquished and received signature on COC?	Yes
Sample collector identified on COC?	Yes	Sample type identified on COC?	Yes
Correct type of Containers Received	Yes	Correct number of containers listed on COC?	Yes
Containers Intact?	Yes	COC includes requested analyses?	Yes
Enough sample volume for indicated tests received?	Yes	Sample labels match COC (Name, Date & Time?)	Yes
Samples arrived within hold time?	Yes	Correct preservatives on COC or not required?	Yes
Chemical preservations checked or not required?	Yes	Preservation checks meet method requirements?	Yes
VOA vials have zero headspace, or not recd.?	Yes		

Project Requested Certification(s)

Microbac Laboratories Inc., - Marietta, OH
68-01670

PA Department of Environmental Protection

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Reviewed and Approved By:

Jacqueline Parsons
Administrative Assistant - AP
Reported: 07/18/2019 16:35

Microbac Laboratories, Inc.

158 Starlite Drive | Marietta, OH 45750 | 800.373.4071 p | www.microbac.com

Page 12 of 17

**Microbac Laboratories
Inc., Pittsburgh Division**



SUBCONTRACT OR
9072600



M 9 G 0 8 7 6

Microbac - PGH

Rec'd: 07/12/2019 09:50

By: Brenda Gregory

Temp: 22.4

(Signature)

SENDING LABORATORY:

Microbac Laboratories Inc., Pittsburgh Division
100 Marshall Drive
Warrendale, PA 15086
Phone: 724-772-0610
Lab Manager: Carolyn Vollentine
Email: carolyn.vollentine@microbac.com

RECEIVING LABORATORY:

Microbac - OVD (PA DEP# 68-01670)
158 STARLITE DRIVE
MARIETTA, OH 45750
Phone: 740-373-4071

Project Info:

Project Name: BASD Samples
Project No: BASD - Middle School

Client: GANNETT FLEMING, INC.
Project Type: ENV-DrinkingWaterNonRe Report TAT: 7
Project Location: Pennsylvania Due: 07/19/2019 00:00

Sample ID: 9072600-01

Sampled: 07/10/2019 08:38

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:38	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO₃

Sample ID: 9072600-02

Sampled: 07/10/2019 08:43

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:43	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO₃

Sample ID: 9072600-03

Sampled: 07/10/2019 08:41

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:41	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO₃



SUBCONTRACT ORDER
9072600

Sample ID: 9072600-04

Sampled: 07/10/2019 08:36

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:36	\$ 12.00

Sub 7/11/19

Containers Supplied:
A: 250 mL Plastic w/ HNO3

Sample ID: 9072600-05

Sampled: 07/10/2019 08:18

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:18	\$ 12.00

Sub 7/11/19

Containers Supplied:
A: 250 mL Plastic w/ HNO3

Sample ID: 9072600-06

Sampled: 07/10/2019 08:16

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:16	\$ 12.00

Sub 7/11/19

Containers Supplied:
A: 250 mL Plastic w/ HNO3

Sample ID: 9072600-07

Sampled: 07/10/2019 08:27

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:27	\$ 12.00

Sub 7/11/19

Containers Supplied:
A: 250 mL Plastic w/ HNO3



SUBCONTRACT ORDER
9072600

Sample ID: 9072600-08

Sampled: 07/10/2019 08:23

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:23	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO3

Sample ID: 9072600-09

Sampled: 07/10/2019 08:49

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:49	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO3

Sample ID: 9072600-10

Sampled: 07/10/2019 08:32

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:32	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO3

Sample ID: 9072600-11

Sampled: 07/10/2019 08:30

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:30	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO3



SUBCONTRACT ORDER
9072600

Sample ID: 9072600-12

Sampled: 07/10/2019 08:20

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:20	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO₃

Sample ID: 9072600-13

Sampled: 07/10/2019 08:46

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:46	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO₃

Sample ID: 9072600-14

Sampled: 07/10/2019 08:49

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:49	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO₃

Sample ID: 9072600-15

Sampled: 07/10/2019 08:27

Matrix: Drinking Water

Sampler: Client

Analysis	Method	Analysis Due	Expires	Network \$
Lead by EPA 200.8 Lead	EPA 200.8, Rv. 5.4 0.001 mg/L	07/19/2019 00:00	01/06/2020 08:27	\$ 12.00
Sub 7/11/19				

Containers Supplied:
A: 250 mL Plastic w/ HNO₃

Released By

Date

Received By

Date

Released By

Date

Received By

Date

