



Microbac Laboratories Inc., Pittsburgh Division  
**CERTIFICATE OF ANALYSIS**

0103748

**GANNETT FLEMING, INC.**

**Project Name: BASD - High School**

ERIC BUZZA  
 FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE  
 PITTSBURGH, PA 15220

Project / PO Number: N/A  
 Received: 10/21/2020  
 Reported: 11/03/2020

**Project Special Information**

5100445

**Analytical Testing Parameters**

<b>Client Sample ID:</b> Maint Garage	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:55
<b>Lab Sample ID:</b> 0103748-01	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	6.24	15.0	0.400	ug/L		10/29/20 1114	10/29/20 1114	EMB

<b>Client Sample ID:</b> Maint Store Rm	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:57
<b>Lab Sample ID:</b> 0103748-02	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.835	15.0	0.400	ug/L		10/29/20 1116	10/29/20 1116	EMB

<b>Client Sample ID:</b> Auditorium 1	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:53
<b>Lab Sample ID:</b> 0103748-03	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	2.01	15.0	0.400	ug/L		10/29/20 1118	10/29/20 1118	EMB

<b>Client Sample ID:</b> Auditorium 2	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:51
<b>Lab Sample ID:</b> 0103748-04	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.518	15.0	0.400	ug/L		10/29/20 1119	10/29/20 1119	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0103748

<b>Client Sample ID:</b> Auditorium 3	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:49
<b>Lab Sample ID:</b> 0103748-05	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	4.29	15.0	0.400	ug/L		10/29/20 1121	10/29/20 1121	EMB

<b>Client Sample ID:</b> Food Service Prep Sink 2	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 6:49
<b>Lab Sample ID:</b> 0103748-06	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	6.52	15.0	0.400	ug/L		10/29/20 1123	10/29/20 1123	EMB

<b>Client Sample ID:</b> Food Service Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 6:47
<b>Lab Sample ID:</b> 0103748-07	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	2.83	15.0	0.400	ug/L		10/29/20 1125	10/29/20 1125	EMB

<b>Client Sample ID:</b> Cafe Fount 1	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 6:55
<b>Lab Sample ID:</b> 0103748-08	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.47	15.0	0.400	ug/L		10/29/20 1134	10/29/20 1134	EMB

<b>Client Sample ID:</b> Cafe Fount 3	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 6:56
<b>Lab Sample ID:</b> 0103748-09	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	4.48	15.0	0.400	ug/L		10/29/20 1136	10/29/20 1136	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0103748

<b>Client Sample ID:</b> Cafe Fount 4	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 6:57
<b>Lab Sample ID:</b> 0103748-10	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.93	15.0	0.400	ug/L		10/29/20 1138	10/29/20 1138	EMB

<b>Client Sample ID:</b> Nurse's Office Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:01
<b>Lab Sample ID:</b> 0103748-11	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	26.8	15.0	0.400	ug/L		10/29/20 1140	10/29/20 1140	EMB

<b>Client Sample ID:</b> SHS Off Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:04
<b>Lab Sample ID:</b> 0103748-12	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	5.10	15.0	0.400	ug/L		10/29/20 1141	10/29/20 1141	EMB

<b>Client Sample ID:</b> 100-1 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:06
<b>Lab Sample ID:</b> 0103748-13	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.716	15.0	0.400	ug/L		10/29/20 1143	10/29/20 1143	EMB

<b>Client Sample ID:</b> 100-2 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:08
<b>Lab Sample ID:</b> 0103748-14	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.791	15.0	0.400	ug/L		10/29/20 1145	10/29/20 1145	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0103748

<b>Client Sample ID:</b> 200-1 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:10
<b>Lab Sample ID:</b> 0103748-15	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.894	15.0	0.400	ug/L		10/29/20 1147	10/29/20 1147	EMB

<b>Client Sample ID:</b> 300-1 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:24
<b>Lab Sample ID:</b> 0103748-16	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/29/20 1319	10/29/20 1319	EMB

<b>Client Sample ID:</b> 300-2 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:27
<b>Lab Sample ID:</b> 0103748-17	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.485	15.0	0.400	ug/L		10/29/20 1154	10/29/20 1154	EMB

<b>Client Sample ID:</b> 306 Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:26
<b>Lab Sample ID:</b> 0103748-18	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.03	15.0	0.400	ug/L		10/29/20 1156	10/29/20 1156	EMB

<b>Client Sample ID:</b> 400-1 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:17
<b>Lab Sample ID:</b> 0103748-19	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.942	15.0	0.400	ug/L		10/29/20 1158	10/29/20 1158	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0103748

<b>Client Sample ID:</b> 400-2 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:18
<b>Lab Sample ID:</b> 0103748-20	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	2.51	15.0	0.400	ug/L		10/29/20 1204	10/29/20 1204	EMB

<b>Client Sample ID:</b> 400-3 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:20
<b>Lab Sample ID:</b> 0103748-21	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	4.27	15.0	0.400	ug/L		10/29/20 1205	10/29/20 1205	EMB

<b>Client Sample ID:</b> 400-4 Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:21
<b>Lab Sample ID:</b> 0103748-22	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	2.59	15.0	0.400	ug/L		10/29/20 1207	10/29/20 1207	EMB

<b>Client Sample ID:</b> Annex Fount 1	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 8:11
<b>Lab Sample ID:</b> 0103748-23	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/29/20 1209	10/29/20 1209	EMB

<b>Client Sample ID:</b> Annex Trn Rm Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 8:14
<b>Lab Sample ID:</b> 0103748-24	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.03	15.0	0.400	ug/L		10/29/20 1211	10/29/20 1211	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0103748

<b>Client Sample ID:</b> Annex Trn Rm Ice	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 8:12
<b>Lab Sample ID:</b> 0103748-25	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/29/20 1213	10/29/20 1213	EMB

<b>Client Sample ID:</b> Annex Wgt Rm Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 8:10
<b>Lab Sample ID:</b> 0103748-26	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	2.64	15.0	0.400	ug/L		10/29/20 1215	10/29/20 1215	EMB

<b>Client Sample ID:</b> Annex Lower Flr Lock Rm Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 8:08
<b>Lab Sample ID:</b> 0103748-27	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/29/20 1224	10/29/20 1224	EMB

<b>Client Sample ID:</b> Serving Line Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 6:51
<b>Lab Sample ID:</b> 0103748-28	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	14.0	15.0	0.400	ug/L		10/29/20 1226	10/29/20 1226	EMB

<b>Client Sample ID:</b> 603-A Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 6:59
<b>Lab Sample ID:</b> 0103748-29	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	62.3	15.0	0.400	ug/L		10/29/20 1227	10/29/20 1227	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0103748

<b>Client Sample ID:</b> 603-B Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:00
<b>Lab Sample ID:</b> 0103748-30	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	11.2	15.0	0.400	ug/L		10/29/20 1229	10/29/20 1229	EMB

<b>Client Sample ID:</b> Gym Lobby Fount 1	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:43
<b>Lab Sample ID:</b> 0103748-31	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.781	15.0	0.400	ug/L		10/29/20 1231	10/29/20 1231	EMB

<b>Client Sample ID:</b> Gym Lobby Fount 2	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:44
<b>Lab Sample ID:</b> 0103748-32	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.603	15.0	0.400	ug/L		10/29/20 1233	10/29/20 1233	EMB

<b>Client Sample ID:</b> Boys Vars Lock Rm Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:38
<b>Lab Sample ID:</b> 0103748-33	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	3.23	15.0	0.400	ug/L		10/29/20 1235	10/29/20 1235	EMB

<b>Client Sample ID:</b> Swim Pool Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:31
<b>Lab Sample ID:</b> 0103748-34	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/29/20 1237	10/29/20 1237	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0103748

<b>Client Sample ID:</b> Gym Train Rm Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:33
<b>Lab Sample ID:</b> 0103748-35	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	2.93	15.0	0.400	ug/L		10/29/20 1238	10/29/20 1238	EMB

<b>Client Sample ID:</b> Gym Train Rm Ice	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:35
<b>Lab Sample ID:</b> 0103748-36	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/30/20 2012	10/30/20 2012	EMB

<b>Client Sample ID:</b> Gym Weight Rm Fount	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:34
<b>Lab Sample ID:</b> 0103748-37	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.934	15.0	0.400	ug/L		10/30/20 2006	10/30/20 2006	EMB

<b>Client Sample ID:</b> Nurse's Kitchen	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:02
<b>Lab Sample ID:</b> 0103748-38	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	21.0	15.0	0.400	ug/L		10/30/20 2014	10/30/20 2014	EMB

<b>Client Sample ID:</b> Maint Lounge Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:59
<b>Lab Sample ID:</b> 0103748-39	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	7.30	15.0	0.400	ug/L		10/30/20 2016	10/30/20 2016	EMB





Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0103748

<b>Client Sample ID:</b> Home EC 203 Sink	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/21/2020 7:14
<b>Lab Sample ID:</b> 0103748-40	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.942	15.0	0.400	ug/L		10/30/20 2017	10/30/20 2017	EMB

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

**Definitions**

**RL:** Reporting Limit  
**ug/L:** Micrograms per Liter

**Project Requested Certification(s)**

Microbac Laboratories Inc., Pittsburgh Division  
02-00257

PA Department of Environmental Protection  
PADEP Accreditation by Rule

**Report Comments**

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.


The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

**Reviewed and Approved By:**

Carolyn Vollenentine  
Service Center Manager  
Reported: 11/03/2020 13:41

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com



**CHAIN OF CUSTODY RECORD**

Number \_\_\_\_\_  
Instructions on back

Lab Report Address Invoice Address Turnaround Time  
 Client Name: *Smart & Fleming* same  
 Address: *Forster Plaza B*  
 City, State, Zip: *Switz 460*  
 Contact: *Pgh Pk 95200*  
 Telephone No.: *Eric Burza*  
 Telephone No.: *412 503 4343*  
 Send Report via:  Mail  Fax  e-mail (address) *cburza@smart.com* Send Invoice via:  Mail  Fax  e-mail (address)  
 Project: *BASO* Location: *High School* PO No.:  
 Sampled by (PRINT): *Eric Burza* Sampler Signature: *E. Burza* Sampler Phone No.: *same*  
 Compliance Monitoring?  Yes  No  
 ( ) Agency/Program

Temperature Upon Receipt (°C) \_\_\_\_\_  
Therm ID \_\_\_\_\_  
Holding Time *18.9*  
Samples Received on Ice? Yes  No  N/A  
Custody Seals Intact? Yes  No  N/A

[ ] Results Only [ ] Level 1 [ ] Level 2 [ ] Level 3 [ ] Level 4 [ ] JEDD

TO BE COMPLETED BY MICROBAC

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
 \*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	REQUESTED ANALYSIS		
	<i>same</i>	<i>10/21/20</i>			<i>ONE U</i>	<i>Lead</i>		HNO3 Preserved Date: 10/21/20 Time: 1140 Intras: KTR		
Possible Hazard Identification <input type="checkbox"/> Hazardous <input type="checkbox"/> Non-Hazardous <input type="checkbox"/> Radioactive <input type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive										
Comments										
Relinquished By (signature) <i>E. Burza</i>						Date/Time <i>10/25/20 940</i>		Received By (signature) <i>Jillie Quail</i>		Date/Time <i>10/21/20 942</i>
Relinquished By (signature)						Date/Time		Received By (signature)		Date/Time
Relinquished By (signature)						Date/Time		Received By (signature)		Date/Time





GANNETT FLEMING, INC.  
PM: Carolyn Vollentine

**Butler Area School District**  
**Facilities Lead and Copper Tesing Results**

Facility	Location	Date	Time
Senior High School	Maint Garage		7:55 AM
Senior High School	Maint Store Rm Sink		7:57 AM
Senior High School	Auditorium 1		7:53 AM
Senior High School	Auditorium 2		7:51 AM
Senior High School	Auditorium 3		7:49 AM
Senior High School	<del>Auditorium 4</del>	<del>—</del>	<del>—</del>
Senior High School	<del>Auditorium 5</del>	<del>—</del>	<del>—</del>
Senior High School	Food Service <sup>Prep Sink 2</sup> Fount		6:49 AM
Senior High School	Food Service Sink		6:47 AM
Senior High School	Café Fount 1		6:55 AM
<del>Senior High School</del>	<del>Café Fount 2</del>	<del>—</del>	<del>—</del>
Senior High School	Cafe Fount 3		6:56 AM
Senior High School	Café Fount 4		6:57 AM
Senior High School	Nurses Off Sink		7:01 AM
Senior High School	SHS Off Sink		7:04 AM
Senior High School	100-1 Fount		7:06 AM
Senior High School	100-2 Fount		7:08 AM
Senior High School	<del>Cons Serv Sink</del>	<del>—</del>	<del>—</del>
Senior High School	200-1 Fount		7:10 AM
Senior High School	300-1 Fount		7:24 AM
Senior High School	300-2 Fount		7:27 AM
Senior High School	306 Sink		7:26 AM
Senior High School	<del>200-2 Fount</del>	<del>—</del>	<del>—</del>
Senior High School	400-1 Fount		7:17 AM
Senior High School	400-2 Fount	LOW PRESSURE	7:18 AM
Senior High School	400-3 Fount		7:20 AM
Senior High School	400-4 Fount		7:21 AM
Senior High School	Annex Fount 1		8:11 AM
Senior High School	Annex Trn Rm Sink		8:14 AM
Senior High School	Annex Trn Rm Ice		8:12 AM
Senior High School	Annex Wgt Rm Fount		8:10 AM
Senior High School	Annex Lower Flr Lock Rm Fount		8:08 AM
Sr. High	Serving line sink		6:51 AM
Sr. High	603-A sink		6:59 AM
Sr. High	603-B sink		7:00 AM

Senior High School	<del>Gym Fountain 1</del>		—
Senior High School	Gym Lobby Fount 1		7:43 AM
Senior High School	Gym Lobby Fount 2		7:44 AM
Senior High School	<del>Gym Rear Hall Fount</del>		—
Senior High School	Boys Vars Lock Rm Fount		7:38 AM
Senior High School	Swim Pool Fount		7:31 AM
Senior High School	<del>Boys Main Lock Rm Fount</del>		—
Senior High School	Gym Train Rm Sink		7:33 AM
Senior High School	Gym Train Rm Ice		7:35 AM
Senior High School	Gym Weight Rm Fount		7:34 AM
Senior High School	<del>Gym Main Lock Fount</del>		—
	Nurses Kitchen		7:02 AM
	MAINT. LOUNGE SINK		7:59 AM
	HOME EC 203 SINK		7:14 AM



GANNETT FLEMING, INC.  
 PM: Carolyn Vellentine