



Microbac Laboratories Inc., Pittsburgh Division  
**CERTIFICATE OF ANALYSIS**

0102647

**GANNETT FLEMING, INC.**

ERIC BUZZA  
 FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE  
 PITTSBURGH, PA 15220

**Project Name: BASD - Intermediate Middle School  
 Center Ave.**

Project / PO Number: N/A  
 Received: 10/14/2020  
 Reported: 10/22/2020

**Project Special Information**

5100445

**Analytical Testing Parameters**

<b>Client Sample ID:</b>	Room 18 Sink 1- First Draw	<b>Collected By:</b>	ERIC BUZZA
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	10/14/2020 7:13
<b>Lab Sample ID:</b>	0102647-01		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	4.35	15.0	0.400	ug/L		10/19/20 2059	10/19/20 2059	EMB

<b>Client Sample ID:</b>	Room 18 Sink 1- 1Minute Flush	<b>Collected By:</b>	ERIC BUZZA
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	10/14/2020 7:14
<b>Lab Sample ID:</b>	0102647-02		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2105	10/19/20 2105	EMB

<b>Client Sample ID:</b>	Room 18 Sink 2- First Draw	<b>Collected By:</b>	ERIC BUZZA
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	10/14/2020 7:16
<b>Lab Sample ID:</b>	0102647-03		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	6.77	15.0	0.400	ug/L		10/19/20 2107	10/19/20 2107	EMB

<b>Client Sample ID:</b>	Room 18 Sink 2- 1 Minute Flush	<b>Collected By:</b>	ERIC BUZZA
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	10/14/2020 7:17
<b>Lab Sample ID:</b>	0102647-04		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2112	10/19/20 2112	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0102647

<b>Client Sample ID:</b> Room 18 Sink 3- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:18
<b>Lab Sample ID:</b> 0102647-05	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	8.62	15.0	0.400	ug/L		10/19/20 2114	10/19/20 2114	EMB

<b>Client Sample ID:</b> Room 18 - 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:19
<b>Lab Sample ID:</b> 0102647-06	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2116	10/19/20 2116	EMB

<b>Client Sample ID:</b> Room 18 Sink 4- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:21
<b>Lab Sample ID:</b> 0102647-07	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	11.3	15.0	0.400	ug/L		10/19/20 2118	10/19/20 2118	EMB

<b>Client Sample ID:</b> Room 18 Sink 4- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:22
<b>Lab Sample ID:</b> 0102647-08	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2120	10/19/20 2120	EMB

<b>Client Sample ID:</b> Room 18 Sink 5- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:23
<b>Lab Sample ID:</b> 0102647-09	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	2.03	15.0	0.400	ug/L		10/19/20 2122	10/19/20 2122	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0102647

<b>Client Sample ID:</b> Room 18 Sink 5- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:24
<b>Lab Sample ID:</b> 0102647-10	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2123	10/19/20 2123	EMB

<b>Client Sample ID:</b> Room 115 Wash Sink - First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:27
<b>Lab Sample ID:</b> 0102647-11	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	3.68	15.0	0.400	ug/L		10/19/20 2125	10/19/20 2125	EMB

<b>Client Sample ID:</b> Room 115 Wash Sink- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:28
<b>Lab Sample ID:</b> 0102647-12	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2134	10/19/20 2134	EMB

<b>Client Sample ID:</b> Room 115 Sink 1- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:29
<b>Lab Sample ID:</b> 0102647-13	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.23	15.0	0.400	ug/L		10/19/20 2136	10/19/20 2136	EMB

<b>Client Sample ID:</b> Room 115 Sink 1- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:31
<b>Lab Sample ID:</b> 0102647-14	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2138	10/19/20 2138	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0102647

<b>Client Sample ID:</b> Room 115 Sink 2- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:32
<b>Lab Sample ID:</b> 0102647-15	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.583	15.0	0.400	ug/L		10/19/20 2140	10/19/20 2140	EMB

<b>Client Sample ID:</b> Room 115 Sink 2- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:33
<b>Lab Sample ID:</b> 0102647-16	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2142	10/19/20 2142	EMB

<b>Client Sample ID:</b> Room 115 Sink 3- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:34
<b>Lab Sample ID:</b> 0102647-17	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.760	15.0	0.400	ug/L		10/19/20 2144	10/19/20 2144	EMB

<b>Client Sample ID:</b> Room 115 Sink 3- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:36
<b>Lab Sample ID:</b> 0102647-18	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2145	10/19/20 2145	EMB

<b>Client Sample ID:</b> Room 115 Sink 4- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:37
<b>Lab Sample ID:</b> 0102647-19	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.776	15.0	0.400	ug/L		10/19/20 2147	10/19/20 2147	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0102647

<b>Client Sample ID:</b> Room 115 Sink 4- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:38
<b>Lab Sample ID:</b> 0102647-20	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/19/20 2149	10/19/20 2149	EMB

<b>Client Sample ID:</b> Room 115 Sink 5- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:39
<b>Lab Sample ID:</b> 0102647-21	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.06	15.0	0.400	ug/L		10/21/20 1130	10/21/20 1130	EMB

<b>Client Sample ID:</b> Room 115 Sink 5- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:40
<b>Lab Sample ID:</b> 0102647-22	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/21/20 1132	10/21/20 1132	EMB

<b>Client Sample ID:</b> Room 115 Sink 6- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:41
<b>Lab Sample ID:</b> 0102647-23	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.00	15.0	0.400	ug/L		10/21/20 1133	10/21/20 1133	EMB

<b>Client Sample ID:</b> Room 115 Sink 6- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:42
<b>Lab Sample ID:</b> 0102647-24	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/21/20 1135	10/21/20 1135	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0102647

<b>Client Sample ID:</b> Room 115 Sink 7- First Draw	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:43
<b>Lab Sample ID:</b> 0102647-25	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	1.50	15.0	0.400	ug/L		10/21/20 1141	10/21/20 1141	EMB

<b>Client Sample ID:</b> Room 115 Sink 7- 1 Minute Flush	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 7:44
<b>Lab Sample ID:</b> 0102647-26	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.400	15.0	0.400	ug/L		10/21/20 1143	10/21/20 1143	EMB

<b>Client Sample ID:</b> MS- Nurse's Office Exam	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 8:14
<b>Lab Sample ID:</b> 0102647-27	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	6.99	15.0	0.400	ug/L		10/21/20 1144	10/21/20 1144	EMB

<b>Client Sample ID:</b> MS- Food Service Sink Prep	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 8:16
<b>Lab Sample ID:</b> 0102647-28	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	16.5	15.0	0.400	ug/L		10/21/20 1146	10/21/20 1146	EMB

<b>Client Sample ID:</b> MS- Faculty Cafe Sink Lounge	<b>Collected By:</b> ERIC BUZZA
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/14/2020 8:18
<b>Lab Sample ID:</b> 0102647-29	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	4.21	15.0	0.400	ug/L		10/21/20 1148	10/21/20 1148	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

0102647

Client Sample ID: CE-Nurse's Sink	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 8:04
Lab Sample ID: 0102647-30	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.638	15.0	0.400	ug/L		10/21/20 1150	10/21/20 1150	EMB

Client Sample ID: CE-Food Service Sink	Collected By: ERIC BUZZA
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 8:04
Lab Sample ID: 0102647-31	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	2.57	15.0	0.400	ug/L		10/21/20 1155	10/21/20 1155	EMB

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- RL: Reporting Limit
- ug/L: Micrograms per Liter

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division  
02-00257

PA Department of Environmental Protection  
PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**


Reviewed and Approved By:



Rachel McCoy  
Client Relations Specialist  
Reported: 10/22/2020 14:06

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com



**CHAIN OF CUSTODY RECORD**

Number 0102647  
Instructions on back

Lab Report Address Invoice Address Turnaround Time  
 Client Name: Gannett Fleming same  
 Address: 500  
 City, State, Zip: same  
 Contact: Eric Buzzza  
 Telephone No.: 412 503 4343  
 Send Report via:  Mail  Fax  e-mail (address) ebuzzza@net.com Send Invoice via:  Mail  Fax  e-mail (address) ebuzzza@net.com  
 Project: By-Har Area School District Intermediate Center Ave McKeesport  
 Sampled by (PRINT): Eric Buzzza Sampler Signature: E. Buzzza No.: 412 503 - 4343  
 \* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
 \*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Temperature Upon Receipt (°C) \_\_\_\_\_  
 Therm ID \_\_\_\_\_  
 Holding Time \_\_\_\_\_  
 Samples Received on Ice? Yes  No   
 Custody Seals Intact? Yes  No   
 [ ] Results Only [ ] Level 1 [ ] Level 2 [ ] Level 3 [ ] Level 4 [ ] JEDD  
 Compliance Monitoring? [ ] Yes [x] No  
 ( ) Agency/Program

Requested Analysis: \_\_\_\_\_  
 Additional Notes: \_\_\_\_\_  
 HNO3 Preserved  
 Date: 10/14/20  
 Time: 1600  
 Initials: KTR

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Sample Disposition	Relinquished By (signature)	Date/Time	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time	Received By (signature)	Date/Time
	<u>340 Attached</u>	<u>10/14</u>				<u>DWS None</u>	<u>X</u>	<u>Lead</u>	<u>E. Buzzza</u>	<u>10/14/20 10:20</u>	<u>E. Buzzza</u>	<u>10/14/20 10:20</u>	<u>[Signature]</u>	<u>10/14/20 10:20</u>	<u>[Signature]</u>	<u>10/14/20 10:20</u>



GANNETT FLEMING, INC.  
PM: Carolyn Volentine



BASD Lead Sampling 2020

Facility	Location	Date	Time
Intermediate School	Room 18 Sink 1 - First Draw	10/14	7:13 AM ✓
Intermediate School	Room 18 Sink 1 - 1 minute flush	10/14	7:14 AM ✓
Intermediate School	Room 18 Sink 2 - First Draw	10/14	7:16 AM ✓
Intermediate School	Room 18 Sink 2 - 1 minute flush	10/14	7:17 AM ✓
Intermediate School	Room 18 Sink 3 - First Draw	10/14	7:18 AM ✓
Intermediate School	Room 18 - 1 minute flush	10/14	7:19 AM ✓
Intermediate School	Room 18 Sink 4* - First Draw	10/14	7:21 AM ✓
Intermediate School	Room 18 sink 4 - 1 minute flush	10/14	7:22 AM ✓
Intermediate School	Room 18 Sink 5* - First Draw	10/14	7:23 AM ✓
Intermediate School	Room 18 sink 5 - 1 minute flush	10/14	7:24 AM ✓
Intermediate School	Room 18 Sink 6 - First Draw	10/14	7:27 AM ✓
Intermediate School	Room 18 Sink 6 - 1 minute flush	10/14	7:28 AM ✓
Intermediate School	Room 115 Sink 2* - First Draw	10/14	7:29 AM ✓
Intermediate School	Room 115 Sink 2 - 1 minute flush	10/14	7:31 AM ✓
Intermediate School	Room 115 Sink 3* - First Draw	10/14	7:32 AM ✓
Intermediate School	Room 115 Sink 3 - 1 minute flush	10/14	7:33 AM ✓
Intermediate School	Room 115 Sink 4 - First Draw	10/14	7:34 AM ✓
Intermediate School	Room 115 Sink 4 - 1 minute flush	10/14	7:36 AM ✓
Intermediate School	Room 115 Sink 5* - First Draw	10/14	7:37 AM ✓
Intermediate School	Room 115 Sink 5 - 1 minute flush	10/14	7:38 AM ✓
Intermediate School	Room 115 Sink 6* - First Draw	10/14	7:39 AM ✓
Intermediate School	Room 115 Sink 6 - 1 minute flush	10/14	7:40 AM ✓
Intermediate School	Room 115 Sink 7* - First Draw	10/14	7:41 AM ✓
Intermediate School	Room 115 Sink 7 - 1 minute flush	10/14	7:42 AM ✓

115 wash  
115 wash  
sink 1  
1  
2  
2  
3  
3  
4  
4  
5  
5  
6  
6

\* These locations had lead results less than the EPA Action Level but were relatively high lead levels

115 - 7 IHS	First Draw	10/14	7:43 AM ✓
115 - 7 IHS	1 minute	10/14	7:49 AM ✓



GANNETT FLEMING, INC.

PM: Carolyn Vollentine

BASD Lead Sampling 2020

Facility	Location	Date	Time
Middle School	Nurse's Office Exam	10/14	8:14 Am
Middle School	Food Service Sink Prep	10/14	8:16 Am
Middle School	Faculty Café Sink	10/14	8:18 Am

\* Lounge ✓



0 1 0 2 6 4 7

GANNETT FLEMING, INC.

PM: Carolyn Vollentine

BASD Lead Sampling 2020

Facility	Location	Date	Time
Center Ave Elementary	Nurses <del>Rest Rm</del> Sink	10/14	8:04 AM
Center Ave Elementary	Food Service Sink	10/14	8:04 AM



0 1 0 2 6 4 7

GANNETT FLEMING, INC.

PM: Carolyn Vollentine