



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

1113842

GANNETT FLEMING, INC.

Project Name: BASD Intermediate High School

ERIC BUZZA
FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE
PITTSBURGH, PA 15220

Project / PO Number: N/A
Received: 11/23/2021
Reported: 12/03/2021

Analytical Testing Parameters

Client Sample ID:	Office Men FTN	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/22/2021 7:39
Lab Sample ID:	1113842-01		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1549	11/30/21 1549	EMB

Client Sample ID:	Security Desk FTN	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/22/2021 7:40
Lab Sample ID:	1113842-02		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1556	11/30/21 1556	EMB

Client Sample ID:	Nurses Desk Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/22/2021 7:41
Lab Sample ID:	1113842-03		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00226	0.0150	0.000400	mg/L		11/30/21 1558	11/30/21 1558	EMB

Client Sample ID:	Aux Gym FTN	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/22/2021 7:32
Lab Sample ID:	1113842-04		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1600	11/30/21 1600	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

1113842

Client Sample ID: Pool Left FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:33
Lab Sample ID: 1113842-05	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00222	0.0150	0.000400	mg/L		11/30/21 1601	11/30/21 1601	EMB

Client Sample ID: Weight Room FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:30
Lab Sample ID: 1113842-06	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L			11/30/21 1609	EMB

Client Sample ID: Training Room Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:35
Lab Sample ID: 1113842-07	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1610	11/30/21 1610	EMB

Client Sample ID: Training Room Ice	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:36
Lab Sample ID: 1113842-08	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1612	11/30/21 1612	EMB

Client Sample ID: Cafe B Front FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:28
Lab Sample ID: 1113842-09	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1614	11/30/21 1614	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

1113842

Client Sample ID: Cafe A Sink Back	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:52
Lab Sample ID: 1113842-10	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0120	0.0150	0.000400	mg/L		11/30/21 1617	11/30/21 1617	EMB

Client Sample ID: 140 L FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:23
Lab Sample ID: 1113842-11	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1619	11/30/21 1619	EMB

Client Sample ID: 124 FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:25
Lab Sample ID: 1113842-12	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1626	11/30/21 1626	EMB

Client Sample ID: Cafe A Back FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:21
Lab Sample ID: 1113842-13	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1628	11/30/21 1628	EMB

Client Sample ID: Cafe A Sink Front	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:54
Lab Sample ID: 1113842-14	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00616	0.0150	0.000400	mg/L		11/30/21 1635	11/30/21 1635	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

1113842

Client Sample ID: 115 Sink 1	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:13
Lab Sample ID: 1113842-15	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000460	0.0150	0.000400	mg/L		11/30/21 1637	11/30/21 1637	EMB

Client Sample ID: 108 FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:50
Lab Sample ID: 1113842-16	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1639	11/30/21 1639	EMB

Client Sample ID: 103 FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:48
Lab Sample ID: 1113842-17	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1641	11/30/21 1641	EMB

Client Sample ID: Lounge Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:46
Lab Sample ID: 1113842-18	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00218	0.0150	0.000400	mg/L		11/30/21 1643	11/30/21 1643	EMB

Client Sample ID: JROTC 1 FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:44
Lab Sample ID: 1113842-19	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1644	11/30/21 1644	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

1113842

Client Sample ID: Cafe D Back FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 8:07
Lab Sample ID: 1113842-20	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1646	11/30/21 1646	EMB

Client Sample ID: 207 FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 8:05
Lab Sample ID: 1113842-21	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L			11/30/21 1710	EMB

Client Sample ID: English WRR FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 8:08
Lab Sample ID: 1113842-22	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1711	11/30/21 1711	EMB

Client Sample ID: Cafe C Back FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 8:09
Lab Sample ID: 1113842-23	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1713	11/30/21 1713	EMB

Client Sample ID: 246 FTN	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 8:03
Lab Sample ID: 1113842-24	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1715	11/30/21 1715	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

1113842

Client Sample ID: 243 FTN		Collected By: Eric Buzza
Sample Matrix: Drinking Water		Collection Date: 11/22/2021 7:59
Lab Sample ID: 1113842-25		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1717	11/30/21 1717	EMB

Client Sample ID: Rm 18 Sink 1		Collected By: Eric Buzza
Sample Matrix: Drinking Water		Collection Date: 11/22/2021 7:07
Lab Sample ID: 1113842-26		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000588	0.0150	0.000400	mg/L		11/30/21 1718	11/30/21 1718	EMB

Client Sample ID: Rm 18 Sink 2		Collected By: Eric Buzza
Sample Matrix: Drinking Water		Collection Date: 11/22/2021 7:08
Lab Sample ID: 1113842-27		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1726	11/30/21 1726	EMB

Client Sample ID: Rm 18 Sink 3		Collected By: Eric Buzza
Sample Matrix: Drinking Water		Collection Date: 11/22/2021 7:09
Lab Sample ID: 1113842-28		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1727	11/30/21 1727	EMB

Client Sample ID: Rm 18 Sink 4		Collected By: Eric Buzza
Sample Matrix: Drinking Water		Collection Date: 11/22/2021 7:10
Lab Sample ID: 1113842-29		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1729	11/30/21 1729	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

1113842

Client Sample ID: Rm 18 Sink 5	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:11
Lab Sample ID: 1113842-30	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000728	0.0150	0.000400	mg/L		11/30/21 1736	11/30/21 1736	EMB

Client Sample ID: Rm 115 Sink 7	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:18
Lab Sample ID: 1113842-31	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000750	0.0150	0.000400	mg/L		11/30/21 1738	11/30/21 1738	EMB

Client Sample ID: Rm 115 Sink 2	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:14
Lab Sample ID: 1113842-32	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		11/30/21 1740	11/30/21 1740	EMB

Client Sample ID: Rm 115 Sink 3	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:14
Lab Sample ID: 1113842-33	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000496	0.0150	0.000400	mg/L		11/30/21 1742	11/30/21 1742	EMB

Client Sample ID: Rm 115 Sink 4	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:15
Lab Sample ID: 1113842-34	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000478	0.0150	0.000400	mg/L		11/30/21 1743	11/30/21 1743	EMB



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

1113842

Client Sample ID: Rm 115 Sink 5	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:16
Lab Sample ID: 1113842-35	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000521	0.0150	0.000400	mg/L		11/30/21 1751	11/30/21 1751	EMB

Client Sample ID: Rm 115 Sink 6	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/22/2021 7:17
Lab Sample ID: 1113842-36	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000704	0.0150	0.000400	mg/L		11/30/21 1752	11/30/21 1752	EMB

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
02-00257

PA Department of Environmental Protection
PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Carolyn Vollentine
Service Center Manager
Reported: 12/03/2021 10:51

MICROBAC 1962 Wager Rd., Erie, PA 16509 | 814.825.8533 p | 814.825.9254 f



GANNETT FLEMING, INC.

PM: Carolyn Volentine

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Turnaround Time

Routine (5 to 7 business days)
 RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No
 Agency/Program

Lab Report Address

Client Name: Gannett Fleming

Address: Foster Plaza 8 Suite 400 730 Holiday Dr

City, State, Zip: Pittsburgh, PA 15220

Contact: Eric Buizza

Telephone No.: (412) 503-4343

Invoice Address

Client Name: Same

Address:

City, State, Zip:

Contact:

Telephone No.:

Send Report via: Mail Fax e-mail (address)

Project: BASD Intermediate High School - Lead Sam; Location: BASD Intermediate High Schoc PO No.:

Sampled by (PRINT): Eric Buizza

Sampler Signature: *E. Buizza*

Sampler Phone No.: (412) 503-4343

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Lead
	See Attached	11-22-21		36 DW G			U	X

Additional Notes

HNO3 Preserved
Date: 11/29/21
Time: 11:25
Initials: JLC

Possible Hazard Identification

Hazardous Non-Hazardous Radioactive

Relinquished By (signature) *E. Buizza* Date/Time 11/23/21 10:22

Relinquished By (signature) *[Signature]* Date/Time

Received By (signature) *[Signature]* Date/Time 11/28/21 10:25

Received By (signature) *[Signature]* Date/Time

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature) Date/Time

Butler Area School District
Facilities Lead and Copper Tesing Results



1 1 1 3 8 4 2
GANNETT FLEMING, INC.
PM: Carolyn Vollentine

Facility	Location	Date	Time
Intermediate School	Office Men FTN	11/22/2021	7:39am
Intermediate School	Office Women FTN	11/22/2021	out of service
Intermediate School	Security Desk FTN	11/22/2021	7:40am
Intermediate School	Nurse's Desk Sink	11/22/2021	7:41am
Intermediate School	Aux Gym FTN	11/22/2021	7:32am
Intermediate School	Pool Left FTN	11/22/2021	7:33am
Intermediate School	Pool Right FTN	11/22/2021	out of service
Intermediate School	Weight Room FTN	11/22/2021	7:30am
Intermediate School	Training Room Sink	11/22/2021	7:35am
Intermediate School	Training Room Ice	11/22/2021	7:36am
Intermediate School	JROTC 141 Men FTN	11/22/2021	out of service
Intermediate School	Café B Front FTN	11/22/2021	7:28am
Intermediate School	Café A Sink Café A Sink Back	11/22/2021	7:28am 7:52am
Intermediate School	140 L FTN	11/22/2021	7:23am
Intermediate School	126 FTN	11/22/2021	out of service
Intermediate School	124 FTN	11/22/2021	7:25am
Intermediate School	Café A Back FTN	11/22/2021	7:21am
Intermediate School	Café A Sink Front	11/22/2021	7:54am
Intermediate School	116 FTN	11/22/2021	out of service
Intermediate School	115 Sink 1	11/22/2021	7:13am
Intermediate School	108 FTN	11/22/2021	7:50am
Intermediate School	Wood Shop FTN	11/22/2021	out of service
Intermediate School	103 FTN	11/22/2021	7:48am
Intermediate School	Lounge Sink	11/22/2021	7:46am
Intermediate School	JROTC 1 FTN	11/22/2021	7:44am
Intermediate School	Café D Back FTN	11/22/2021	8:07am
Intermediate School	207 FTN	11/22/2021	8:05am 8:05am
Intermediate School	English WRR FTN	11/22/2021	8:08am
Intermediate School	Café C Back FTN	11/22/2021	7:57am 8:09am

8:03

Intermediate School	246 FTN	11/22/2021	7:59am
Intermediate School	243 FTN	11/22/2021	7:59am
Intermediate School	Rm 18 Sink 1	11/22/2021	7:07am
Intermediate School	Rm 18 Sink 2	11/22/2021	7:08am
Intermediate School	Rm 18 Sink 3	11/22/2021	7:09am
Intermediate School	Rm 18 Sink 4	11/22/2021	7:10am
Intermediate School	Rm 18 Sink 5	11/22/2021	7:11am
Intermediate School	Rm ¹¹⁵ 18 Sink 6 7	11/22/2021	7:18am
Intermediate School	Rm 115 Sink 2	11/22/2021	7:14am
Intermediate School	Rm 115 Sink 3	11/22/2021	7:14am
Intermediate School	Rm 115 Sink 4	11/22/2021	7:15am
Intermediate School	Rm 115 Sink 5	11/22/2021	7:16am
Intermediate School	Rm 115 Sink 6	11/22/2021	7:17am



1 1 1 3 8 4 2

GANNETT FLEMING, INC.

PM: Carolyn Vollentine