


## Report of Analysis

<b>Name:</b>	Parkway School Greenwich Public Schools - Cordes George 290 Greenwich Ave Greenwich, CT 06830-6521	<b>Sample ID#:</b>	289713
		<b>Sample Type:</b>	Drinking Water
		<b>Sampler:</b>	PD
		<b>PWS ID:</b>	CT0570212
<b>Sample Date:</b>	7/6/2022 12:20 PM		
<b>Receipt Date:</b>	7/6/2022 3:50 PM		
<b>Report Date:</b>	7/8/2022		
<b>Sample Site:</b>	ENTRY POINT		

Parameter	Sample Result	Units	Method	RL	Analysis Date	Analyst
<b>Nutrient</b>						
Nitrate as N	1.4	mg/L	EPA 300.0	0.5	7/6/2022 21:10	JR
Nitrite as N	ND	mg/L	EPA 300.0	0.1	7/6/2022 21:10	JR

**Comments:** Samples were collected in accordance with the NE States Sample Collection Manual Rev 5.0

ND = Not Detected  
 \* = Above Specified Limit

**Report Approved by:**  \_\_\_\_\_ CT Lic PH-0787 NY Lic 11706  
 Lab Director

AquaEnvLab.com  
 YorkLab.com  
 203 270 9973

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.