

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Shadow Ridge MS

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in Service Date	Sample Count
			in PPB			
Initial Sample	032117.281A.200DF.01	Drinking fountain, corridor 200, east wall, right side DF	ND	-	-	1
	032117.281A.200DF.02	Drinking fountain, corridor 200, east wall, left side DF	ND	-	-	1
	032117.281A.201DF.01	Drinking fountain, corridor 201, east wall, right side DF	ND	-	-	1
	032117.281A.201DF.02	Drinking fountain, corridor 201, east wall, left side DF	ND	-	-	1
	032117.281A.202DF.01	Drinking fountain, corridor 202, right side DF	ND	-	-	1
	032117.281A.202DF.02	Drinking fountain, corridor 202, left side DF	ND	-	-	1
	032117.281A.500DF.01	Drinking fountain, corridor 500, east wall, south end, right s	ND	-	-	1
	032117.281A.500DF.02	Drinking fountain, corridor 500, east wall, south end, left sic	0.65	-	-	1
	032117.281A.500DF.03	Drinking fountain, corridor 500, east wall, north end, right s	ND	-	-	1
	032117.281A.500DF.04	Drinking fountain, corridor 500, east wall, north end, left sic	ND	-	-	1
	032117.281A.A100SK.01	Sink, room A100, SW corner	0.8	-	-	1
	032117.281A.A100SK.02	Sink, room A100, SE corner	1.7	-	-	1
	032117.281A.A106SK.01	Sink, room A106	0.54	-	-	1
	032117.281A.A107SK.01	Sink, room A107	0.62	-	-	1
	032117.281A.A200SK.01	Sink, room A200, SW corner	1.2	-	-	1
	032117.281A.A200SK.02	Sink, room A200, SE corner	0.7	-	-	1
	032117.281A.A204SK.01	Sink, room A204, north island, math-lab classroom	21	Taken offline	-	1
	032117.281A.A204SK.02	Sink, room A204, west wall	3.2	-	-	1
	032117.281A.A204SK.03	Sink, room A204, SW corner	2.3	-	-	1
	032117.281A.A204SK.04	Sink, room A204, SE corner	0.8	-	-	1
	032117.281A.A206SK.01	Sink, room A206	6.1	-	-	1
	032117.281A.A207SK.01	Sink, room A207	0.84	-	-	1
	032117.281A.B103SK.01	Sink, room B103	3.2	-	-	1
	032117.281A.B107SK.01	Sink, room B107	0.58	-	-	1
	032117.281A.B109SK.01	Sink, room B109	1.6	-	-	1
	032117.281A.C100SK.01	Sink, room C100, SW corner	0.79	-	-	1
	032117.281A.C100SK.02	Sink, room C100, SE corner	0.56	-	-	1
	032117.281A.C106SK.01	Sink, room C106	1	-	-	1
	032117.281A.C107SK.01	Sink, room C107	0.58	-	-	1
	032117.281A.C200SK.01	Sink, room C200, SW corner	2	-	-	1
	032117.281A.C200SK.02	Sink, room C200, SE corner	12	-	-	1
	032117.281A.C204SK.01	Sink, room C204, north island	9.2	-	-	1
	032117.281A.C204SK.02	Sink, room C204, west wall	3	-	-	1
	032117.281A.C204SK.03	Sink, room C204, SW corner	3	-	-	1
	032117.281A.C204SK.04	Sink, room C204, SE corner	1.3	-	-	1
	032117.281A.C206SK.01	Sink, room C206	0.6	-	-	1
	032117.281A.C207SK.01	Sink, room C207	3.6	-	-	1
	032117.281A.D106SK.01	Sink, room D106	0.62	-	-	1
	032117.281A.D121SK.01	Sink, room D121	ND	-	-	1
	032117.281A.D123SK.01	Sink, room D123	ND	-	-	1
	032117.281A.D139SK.01	Sink, room D139	ND	-	-	1
	032117.281A.D204SK.01	Sink, room D204	0.9	-	-	1
	032117.281A.D208SK.01	Sink, room D208, W wall, far left SK	0.6	-	-	1
	032117.281A.D208SK.02	Sink, room D208, W wall, next to SK.01	0.61	-	-	1
	032117.281A.D208SK.03	Sink, room D208, W wall, next to SK.02	0.64	-	-	1
	032117.281A.D208SK.04	Sink, room D208, W wall, next to SK.03	0.73	-	-	1
	032117.281A.D208SK.05	Sink, room D208, W wall, next to SK.04	1.2	-	-	1
	032117.281A.D208SK.06	Sink, room D208, W wall, far right SK	7.3	-	-	1
	032117.281A.D211SK.01	Sink, room D211, NW corner, right side SK	0.59	-	-	1
	032117.281A.D211SK.02	Sink, room D211, NW corner, left side SK	0.7	-	-	1
032117.281A.D211SK.03	Sink, room D211, SW corner, right side SK	1.2	-	-	1	
032117.281A.D211SK.04	Sink, room D211, SW corner, left side SK	1.1	-	-	1	
032117.281A.D212SK.01	Sink, room D212	ND	-	-	1	
032117.281A.E100DF.01	Drinking fountain, room E100, NE corner, left side DF	0.51	-	-	1	
032117.281A.E100DF.02	Drinking fountain, room E100, NE corner, right side DF	ND	-	-	1	

Water Sampling Results

Report Legend:

Sample ID: Lab Generated Unique ID | Yellow: 15-19.9PPB | Orange: 20 PPB and Above

ND: Non-detect (below detection limit) | PPB: Parts per Billion

School Name Shadow Ridge MS

Sample Type	Sample ID	Sample Description	Lead Result	Action Taken	Back in Service	Sample Count
			in PPB		Date	
	032117.281A.E105SK.01	Sink, room E105	1.8	-	-	1
	032117.281A.E107DF.01	Drinking fountain, room E107, SE corner, right side DF	ND	-	-	1
	032117.281A.E107DF.02	Drinking fountain, room E107, SE corner, left side DF	ND	-	-	1
	032117.281A.E111SK.01	Sink, room E111	1.9	-	-	1
	032117.281A.E113DF.01	Drinking fountain, room E113, west wall, right side DF	1.3	-	-	1
	032117.281A.E113DF.02	Drinking fountain, room E113, west wall, left side DF	0.64	-	-	1
	032117.281A.F104SK.01	Sink, room F104, NE island	0.61	-	-	1
	032117.281A.F104SK.02	Sink, room F104, NW island	6.5	-	-	1
	032117.281A.F104SK.03	Sink, room F104, south wall	1.5	-	-	1
	032117.281A.F104SK.04	Sink, room F104, SW corner	4.7	-	-	1
	032117.281A.F104SK.05	Sink, room F104, east wall	2.4	-	-	1
	032117.281A.F105SK.01	Sink, room F105, snack bar sink	25	Taken offline	-	1
	032117.281A.F111SK.01	Sink, room F111	0.52	-	-	1
	032117.281A.F115DF.01	Drinking fountain, room F115	1.3	-	-	1
	032117.281A.F122DF.01	Drinking fountain, room F122, north wall	ND	-	-	1
	032117.281A.F122SK.01	Sink, room F122, south wall	0.52	-	-	1
Initial Sample Total						71

Resultados de las Muestras de Agua

Guía en español para leer los resultados de las pruebas de las muestras de agua en su escuela

Por favor, consulte esta guía para entender mejor los resultados en español de las pruebas de las muestras de agua en su escuela:

Report Legend: Leyenda del Reporte

- Sample ID: Lab Generated Unique ID = ID de la Muestra: ID única creada por el laboratorio
- Yellow: 15-19.9PPB | Orange: 20 PPB and Above = Amarillo: 15-19.9 ppb | Anaranjado: 20 ppb y más
- PPB: partes por mil millones
- ND: No detectable (por debajo del límite detectable)

Sample Description: ID de la Muestra

- Drinking fountain = Fuente de agua
- Sink = Lavabo
- Room ## = salón ##
- Middle of room = a mitad del salón
- North wall = pared del norte
- NE corner = esquina al noreste
- SE corner = esquina al sureste
- NW corner = esquina al noroeste
- SW corner = esquina al suroeste
- Next to SK.## = al lado del SK.## (SK=lavabo/fregadero)
- Hallway = pasillo
- Main hallway = pasillo principal
- Long main hallway = Pasillo principal largo
- Short main hallway = Pasillo principal corto

Lead Result in PPB = Resultados de plomo en PPB

La Agencia de Protección Ambiental (EPA, por sus siglas en inglés) mide la cantidad de plomo en el agua en "partes por mil millones" o "ppb (por sus siglas en inglés)." Una parte por mil millones equivale a una gota de agua en 55,000 galones. Al igual que otros distritos escolares en Colorado que voluntariamente están conduciendo estas pruebas, Adams 12 Five Star Schools está siguiendo las normas de EPA para eliminar y remediar cualquier accesorio de plomería que tenga niveles de plomo de 15 ppb o más.

Action = Acción

Taken offline = Desconectado/a