



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

19 October 2018

Pleasanton, City of

Attn: Susan Clough

PO Box 520

Pleasanton, CA 94566

RE: Lead In Schools

Work Order: 18J0692

Enclosed are the results of analyses for samples received by the laboratory on 10/04/18 21:54. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

DRAFT REPORT

DATA SUBJECT TO CHANGE



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Pleasanton, City of	Project:	Lead In Schools	
PO Box 520	Project #:	0110008 / Resamples	Reported:
Pleasanton CA, 94566	Project Mgr:	Susan Clough	10/19/18 13:18

Analytical Report for Samples

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
0110008-AAD-J	18J0692-01	Water	10/04/18 07:09	10/04/18 21:54
0110008-AAH-A	18J0692-02	Water	10/04/18 07:20	10/04/18 21:54
0110008-ABB-D	18J0692-03	Water	10/04/18 07:50	10/04/18 21:54



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 0110008-AAD-J
Laboratory ID: 18J0692-01

Report Date: 10/19/18 13:18
Laboratory Code: 1610

System Name: CITY OF PLEASANTON
Source Name:
Sampled by: Marque DeBray
Employed by: City of Pleasanton

Sample Date: 10/04/18 07:09
Sample Received: 10/04/18 21:54
User ID:
System Number:

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	50		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 0110008-AAH-A
Laboratory ID: 18J0692-02

Report Date: 10/19/18 13:18
Laboratory Code: 1610

System Name: CITY OF PLEASANTON
Source Name:
Sampled by: Marque DeBray
Employed by: City of Pleasanton

Sample Date: 10/04/18 07:20
Sample Received: 10/04/18 21:54
User ID:
System Number:

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Sample Name: 0110008-ABB-D
Laboratory ID: 18J0692-03

Report Date: 10/19/18 13:18
Laboratory Code: 1610

System Name: CITY OF PLEASANTON
Source Name:
Sampled by: Marque DeBray
Employed by: City of Pleasanton

Sample Date: 10/04/18 07:50
Sample Received: 10/04/18 21:54
User ID:
System Number:

Inorganic Chemicals

Parameter	Result	MCL	DLR	Units	Storet	Test Method
Lead	<5.0		5.0	ug/L	01051	EPA 200.8



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 6398 Dougherty Rd., Suite 35, Dublin, CA 94568 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Notes and Definitions

ND Analyte NOT DETECTED at or above the reporting limit

* Tiered Maximum Contaminant and/or Action Levels: Sulfate and Chloride 250-500-600 mg/L, Specific Conductance 900-1600-2200 umho/cm, TDS 500-1000-1500 mg/L.

Items for Project Manager Review

LabNumber

Analysis

Analyte

Exception
