



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

ELAP Certificates 1551, 2728, and 2922

24 October 2018

Pleasanton, City of

Attn: Susan Clough

PO Box 520

Pleasanton, CA 94566

RE: Lead In Schools

Work Order: 18J0729

Enclosed are the results of analyses for samples received by the laboratory on 10/04/18 21:57. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jeanette L. Poplin For Robbie C. Phillips

Project Manager



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Pleasanton, City of
PO Box 520
Pleasanton, CA 94566

Project Manager: Susan Clough
Project: Lead In Schools
Project Number: 0110008 / Valley View - 13

Reported:
10/24/18 10:59

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
0110008-ABD-A	18J0729-01	Water	10/04/18 06:12	10/04/18 21:57
0110008-ABD-B	18J0729-02	Water	10/04/18 06:19	10/04/18 21:57
0110008-ABD-C	18J0729-03	Water	10/04/18 06:35	10/04/18 21:57
0110008-ABD-D	18J0729-04	Water	10/04/18 06:40	10/04/18 21:57
0110008-ABD-E	18J0729-05	Water	10/04/18 06:28	10/04/18 21:57



Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Pleasanton, City of
PO Box 520
Pleasanton, CA 94566

Project Manager: Susan Clough
Project: Lead In Schools
Project Number: 0110008 / Valley View - 13

Reported:
10/24/18 10:59

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
0110008-ABD-A (18J0729-01)								
		Sample Type: Water			Sampled: 10/04/18 06:12			
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	ND ug/L	5.0	1	AJ83629	10/11/18 09:58	10/12/18 04:17	EPA 200.8	
0110008-ABD-B (18J0729-02)								
		Sample Type: Water			Sampled: 10/04/18 06:19			
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	ND ug/L	5.0	1	AJ83629	10/11/18 09:58	10/12/18 04:23	EPA 200.8	
0110008-ABD-C (18J0729-03)								
		Sample Type: Water			Sampled: 10/04/18 06:35			
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	ND ug/L	5.0	1	AJ83629	10/11/18 09:58	10/12/18 04:29	EPA 200.8	
0110008-ABD-D (18J0729-04)								
		Sample Type: Water			Sampled: 10/04/18 06:40			
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	ND ug/L	5.0	1	AJ83629	10/11/18 09:58	10/12/18 04:35	EPA 200.8	
0110008-ABD-E (18J0729-05)								
		Sample Type: Water			Sampled: 10/04/18 06:28			
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	ND ug/L	5.0	1	AJ83629	10/11/18 09:58	10/12/18 05:17	EPA 200.8	



Alpha

Alpha Analytical Laboratories Inc.

e-mail: clientservices@alpha-labs.com

Corporate: 208 Mason St., Ukiah, CA 95482 • Phone: (707) 468-0401 • Fax: (707) 468-5267

Bay Area: 262 Rickenbacker Circle, Livermore, CA 94551 • Phone: (925) 828-6226 • Fax: (925) 828-6309

Central Valley: 9090 Union Park Way, Suite 113, Elk Grove, CA 95624 • Phone: (916) 686-5190 • Fax: (916) 686-5192

Pleasanton, City of
PO Box 520
Pleasanton, CA 94566

Project Manager: Susan Clough
Project: Lead In Schools
Project Number: 0110008 / Valley View - 13

Reported:
10/24/18 10:59

Notes and Definitions

- P-02 Sample acidified to pH <2 and allowed to sit 24 hours before further processing.
- ND Analyte NOT DETECTED at or above the reporting limit
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference

Corporate Laboratory
208 Mason Street, Ukiah CA 95482
707-468-0401 F) 707-468-5267
email: clientservices@alpha-labs.com

Bay Area Laboratory
262 Rickenbacker Circle, Livermore CA 94551
925-828-6226 F) 925-828-6309






Central Valley Laboratory
9090 Union Park Way #113, Elk Grove CA 95624
916-686-5190 F) 916-686-5192

Alpha Analytical Laboratories Inc.
www.alpha-labs.com
WATERS, SEDIMENTS, SOLIDS

Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format

Lab No 1050729 Pg 1 of 1

Report to			Invoice to (if different)			Project Information				Analysis Request		TAT		Temp upon Receipt °C					
Company: City of Pleasanton Attn: Susan Clough Address: 3333 Busch Road Pleasanton, CA 94566 925-931-5510 Email Address: sclough@cityofpleasantonca.gov Field Sampler - Printed Name & Signature: Marque DeBray 			Contact: Email address: Address: PO Box 520 Phone/Fax:			Project ID: Valley View -13 Project No: Lead in Schools PO Number:				Analysis Request 		TAT Standard 10 days <input checked="" type="radio"/> RUSH: 5 days <input type="radio"/> 48 hours <input type="radio"/> Other: _____ days <input type="radio"/>		Temp upon Receipt °C Ukiah temp: <u>30.0</u> Livermore temp: _____ Elk Grove temp: _____					
Sample Identification		Sampling		Container			Preservative			Matrix			DDW Source Numbers:		Sample Notes or				
		Date	Time	40ml Vial	Poly	Glass	Sleeve	Other	HCl	HNO3	H2SO4	Other	None	Water	Soil	Other	Sample Notes or		
0110008-ABD-A		10/4/18	0612					X	X	X	X	X	X	X			VV- Rooms A2-A3		
0110008-ABD-B		10/4/18	0619					X	X	X	X	X	X	X			VV- Music Room 30		
0110008-ABD-C		10/4/18	0635					X	X	X	X	X	X	X			VV- MPR		
0110008-ABD-D		10/4/18	0640					X	X	X	X	X	X	X			VV- Room 28		
0110008-ABD-E		10/4/18	0638					X	X	X	X	X	X	X			VV- Kids' Club Facility		
				Relinquished by		Received by								Date		Time			
				Susan Clough 		  								10/4/18		11:20			
														10-4-18		19:05			
														10-4-18		21:57			
																State System Number: 0110008		DDW Write On EDT Transmission? <input checked="" type="radio"/> Yes <input type="radio"/> No	
																If "Y" please enter the Source Number(s) in the column above		CA Geotracker EDF Report? <input type="radio"/> Yes <input type="radio"/> No	
																Global ID: _____		Sampling Company Log Code: _____	
																EDF to (Email Address): _____		Misc. Supplies: _____	
																Travel and Site Time: _____			