



Alpha

Alpha Analytical Laboratories, Inc.

email: clientservices@alpha-labs.com

Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

27 March 2019

Pleasanton, City of
Attn: Marque Debray
PO Box 520
Pleasanton, CA 94566
RE: Lead In Schools
Work Order: 19C1774

Enclosed are the results of analyses for samples received by the laboratory on 03/13/19 21:54. If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jeanette L. Poplin For Robbie C. Phillips
Project Manager



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Pleasanton, City of
PO Box 520
Pleasanton, CA 94566

Project Manager: Marque Debray
Project: Lead In Schools
Project Number: 0110008 / Amador High

Reported:
03/27/19 13:31

Bay Area: 262 Rickenbacker Circle | Livermore, CA 94551 | T: 925-828-6226 | F: 925-828-6309 | ELAP# 2728
Central Valley: 9090 Union Park Way Suite 113 | Elk Grove, CA 95624 | T: 916-686-5190 | F: 916-686-5192 | ELAP# 2922
North Bay: 110 Liberty Street | Petaluma, CA 94952 | T: 707-769-3128 | F: 707-769-8093 | ELAP# 2303
San Diego Service Center: 2722 Loker Avenue West Suite A | Carlsbad, CA 92010 | T: 760-930-2555 | F: 760-930-2510

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
D6 Faucet	19C1774-01	Water	03/13/19 07:08	03/13/19 21:54
D9 Faucet	19C1774-02	Water	03/13/19 07:37	03/13/19 21:54
Green Fountain BB #1	19C1774-03	Water	03/13/19 07:52	03/13/19 21:54
Green Fountain BB #2	19C1774-04	Water	03/13/19 07:54	03/13/19 21:54
Green Fountain BB #3	19C1774-05	Water	03/13/19 07:59	03/13/19 21:54
Concrete Fountain	19C1774-06	Water	03/13/19 06:38	03/13/19 21:54
Q115 (Hose Bib Outside)	19C1774-07	Water	03/13/19 06:18	03/13/19 21:54
Pool Sink	19C1774-08	Water	03/13/19 06:25	03/13/19 21:54
Pantry Sink	19C1774-09	Water	03/13/19 07:03	03/13/19 21:54

Case Narrative

The reporting limits for lead vary due to the dilutions required to bring results within the calibration range of the instrument.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
 Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Pleasanton, City of PO Box 520 Pleasanton, CA 94566	Project Manager: Marque Debray Project: Lead In Schools Project Number: 0110008 / Amador High	Reported: 03/27/19 13:31
---	---	-----------------------------

	Result	Reporting Limit	Dilution	Batch	Prepared	Analyzed	Method	Note
D6 Faucet (19C1774-01)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	9.8 ug/L	5.0	1	AC93971	03/18/19 10:20	03/20/19 17:49	EPA 200.8	
D9 Faucet (19C1774-02)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	840 ug/L	500	100	AC94023	03/20/19 05:50	03/26/19 08:56	EPA 200.8	C-04
Green Fountain BB #1 (19C1774-03)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	210 ug/L	5.0	50	AC94023	03/20/19 05:50	03/26/19 09:02	EPA 200.8	C-04
Green Fountain BB #2 (19C1774-04)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	280 ug/L	250	50	AC94023	03/20/19 05:50	03/26/19 09:09	EPA 200.8	C-04
Green Fountain BB #3 (19C1774-05)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	40 ug/L	5.0	1	AC93971	03/18/19 10:20	03/20/19 17:56	EPA 200.8	C-04
Concrete Fountain (19C1774-06)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	9.2 ug/L	5.0	1	AC93971	03/18/19 10:20	03/20/19 18:02	EPA 200.8	
Q115 (Hose Bib Outside) (19C1774-07)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	13 ug/L	5.0	1	AC93971	03/18/19 10:20	03/20/19 18:09	EPA 200.8	C-04
Pool Sink (19C1774-08)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	6.7 ug/L	5.0	1	AC93971	03/18/19 10:20	03/20/19 18:16	EPA 200.8	
Pantry Sink (19C1774-09)								
Metals by EPA Method 200.8 ICP/MS								P-02
Lead	1400 ug/L	500	100	AC94023	03/20/19 05:50	03/26/19 09:15	EPA 200.8	C-04

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



Alpha Analytical Laboratories, Inc. email: clientservices@alpha-labs.com
Corporate: 208 Mason Street | Ukiah, CA 95482 | T: 707-468-0401 | F: 707-468-5267 | ELAP# 1551

Pleasanton, City of
PO Box 520
Pleasanton, CA 94566

Project Manager: Marque Debray
Project: Lead In Schools
Project Number: 0110008 / Amador High

Reported:
03/27/19 13:31

Notes and Definitions

- C-04 Result confirmed by re-analysis
- P-02 Sample acidified to pH <2 and allowed to sit 24 hours before further processing.
- ND Analyte NOT DETECTED at or above the reporting limit
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference



Corporate Laboratory
208 Mason Street, Ukiah CA 95482
707-468-0401 F) 707-468-5267
email: clientservices@alpha-labs.com

Bay Area Laboratory
262 Rickenbacker Circle, Livermore CA 94551
925-828-6226 F) 925-828-6309

Central Valley Laboratory
9090 Union Park Way #113, Elk Grove CA 95624
916-686-5190 F) 916-686-5192

ELAP Certifications
Ukiah 1551, Livermore 2728, Elk Grove 2922

Chain of Custody - Work Order

Reports and Invoices delivered by email in PDF format

Lab No 19C1774 Pg of

Report to		Invoice to (if different)		Project Information		Analysis Request		Temp upon Receipt °C															
Company:	City of Pleasanton	Contact:		Project ID:	Amador High	Standard 10 days <input checked="" type="checkbox"/>	RUSH: 5 days <input type="checkbox"/> 48 hours <input type="checkbox"/> Other: <input type="checkbox"/> days <input type="checkbox"/>	Ukiah temp: <u>1.4 C</u>	Livermore temp:														
Attn:	Marque DeBray	Email address:		Project No:																			
Address:	3333 Busch Rd Pleasanton CA	Address:	PO Box 520	PO Number:																			
Phone/Fax:	925-519-0551	Phone/Fax:																					
Email Address:		m de bray @ city of pleasanton ca gov		Field Sampler - Printed Name & Signature:		Sample Source Numbers:		Elk Grove temp:															
Marque DeBray																							
Sample Identification	Sampling		40ml Vial	Poly	Glass	Sleeve	Other	Container			Preservative			Matrix	Total Number of Containers per Sample ID								
	Date	Time						HCl	HNO3	H2SO4	Other	None	Water			Soil	Other						
006 faucet	3-13-19	0708	X					X			X				1								
009 faucet	3-13-19	0757	X					X			X				1								
013 faucet	3-13-19	0758	X					X			X				1								
014 Green fountain BB #1	3-13-19	0758	X					X			X				1								
015 Green fountain BB #2	3-13-19	0754	X					X			X				1								
016 Green fountain BB #3	3-13-19	0759	X					X			X				1								
017 Concrete fountain	3-13-19	0638	X					X			X				1								
018 115 (hose bib outside)	3-13-19	0618	X					X			X				1								
019 Pool Sink	3-13-19	0615	X					X			X				1								
020 Pantry Sink	3-13-19	0703	X					X			X				1								
Relinquished by		Received by		Date		Time		DDW Write On EDT Transmission?		State System Number:		If "Y" please enter the Source Number(s) in the column above		CA Geotracker EDF Report?		Global ID:		EDF to (Email Address):		Travel and Site Time:		Misc. Supplies:	
Susan Clark		of		3/13/19		12:15		Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>						Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>									
of		PA		3-13-19		19:21																	
of		PA		3-13-19		21:51																	

Signature below authorizes work under terms stated on reverse side.