

**MOUNT OLIVE TOWNSHIP  
SCHOOL DISTRICT**

227 US Route 206, Suite 10  
Flanders, NJ 07836  
973.691.4000  
MOTSD.org  
@MOTSD

**BOARD OF EDUCATION**

Anthony Strillacci  
*President*

Christopher Zeier  
*Vice-President*

Jennifer Aquino

Lisa Fenton

Dr. Antoine Gayles

Dr. Anthony Giordano

Lisa Narcise

Elizabeth Ouimet

William Robinson

**ADMINISTRATION**

Dr. Robert R. Zywicki  
*Superintendent of Schools*

Dr. Sumit Bangia  
*Assistant Superintendent*

Gail Libby  
*Business Administrator*

Lynn Jones  
*Board Secretary*

June 21, 2022

Mount Olive Township Board of Education  
227 Route 206, Suite #10  
Flanders, NJ 07836

Dear Mount Olive Township Board of Education Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Mount Olive Township Board of Education tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Mount Olive Township Board of Education will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Testing Results

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Mount Olive Township Board of Education. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 204 samples taken, all but 14 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Mount Olive Township Board of Education has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
Chester M. Stephens – Water Fountain at B39	42.1	Water fountain has been taken out of service.
Mount Olive High School Sink in Nurses Exam Room	28.2	Sink has been labeled "Hand Washing Only"
Mount Olive High School Kitchen Food Prep Sink	20.7	Faucet is out of service and will be replaced summer 2022
Mount Olive High School Sink 2 Rm G126	22.0	Sink has been labeled "Hand Washing Only"
Sandshore Kitchen Sink (Back Room)	23.5	Faucet is out of service and will be replaced summer 2022
Sandshore Nurse Exam Room Sink	19.8	Sink has been labeled "Hand Washing Only"

Sandshore Water Fountain by Rm 184	51.3	Charcoal filter was changed on June 21, 2022
Sandshore Sink in Rm 180	20.1	Sink has been labeled "Hand Washing Only"
Sandshore sink in library	34.7	Sink has been labeled "Hand Washing Only"
Mount Olive Middle School Sink in Dish Wash Room	37.8	Faucet is out of service and will be replaced summer 2022
Mount Olive Middle School Sink in Service Area Right	45.4	Faucet is out of service and will be replaced summer 2022
Mount Olive Middle School Sink in E134	28.8	Sink has been labeled "Hand Washing Only"
Mount Olive Middle School Sink in F113	63.5	Sink has been labeled "Hand Washing Only"

#### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

#### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

#### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.


#### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.motsd.org](http://www.motsd.org). For more information about water quality in our schools, contact Glenn Miller, Director of Buildings and Grounds at the Board of Education Office, 973-691-4008, ext. 8505.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

A handwritten signature in black ink, appearing to read "Gail M. Libby". The signature is fluid and cursive, with a large initial "G" and "L".

Gail M. Libby  
Business Administrator  
Mount Olive Township Board of Education