



SCARBOROUGH FIRE DEPARTMENT
PLANNING DEPARTMENT
 PO BOX 360 SCARBOROUGH ME 04070-0360
 PHONE:207-730-4040 FAX 207-730-4046
 SUBMITTALS@SCARBOROUGHMAINE.ORG
 SCARBOROUGHMAINE.ORG

Application for Fire Suppression System Permit

State Fire Marshall Permit # _____

Project Name: _____ Date: _____
 Property Address: _____ Phone #: _____
 Property Owner: _____ Fax #: _____
 Email: _____

Type of System: 13 13D 13R Life Safety Hydra-pro
System Design: Wet Dry Pre-Action Deluge
System Monitoring: Water Flow Tamper Low Air

Number and Location of Zones: _____

INSTALLER

Name: _____ Phone #: _____
 Address: _____

MONITORING COMPANY

Name: _____ Phone #: _____
 Address: _____

EMERGENCY NOTIFICATION

Name: _____
 Address: _____
 Phone #: _____

TENANT INFORMATION

Name: _____
 Address: _____
 Phone #: _____

All sprinkler plans must be reviewed and approved by the State Fire Marshall prior to submission to the Scarborough Fire Department.

All sprinkler systems must meet or exceed the requirements of NFPA and the Scarborough Fire Department Sprinkler Ordinance, Chapter 305.

Sprinkler plans, including all applicable hydraulic calculations, must be submitted (10) ten days prior to scheduled meeting and should include 1 set of paper and 1 set digital.

Applicants Signature: _____ Date: _____

APPROVED BY:

Fire Official: _____ Date: _____

Calculate Permit Fee:

Quantity x Rate =

_____	x \$50.00 =	_____	Minimum Permit Fee
_____	x \$100.00 =	_____	Fire Pump Installations
_____	x \$100.00 =	_____	Fuel Canopy Installations
_____	x \$100.00 =	_____	Kitchen Suppression System Installations
_____	x \$.50 =	_____	Relocation of existing heads (per head)
_____	x \$1.00 =	_____	Each new sprinkler head

Total Amount Due= _____ Date Paid: _____ Check #: _____

Set of paper drawings Digital Copies

Map/Lot: _____

Permit #: _____



Town of Scarborough
· FIRE DEPARTMENT
275 US Route 1
Scarborough, Maine 04074
Tel: 207-883-4542
Fax: 207-730-4270

Rich C. Kindelan, Fire Chief/EMA Director
Kevin D. Duross, Deputy Fire Chief
Ian K. Tenney, Deputy Fire Chief
John S. Brennan, Deputy Fire Chief

Fire Department Connection (FDC) Signage


All Fire Department Connection (FDC) signs shall be clearly labeled, visible and are required on all outside connections on any new buildings within the Town of Scarborough.

FDC signs shall consist of the following:

- Signs shall be 12" by 18" used either vertically or horizontally
- Signs shall be red in color with white lettering
- Signs shall be constructed of a durable material to withstand weather elements
- Top line: 1" white lettering indicating the type of system. Examples include the following:
 - Auto Sprinkler
 - Dry Standpipe
 - Manual wet standpipe
 - Combination
- Center Line: 4" white letters reading "FDC" centered on the sign
- Bottom Line: 1" white lettering to indicate the following:
 - System demand in PSI
 - Riser number and area covered (if partial system)
 - Any additional information, as required by the Scarborough Fire Department

Placement of FDC Signs:

- Signs shall be permanently mounted 8' above the FDC
 - When not feasible, signs can be mounted in an alternate location as approved by the Scarborough Fire Department
 - FDC's not visible from the approach side (front) of the building may require additional signage (directional arrows). Arrow shall be white letters and the signage shall be red measuring 4" by 18".



Please Contact Deputy Chief John Brennan with any questions: jbrennan@scarboroughmaine.org