

Public Schools of Edison Township

312 Pierson Avenue * Edison, New Jersey 08837
Telephone (732) 452-4550 Fax (732) 452-4555

Bernard F. Bragen, Jr., Ed.D.
Superintendent of Schools

Ann Kluck
Assistant Business Administrator/
Board Secretary

June 27, 2022

Thomas Jefferson Middle School
450 Division Street
Edison, NJ 08817

Dear Thomas Jefferson Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Edison Township Public School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Thomas Jefferson Middle School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 $\mu\text{g/l}$ (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. Accordingly, all sources found to contain action levels were immediately taken out of service.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Edison Township Public School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the twenty-nine samples taken, all but one tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 $\mu\text{g/l}$ [ppb]).

The table below identifies the drinking water outlets that tested above the 15 $\mu\text{g/l}$ for lead, the actual lead level, and what temporary remedial action Edison Township Public School District has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in $\mu\text{g/l}$ (ppb)	LCR Action Level (1) (ppb)	Remedial Action
Water fountain – Faculty bathroom, Outlet # 17, Sample # 14-17 FD	26.1	15.0	The fixtures were taken out of service and new plumbing materials were ordered to alleviate the above threshold readings. The fixtures will remain out of service until future testing provides results below action level.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes, and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.


For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at www.edison.k12.nj.us. For more information about water quality in our schools, contact William Kolibas, Director of Buildings & Grounds at (732) 452-4550.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

A handwritten signature in blue ink that reads "Bernard F. Bragen Jr." The signature is fluid and cursive, with the first and last names being more prominent.

Bernard F. Bragen, Jr., Ed.D.
Superintendent of Schools



William Kolibas
Public Schools of Edison Township
312 Pierson Avenue
Edison, NJ 08837

12/21/2021

RE: [Thomas Jefferson Middle - 450 Division Street] – Lead in Water Summary Table
{Omega Project #: 21-1275-14}

Samples collected on 12/3/2021.

RESULTS TABLE SUMMARY:

Sample #	Outlet #/Location	1 st Draw (FD) Or Flush (FL)	Lead	
			Results (ppb)	LCR Action Level ⁽¹⁾ (ppb)
14-01 FD	54/Teacher Room Sink Main Office	FD	1.30	15
14-02 FD	65/Teacher Room Sink Lounge	FD	1.04	15
14-03 FD	64/Water Fountain By 211	FD	1.14	15
14-04 FD	63/Water Fountain By 206	FD	ND	15
14-05 FD	60/Water Fountain by Main Entrance	FD	1.73	15
14-06 FD	68/Water Fountain by Library	FD	ND	15
14-07 FD	73/Nurse's Office Sink	FD	1.65	15
14-08 FD	77/Water Fountain by Room 221	FD	1.31	15
14-09 FD	95/Water Fountain Outside Gym – NOT OPERATIONAL	FD	NS	15
14-10 FD	86/Kitchen Sink Near Door (R)	FD	4.54	15
14-11 FD	85/Kitchen Sink Near Door (L) – NOT OPERATIONAL	FD	NS	15
14-12 FD	88/Kitchen Sink Back Left Corner (R)	FD	2.51	15
14-13 FD	87/Kitchen Sink Back Left Corner (L)	FD	ND	15
14-14 FD	86A/Kitchen Sink Snack Line	FD	ND	15
14-15 FD	82A/Water Fountain Cafeteria – NOT LOCATED	FD	NS	15
14-16 FD	82/Water Fountain Outside Cafeteria	FD	2.03	15
14-17 FD	17/Water Fountain Next to Women Faculty Bathroom	FD	26.1	15
14-18 FD	13/Water Fountain by Room 105	FD	2.04	15
14-19 FD	46/Water Fountain Across 125	FD	2.34	15
14-20 FD	42/Water Fountain By 114	FD	ND	15
14-21 FD	37/Room 116 Sink by Door	FD	5.91	15
14-22 FD	38/Room 116 Sink Back Left	FD	4.81	15
14-23 FD	39/Room 116 Sink Back Center	FD	11.4	15
14-24 FD	40/Room 116 Sink Back Right	FD	11.2	15
14-25 FD	41/Room 116 Sink on Right Side	FD	8.74	15
14-26 FD	36A/Water Fountain By 115	FD	1.01	15
14-27 FD	26A/Water Fountain Outside Custodian Room– NOT LOCATED	FD	NS	15
14-28 FD	Water Fountain by Storage Room	FD	ND	15

14-29 BL	Field Blank	Blank	ND	NA
----------	-------------	-------	----	----

The outlets above 15 ppb should be taken out of service until further evaluation is conducted (repeat first draw, collect flush sample, further evaluation of related plumbing).

⁽¹⁾ EPA Lead in Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

NS – Not Sampled

NA – Not Analyzed

David Ekstrand



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Lab

12/20/2021

**Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606**

Phone: (201) 489-8700

Fax: (201) 489-8797

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/8/2021. The results are tabulated on the attached data pages for the following client designated project:

Edison BOE/ Jefferson / 21-1275-14

The reference number for these samples is EMSL Order #012114102. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012114102

CustomerID: OMEG50

CustomerPO: 21-1275-14

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
Fax: (201) 489-8797
Received: 12/8/2021 09:00 AM

Project: Edison BOE/ Jefferson / 21-1275-14

Analytical Results

Client Sample Description 14-01 FD
Teacher Room Sink Main Office
Collected: 12/3/2021 7:16:00 AM
Lab ID: 012114102-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.30	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:23

Client Sample Description 14-02 FD
Teacher Room Sink Lounge
Collected: 12/3/2021 7:24:00 AM
Lab ID: 012114102-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.04	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:27

Client Sample Description 14-03 FD
Water Fountain by 211
Collected: 12/3/2021 7:22:00 AM
Lab ID: 012114102-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.14	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:29

Client Sample Description 14-04 FD
Water Fountain by 206
Collected: 12/3/2021 7:20:00 AM
Lab ID: 012114102-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:30

Client Sample Description 14-05 FD
Water Fountain by Main Entrance
Collected: 12/3/2021 7:15:00 AM
Lab ID: 012114102-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.73	1.00 µg/L	12/13/2021 IC	12/14/2021 JW 15:57

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012114102
 CustomerID: OMEG50
 CustomerPO: 21-1275-14
 ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 12/8/2021 09:00 AM

Project: Edison BOE/ Jefferson / 21-1275-14

Analytical Results

Client Sample Description		14-06 FD Water Fountain by Library	Collected:		12/3/2021 7:29:00 AM	Lab ID:		012114102-0006	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead	ND	1.00 µg/L		12/8/2021	KB	12/8/2021 23:32	KB	
Client Sample Description		14-07 FD Nurse's Office Sink	Collected:		12/3/2021 7:46:00 AM	Lab ID:		012114102-0007	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead	1.65	1.00 µg/L		12/8/2021	KB	12/8/2021 23:33	KB	
Client Sample Description		14-08 FD Water Fountain by Room 221	Collected:		12/3/2021 7:27:00 AM	Lab ID:		012114102-0008	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead	1.31	1.00 µg/L		12/8/2021	KB	12/8/2021 23:34	KB	
Client Sample Description		14-10 FD Kitchen Sink Near Door ®	Collected:		12/3/2021 6:47:00 AM	Lab ID:		012114102-0009	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead	4.54	1.00 µg/L		12/8/2021	KB	12/8/2021 23:36	KB	
Client Sample Description		14-12 FD Kitchen Sink Back Left Corner ®	Collected:		12/3/2021 6:48:00 AM	Lab ID:		012114102-0010	
Method	Parameter		Result	RL Units		Prep Date & Analyst		Analysis Date & Analyst	
METALS									
200.8	Lead	2.51	1.00 µg/L		12/8/2021	KB	12/8/2021 23:43	KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012114102

CustomerID: OMEG50

CustomerPO: 21-1275-14

ProjectID:

Attn: **Lab****Omega Environmental Services**
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700

Fax: (201) 489-8797

Received: 12/8/2021 09:00 AM

Project: **Edison BOE/ Jefferson / 21-1275-14****Analytical Results**

Client Sample Description	14-13 FD Kitchen Sink Back Left Corner (L)	Collected:	12/3/2021 6:49:00 AM	Lab ID:	012114102-0011
----------------------------------	---	-------------------	-------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:45

Client Sample Description	14-14 FD Kitchen Sink Snack Line	Collected:	12/3/2021 7:02:00 AM	Lab ID:	012114102-0012
----------------------------------	-------------------------------------	-------------------	-------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:46

Client Sample Description	14-16 FD Water Fountain Outside Cafeteria	Collected:	12/3/2021 7:08:00 AM	Lab ID:	012114102-0013
----------------------------------	--	-------------------	-------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.03	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:51

Client Sample Description	14-17 FD Water Fountain Next to Women Faculty Bathroom	Collected:	12/3/2021 7:54:00 AM	Lab ID:	012114102-0014
----------------------------------	---	-------------------	-------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	26.1	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:52

Client Sample Description	14-18 FD Water Fountain by Room 105	Collected:	12/3/2021 7:55:00 AM	Lab ID:	012114102-0015
----------------------------------	--	-------------------	-------------------------	----------------	----------------

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.04	1.00 µg/L	12/8/2021 KB	12/8/2021 KB 23:54

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012114102
 CustomerID: OMEG50
 CustomerPO: 21-1275-14
 ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 12/8/2021 09:00 AM

Project: Edison BOE/ Jefferson / 21-1275-14

Analytical Results

Client Sample Description		14-19 FD Water Fountain Across 125	Collected: 12/3/2021 7:49:00 AM		Lab ID: 012114102-0016		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	2.34	1.00 µg/L	12/8/2021	KB	12/8/2021 23:58	KB
Client Sample Description		14-20 FD Water Fountain by 114	Collected: 12/3/2021 7:32:00 AM		Lab ID: 012114102-0017		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	ND	1.00 µg/L	12/8/2021	KB	12/8/2021 23:59	KB
Client Sample Description		14-21 FD Room 116 Sink by Door	Collected: 12/3/2021 7:37:00 AM		Lab ID: 012114102-0018		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	5.91	1.00 µg/L	12/8/2021	KB	12/9/2021 00:01	KB
Client Sample Description		14-22 FD Room 116 Sink Back Left	Collected: 12/3/2021 7:38:00 AM		Lab ID: 012114102-0019		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	4.81	1.00 µg/L	12/8/2021	KB	12/9/2021 00:02	KB
Client Sample Description		14-23 FD Room 116 Sink Back Center	Collected: 12/3/2021 7:39:00 AM		Lab ID: 012114102-0020		
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	11.4	1.00 µg/L	12/8/2021	KB	12/9/2021 00:04	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012114102
 CustomerID: OMEG50
 CustomerPO: 21-1275-14
 ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 12/8/2021 09:00 AM

Project: Edison BOE/ Jefferson / 21-1275-14

Analytical Results

Client Sample Description		14-24 FD Room 116 Sink Back Right	Collected:	12/3/2021 7:40:00 AM	Lab ID:	012114102-0021	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	11.2	1.00 µg/L	12/8/2021	KB	12/9/2021 00:05	KB

Client Sample Description		14-25 FD	Collected:	12/3/2021	Lab ID:	012114102-0022	
		Room 116 Sink Back on Right Side		7:41:00 AM			
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst	
METALS							
200.8	Lead	8.74	1.00 µg/L	12/8/2021	KB	12/8/2021 23:10	KB

Client Sample Description		14-26 FD	Collected:	12/3/2021	Lab ID:	012114102-0023	
		Water Fountain by 115		7:35:00 AM			
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	1.01	1.00 µg/L	12/8/2021 KB	12/8/2021 23:11	KB	

Client Sample Description		14-28 FD	Collected:	12/3/2021	Lab ID:	012114102-0024	
		Water Fountain by Storage Rm		7:59:00 AM			
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	12/8/2021 KB	12/8/2021 23:12		KB

Client Sample Description		14-29	Collected:		12/3/2021	Lab ID:		012114102-0025	
		Blank							
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst			
METALS									
200.8	Lead	ND	1.00 µg/L	12/8/2021	KB	12/8/2021	KB	23:14	



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012114102
CustomerID:	OMEG50
CustomerPO:	21-1275-14
ProjectID:	

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results



EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

012114102

Customer Information		Billing Information	
Customer ID:		Billing ID:	
Company Name: Omega Environmental		Company Name: Omega Environmental	
Contact Name:		Billing Contact:	
Street Address: 280 Huyler Street		Street Address: 280 Huyler Street	
City, State, Zip: S. Hackensack, NJ 07806	Country: USA	City, State, Zip: S. Hackensack, NJ 07806	Country: USA
Phone: 201-489-8700		Phone: 201-489-8700	
Email(s) for Report: Lab@omega-env.com		Email(s) for Invoice: ap@omega-env.com	

Project Information			
Project Name/No: Edison BOE/ Jefferson / 21-1275-14		Purchase Order:	
EMSL LIMS Project ID:		US State where samples collected: NJ	State of Connecticut (CT) must select project location:
(If applicable, EMSL will provide)		Commercial (Taxable)	Residential (Non-Taxable)
Sampled By Name: Kari-Dean Scarlett	Sampled By Signature: [Signature]	No. of Samples in Shipment: 25	

Turn-Around-Time (TAT)							
☐ 3 Hour	☐ 6 Hour	☐ 24 Hour	☐ 32 Hour	☐ 48 Hour	☐ 72 Hour	☐ 96 Hour	☒ 1 Week
☒ 2 Week							

MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/m ³	SW 846-7000B	Flame Atomic Absorption	0.000% (80ppm)	☐
Reporting Limit based on a minimum 0.25g sample weight	SW 846-6010D	ICP-OES	0.0004% (4ppm)	☐
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	☐
	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	☐
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	☐
	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-6010D*	ICP-OES	1.0µg/wipe	☐
*If no box is checked, non-ASTM Wipe is assumed	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
TCLP	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
SPLP	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
TTLC	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	☐
	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
STLC	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
Soil	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	☐
	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
Wastewater	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	☐
Unpreserved	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Preserved with HNO ₃	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☒
Drinking Water	40 CFR Part 50	ICP-OES	12 µg/filter	☐
Unpreserved				☐
Preserved with HNO ₃				☐
TSP/SPM Filter				☐
Other:				☐

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
Samples begin on the following page			

Method of Shipment: Pick up		Sample Condition Upon Receipt:	
Relinquished by: [Signature]	Date/Time: 12-3-21 9AM	Received by: [Signature]	Date/Time: 12/7/21 8:00
Relinquished by: [Signature]	Date/Time: 12-3-21 9AM	Received by: [Signature]	Date/Time: 12/18/21 9:00

Controlled Document - COC-25 (Lead 816-416352)

*8010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance. Page 1 of 3

25 EL



EMSL ANALYTICAL, INC.
TESTING LABORATORY
TESTING LABS • PRODUCTS • TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Jefferson 21-1275-14

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Outlet #	Sample Location	Volume / Area	Date / Time Sampled	Notes
14-01 FD	54	Teacher Room Sink Main Office	250 mL	12/3/04 7:10	
14-02 FD	65	Teacher Room Sink Lounge		7:20	
14-03 FD	64	Water Fountain by 211		7:20	
14-04 FD	63	Water Fountain by 206		7:20	
14-05 FD	60	Water Fountain by Main Entrance		7:15	
14-06 FD	68	Water Fountain by Library		7:29	
14-07 FD	73	Nurse's Office Sink		7:46	
14-08 FD	77	Water Fountain by Room 221		7:27	Not working
14-09 FD	95	Water Fountain Outside Gym			
14-10 FD	86	Kitchen Sink Near Door (R)		12/3/04 6:47	
14-11 FD	85	Kitchen Sink Near Door (L)			Not working
14-12 FD	88	Kitchen Sink Back Left Corner (R)		6:48	
14-13 FD	87	Kitchen Sink Back Left Corner (L)		6:49	
14-14 FD	86A	Kitchen Sink Snack line		7:00	Not found
14-15 FD	82A	Water Fountain Cafeteria			
14-16 FD	82	Water Fountain Outside Cafeteria		7:08	
14-17 FD	17	Water Fountain Next to Women Faculty Bathroom		7:54	
14-18 FD	13	Water Fountain by Room 105		7:55	
End of Shipment			Sample Condition Upon Receipt		
Inquired by:	D. Carole		Date/Time:	12-3-04 9 AM	Date/Time:
Inquired by:			Date/Time:		Date/Time:

Order ID: 012114102



Lead Chain of Custody
EIMS Order Number / Lab Use Only

PHONE: (800) 220-3675
EMAIL: CinnaminsonLeadLab@CinnaminsonLeadLab.com

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

[illegible]

orderID: 012114102