



# Public Schools of Edison Township

312 Pierson Avenue \* Edison, New Jersey 08837  
Telephone (732) 452-4550 Fax (732) 452-4555

**Bernard F. Bragen, Jr., Ed.D.**  
Superintendent of Schools

**Ann Kluck**  
Assistant Business Administrator/  
Board Secretary

June 27, 2022

John Adams Middle School  
1081 New Dover Rd.  
Edison, NJ 08820

Dear John Adams Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Edison Township Public School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, John Adams Middle School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. Accordingly, all sources found to contain action levels were immediately taken out of service.

## Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Edison Township Public School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the twenty-six samples taken, all but one tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Edison Township Public School District has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	LCR Action Level (1) (ppb)	Remedial Action
Room 108 sink (in front of the oven), Outlet # 41, Sample # 13-21 FD	148	15.0	The fixtures were taken out of service and new plumbing materials were ordered to alleviate the above threshold readings. The fixtures will remain out of service until future testing provides results below action level.

**Nothing Less Than Excellence**

## Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

## Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.


## For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.edison.k12.nj.us](http://www.edison.k12.nj.us). For more information about water quality in our schools, contact William Kolibas, Director of Buildings & Grounds at (732) 452-4550.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,



Bernard F. Bragen, Jr., Ed.D.  
Superintendent of Schools



William Kolibas  
Public Schools of Edison Township  
312 Pierson Avenue  
Edison, NJ 08837

12/21/2021

**RE: [John Adams Middle - 1081 New Dover Road] – Lead in Water Summary Table {Omega Project #: 21-1275-13}**

Samples collected on 12/2/2021.

**RESULTS TABLE SUMMARY:**

Sample #	Outlet #/Location	1 <sup>st</sup> Draw (FD) Or Flush (FL)	Lead	
			Results (ppb)	LCR Action Level <sup>(1)</sup> (ppb)
13-01 FD	03/Kitchen Sink Near Oven (R) – May have been used prior to sampling	FD	1.34	15
13-02 FD	02/Kitchen Sink Near Dishwasher	FD	ND	15
13-03 FD	04/Kitchen Sink Near Lockers (R)	FD	ND	15
13-04 FD	01A/Water Fountain Next to Custodial Closet (R) – OUT OF SERVICE	FD	NS	15
13-05 FD	21/Nurse's Office Sink	FD	3.25	15
13-06 FD	26/Water Fountain Near 106 (R) – OUT OF SERVICE	FD	NS	15
13-07 FD	26/Water Fountain Near 106 (L) – OUT OF SERVICE	FD	NS	15
13-08 FD	70/Water Fountain Across 137 (R) – OUT OF SERVICE	FD	NS	15
13-09 FD	70/Water Fountain Across 137 (L) – OUT OF SERVICE	FD	NS	15
13-10 FD	59/Water Fountain Across Faculty Room (R) – OUT OF SERVICE	FD	NS	15
13-11 FD	50/Faculty Room Sink	FD	3.30	15
13-12 FD	13/Water Fountain Boy's Locker Room-- OUT OF SERVICE	FD	NS	15
13-13 FD	08/Water Fountain Girl's Locker Room-- OUT OF SERVICE	FD	NS	15
13-14 FD	60/Water Fountain Across 210 (R) – OUT OF SERVICE	FD	NS	15
13-15 FD	67/Water Fountain Across 203 (L) – OUT OF SERVICE	FD	NS	15
13-16 FD	36/Room 108 Sink (Closest to Door)	FD	4.54	15
13-17 FD	40/Room 108 Sink (Back Left)	FD	2.89	15
13-18 FD	39/Room 108 Sink (Back Center)	FD	3.37	15
13-19 FD	38/Room 108 Sink (Back Right)	FD	2.79	15
13-20 FD	37/Room 108 Sink (On Right Side of Room)	FD	3.32	15
13-21 FD	41/Room 108 Sink (In Front of The Oven)	FD	148	15
13-22 FD	01B/Sink by Main Custodial Closet	FD	9.02	15
13-23 FD	Kitchen Sink Near Oven (L)	FD	1.38	15
13-24 FD	Kitchen Sink Near Lockers (L)	FD	ND	15
13-25 FD	Main Office Sink	FD	7.35	15
13-26 BL	Field Blank	Blank	ND	NA

The outlets above 15 ppb should be taken out of service until further evaluation is conducted (repeat first draw, collect flush sample, further evaluation of related plumbing).

<sup>(1)</sup> EPA Lead in Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

NS – Not Sampled

NA – Not Analyzed

David Ekstrand



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Lab**

12/20/2021

**Omega Environmental Services**

**280 Huyler Street**

**South Hackensack, NJ 07606**

Phone: (201) 489-8700

Fax: (201) 489-8797

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/8/2021. The results are tabulated on the attached data pages for the following client designated project:

**Edison BOE/ Adams / 21-1275-13**

The reference number for these samples is EMSL Order #012114200. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry  
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012114200  
CustomerID: OMEG50  
CustomerPO: 21-1275-13  
ProjectID:

Attn: **Lab**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

Phone: (201) 489-8700  
Fax: (201) 489-8797  
Received: 12/8/2021 09:00 AM

Project: Edison BOE/ Adams / 21-1275-13

**Analytical Results**

**Client Sample Description** 13-01 FD  
Kitchen Sink Near Oven ®

**Collected:** 12/2/2021 6:39:00 AM

**Lab ID:** 012114200-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.34	1.00 µg/L	12/13/2021 IC	12/14/2021 JW 16:59

**Client Sample Description** 13-02 FD  
Kitchen Sink Near Dishwasher

**Collected:** 12/2/2021 6:40:00 AM

**Lab ID:** 012114200-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 15:49

**Client Sample Description** 13-03 FD  
Kitchen Sink Near Lockers ®

**Collected:** 12/2/2021 6:41:00 AM

**Lab ID:** 012114200-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 15:54

**Client Sample Description** 13-05 FD  
Nurse's Office Sink

**Collected:** 12/2/2021 6:55:00 AM

**Lab ID:** 012114200-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.25	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 15:55

**Client Sample Description** 13-11 FD  
Faculty Room Sink

**Collected:** 12/2/2021 7:11:00 AM

**Lab ID:** 012114200-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	3.30	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 16:00

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012114200

CustomerID: OMEG50

CustomerPO: 21-1275-13

ProjectID:

Attn: **Lab**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

Phone: (201) 489-8700  
Fax: (201) 489-8797  
Received: 12/8/2021 09:00 AM

Project: Edlson BOE/ Adams / 21-1275-13

**Analytical Results**

Client Sample Description		13-16 FD Room 108 Sink (Closest to Door)		Collected:	12/2/2021 7:01:00 AM	Lab ID:	012114200-0006	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	4.54	1.00 µg/L	12/10/2021	KB	12/10/2021 16:01	KB	
Client Sample Description		13-17 FD Room 108 Sink (Back Left)		Collected:	12/2/2021 7:01:00 AM	Lab ID:	012114200-0007	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	2.89	1.00 µg/L	12/10/2021	KB	12/10/2021 16:03	KB	
Client Sample Description		13-18 FD Room 108 Sink (Back Center)		Collected:	12/2/2021 7:03:00 AM	Lab ID:	012114200-0008	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	3.37	1.00 µg/L	12/10/2021	KB	12/10/2021 16:04	KB	
Client Sample Description		13-19 FD Room 108 Sink (Back Right)		Collected:	12/2/2021 7:04:00 AM	Lab ID:	012114200-0009	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	2.79	1.00 µg/L	12/10/2021	KB	12/10/2021 16:05	KB	
Client Sample Description		13-20 FD Room 108 Sink (On Right Side of Room)		Collected:	12/2/2021 7:04:00 AM	Lab ID:	012114200-0010	
Method	Parameter	Result	RL Units	Prep Date & Analyst		Analysis Date & Analyst		
METALS								
200.8	Lead	3.32	1.00 µg/L	12/10/2021	KB	12/10/2021 16:07	KB	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012114200

CustomerID: OMEG50

CustomerPO: 21-1275-13

ProjectID:

Attn: **Lab**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

Phone: (201) 489-8700  
Fax: (201) 489-8797  
Received: 12/8/2021 09:00 AM

Project: Edison BOE/ Adams / 21-1275-13

**Analytical Results**

**Client Sample Description** 13-21 FD  
Room 108 Sink ((In Front of the Oven)

**Collected:** 12/2/2021 7:07:00 AM

**Lab ID:** 012114200-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	148 D	5.00 µg/L	12/13/2021 IC	12/14/2021 JW 18:17

**Client Sample Description** 13-22 FD  
Sink by Main Custodial Closet

**Collected:** 12/2/2021 7:20:00 AM

**Lab ID:** 012114200-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	9.02	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 16:08

**Client Sample Description** 13-23 FD  
Kitchen Sink Near Oven (L)

**Collected:** 12/2/2021 6:38:00 AM

**Lab ID:** 012114200-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	1.38	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 16:10

**Client Sample Description** 13-24 FD  
Kitchen Sink Near Lockers (L)

**Collected:** 12/2/2021 6:41:00 AM

**Lab ID:** 012114200-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 16:18

**Client Sample Description** 13-25 FD  
Sink in Main Office

**Collected:** 12/2/2021 7:10:00 AM

**Lab ID:** 012114200-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
<b>METALS</b>					
200.8	Lead	7.35	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 16:19



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 012114200

CustomerID: OMEG50

CustomerPO: 21-1275-13

ProjectID:

Attn: **Lab**  
**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

Phone: (201) 489-8700  
Fax: (201) 489-8797  
Received: 12/8/2021 09:00 AM

Project: Edison BOE/ Adams / 21-1275-13

**Analytical Results**

**Client Sample Description** 13-26  
Blank  
**Collected:** 12/2/2021  
**Lab ID:** 012114200-0016

<b>Method</b>	<b>Parameter</b>	<b>Result</b>	<b>RL Units</b>	<b>Prep Date &amp; Analyst</b>	<b>Analysis Date &amp; Analyst</b>
<b>METALS</b>					
200.8	Lead	ND	1.00 µg/L	12/10/2021 KB	12/10/2021 KB 16:21

**Definitions:**

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL ANALYTICAL, INC.  
TESTING LABS • PRODUCTS • TRAINING

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

012114200

Customer Information		Billing Information		
Customer ID:		Billing ID:		
Company Name: Omega Environmental		Company Name: Omega Environmental		
Contact Name:		Billing Contact:		
Street Address: 280 Huyler Street		Street Address: 280 Huyler Street		
City, State, Zip: S. Hackensack, NJ 07606		City, State, Zip: S. Hackensack, NJ 07606		
Country: USA		Country: USA		
Phone: 201-489-8700		Phone: 201-489-8700		
Email(s) for Report: Lab@omega-env.com		Email(s) for Invoice: ap@omega-env.com		
Project Information				
Project Name/No: Edison BOE/ Adams / 21-1275-13		Purchase Order:		
EMSL LIMS Project ID: (if applicable, EMSL will provide)		US State where samples collected: NJ		
Sampled By Name: Kerri-Dean Scatell		State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable) <input type="checkbox"/> Residential (Non-Taxable)		
Turn-Around-Time (TAT)		No. of Samples in Shipment: 16		
<input type="checkbox"/> 3 Hour <input type="checkbox"/> 6 Hour <input type="checkbox"/> 24 Hour <input type="checkbox"/> 32 Hour <input type="checkbox"/> 48 Hour <input type="checkbox"/> 72 Hour <input type="checkbox"/> 96 Hour <input checked="" type="checkbox"/> 1 Week <input checked="" type="checkbox"/> 2 Week				
Please call ahead for large projects and/or turnaround times 6 Hours or less. *32 Hour TAT available for select tests only, samples must be submitted by 11:30am.				
MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS <input type="checkbox"/> % by wt. <input type="checkbox"/> pure (mg/kg) <input type="checkbox"/> region	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input type="checkbox"/>
*Reporting Limit based on a minimum 0.25g sample weight	SW 846-8010D*	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	<input type="checkbox"/>
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	<input type="checkbox"/>
WIPE <input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
*If no box is checked, non-ASTM Wipe is assumed	SW 846-8010D*	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
Unpreserved <input type="checkbox"/> PH<2	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Preserved with HNO3	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
Drinking Water	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input type="checkbox"/>
Unpreserved <input checked="" type="checkbox"/> PH<2	40 CFR Part 60	ICP-OES	12 µg/filter	<input type="checkbox"/>
Preserved with HNO3				<input checked="" type="checkbox"/>
TSP/SPM Filter				<input type="checkbox"/>
Other:				<input type="checkbox"/>
Sample Number	Sample Location	Volume / Area	Date / Time Sampled	
Samples begin on the following page				
Method of Shipment: <b>Pickup</b>		Sample Condition Upon Receipt:		
Relinquished by: <b>K Scatell</b>	Date/Time: <b>12-2-21 8:30 AM</b>	Received by: <b>E. J. Coury</b>	Date/Time: <b>12/7/21 8:10 AM</b>	
Relinquished by:	Date/Time:	Received by: <b>E. J. Coury</b>	Date/Time: <b>12/8/21 9:00 AM</b>	

Controlled Document - CDC-25 Lead R18 4/09/2021

\*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.  
TESTING LABORATORY  
TESTING LAKE • PRODUCTS • TRAINING

## Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3575  
EMAIL: CinnaminsonLeadLab@emsl.com

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Adams 21-1275-13

Sample Number	Outlet #	Sample Location	Volume / Area	Date / Time Sampled	Notes
13-01 FD	03	Kitchen Sink near oven (R)	250mL	12-2-21 6:39	used before test
13-02 FD	02	Kitchen Sink near dishwasher		6:40	
13-03 FD	04	Kitchen Sink near lockers (R)		6:41	
13-04 FD	01A	Water Fountain next to custodial closet (R)			Not Sampled
13-05 FD	21	Nurse's Office Sink		6:55	
13-06 FD	26	Water Fountain near 106 (R)			Not Sampled
13-07 FD	26	Water Fountain near 106 (L)			Not Sampled
13-08 FD	70	Water Fountain across 137 (R)			Not Sampled
13-09 FD	70	Water Fountain across 137 (L)			Not Sampled
13-10 FD	59	Water Fountain across Faculty Room (R)			Not Sampled
13-11 FD	50	Faculty Room Sink		7:11	
13-12 FD	13	Water Fountain Boy's Locker Room			Not Sampled
13-13 FD	08	Water Fountain Girl's Locker Room			Not Sampled
13-14 FD	60	Water Fountain across 210 (R)			Not Sampled
13-15 FD	67	Water Fountain across 203 (L)			Not Sampled
13-16 FD	36	Room 108 Sink (closest to door)		7:07	
13-17 FD	40	Room 108 Sink (back left)		7:07	
13-18 FD	39	Room 108 Sink (back center)		7:03	

Sample Condition Upon Receipt

Date/Time

Received by:

12-2-21 8:30

Date/Time

Received by:

Date/Time

Method of Shipment: Pick up

Requested by: [Signature]

Requested by:

Date/Time

Date/Time

Order ID: 012114200



## Lead Chain of Custody

**EMSL Order Number / Lab Use Only**

EMSL Analytical, Inc.  
200 Route 130 North  
Cinnaminson, NJ 08077

PHONE: (800) 220-3675

**EMSL ANALYTICAL, INC.**

Chaminisond@aol.com

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Adams 21-1275-13

[illegible]

OrderID: 012114200