



Public Schools of Edison Township

312 Pierson Avenue * Edison, New Jersey 08837
Telephone (732) 452-4550 Fax (732) 452-4555

Bernard F. Bragen, Jr., Ed.D.
Superintendent of Schools

Ann Kluck
Assistant Business Administrator/
Board Secretary

June 27, 2022

Lindeneau Elementary School
50 Blossom St.
Edison, NJ 08817

Dear Lindeneau School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Edison Township Public School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Lindeneau Elementary School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 $\mu\text{g/l}$ (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. Accordingly, all sources found to contain action levels were immediately taken out of service.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Edison Township Public School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the twenty-four samples taken, all but three tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 $\mu\text{g/l}$ [ppb]).

The table below identifies the drinking water outlets that tested above the 15 $\mu\text{g/l}$ for lead, the actual lead level, and what temporary remedial action Edison Township Public School District has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in $\mu\text{g/l}$ (ppb)	LCR Action Level (1) (ppb)	Remedial Action
Water fountain by room 19 (R), Sample # 8-02 FD	33.8	15.0	The fixtures were taken out of service and new plumbing materials were ordered to alleviate the above threshold readings. The fixtures will remain out of service until future testing provides results below action level.
Water fountain, Room 23, Sample # 8-12 FD	36.2	15.0	

Nothing Less Than Excellence

Sample Location	First Draw Result in $\mu\text{g/l}$ (ppb)	LCR Action Level (1) (ppb)	Remedial Action
Water fountain, Room 25, Sample # 8-13 FD	41.3	15.0	The fixtures were taken out of service and new plumbing materials were ordered to alleviate the above threshold readings. The fixtures will remain out of service until future testing provides results below action level.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes, and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at www.edison.k12.nj.us. For more information about water quality in our schools, contact William Kolibas, Director of Buildings & Grounds at (732) 452-4550.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,


Bernard F. Bragen, Jr., Ed.D.
Superintendent of Schools



William Kolibas
Public Schools of Edison Township
312 Pierson Avenue
Edison, NJ 08837

12/14/2021

RE: [Lindeneau Elementary - 50 Blossom Street] – Lead in Water Summary Table
{Omega Project #: 21-1275-8}

Sampled collected on 11/24/2021.

RESULTS TABLE SUMMARY:

Sample #	Location	1 st Draw (FD) Or Flush (FL)	Lead	
			Results (Ppb)	LCR Action Level ⁽¹⁾ (Ppb)
8-01FD	Kitchen Sink	FD	ND	15
8-02 FD	Water Fountain by Room 19 (R)	FD	33.8	15
8-03 FD	Water Fountain by Room 19 (L)	FD	2.95	15
8-04 FD	Water Fountain Across MPR 3	FD	ND	15
8-05 FD	Nurse's Office Sink	FD	3.63	15
8-06 FD	Faculty Room Sink	FD	1.21	15
8-07 FD	Main Office Sink	FD	4.67	15
8-08 FD	Water Fountain Near Room 26 (R)	FD	ND	15
8-09 FD	Water Fountain Near Room 26 (L)	FD	ND	15
8-10 FD	Room 24A Water Fountain	FD	8.55	15
8-11 FD	Room 24B Water Fountain	FD	4.99	15
8-12 FD	Water Fountain Room 23	FD	36.2	15
8-13FD	Water Fountain Room 25	FD	41.3	15
8-14 FD	Water Fountain Room 22	FD	3.52	15
8-15 FD	Water Fountain Room 26	FD	6.49	15
8-16 FD	Water Fountain Room 21B	FD	7.59	15
8-17 FD	Water Fountain Room 21A	FD	1.77	15
8-18 FD	Water Fountain Near Room 9 (R)	FD	ND	15
8-19 FD	Water Fountain Near Room 9 (L)	FD	ND	15
8-20 FD	Water Fountain Next to Room 4 (R)	FD	4.11	15
8-21 FD	Water Fountain Next to Room 4 (L)	FD	1.60	15
8-22FD	Water Fountain next to MPR 1 (R)	FD	11.7	15
8-23FD	Water Fountain next to MPR 1 (L)	FD	10.3	15
8-24	Field Blank	Blank	ND	15

The outlets above 15.5 ppb should be taken out of service until further evaluation is conducted (repeat first draw, collect flush sample, further evaluation of related plumbing).

⁽¹⁾ EPA Lead in Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

NA – Not Analyzed



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 856-4571 Email: EnvChemistry2@emsl.com

Attn:

Lab

12/8/2021

Omega Environmental Services

280 Huyler Street

South Hackensack, NJ 07606

Phone: (201) 489-8700

Fax: (201) 489-8797

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 12/1/2021. The results are tabulated on the attached data pages for the following client designated project:

Edison BOE/ Lindeneau/ 21-1275-8

The reference number for these samples is EMSL Order #012113727. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113727

CustomerID: OMEG50

CustomerPO: 21-1275-8

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 12/1/2021 09:00 AM

Project: Edison BOE/ Lindeneau/ 21-1275-8

Analytical Results

Client Sample Description 8-01 FD
 Kitchen Sink
Collected: 11/24/2021
 6:41:00 AM
Lab ID: 012113727-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:26

Client Sample Description 8-02 FD
 Water Fountain by Room 19 (R)
Collected: 11/24/2021
 6:45:00 AM
Lab ID: 012113727-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	33.8	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:30

Client Sample Description 8-03 FD
 Water Fountain by Room 19 (L)
Collected: 11/24/2021
 6:46:00 AM
Lab ID: 012113727-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.95	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:32

Client Sample Description 8-04 FD
 Water Fountain across MPR 3
Collected: 11/24/2021
 6:58:00 AM
Lab ID: 012113727-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:33

Client Sample Description 8-05 FD
 Nurse's Office Sink
Collected: 11/24/2021
 7:10:00 AM
Lab ID: 012113727-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.63	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:35

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113727

CustomerID: OMEG50

CustomerPO: 21-1275-8

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 12/1/2021 09:00 AM

Project: Edlson BOE/ Lindeneau/ 21-1275-8

Analytical Results

Client Sample Description 8-06 FD
 Faculty Room Sink
Collected: 11/24/2021
 7:12:00 AM
Lab ID: 012113727-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.21	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:39

Client Sample Description 8-07 FD
 Main Office Sink
Collected: 11/24/2021
 7:37:00 AM
Lab ID: 012113727-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.67	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:41

Client Sample Description 8-08 FD
 Water Fountain near Room 26 (R)
Collected: 11/24/2021
 7:14:00 AM
Lab ID: 012113727-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:42

Client Sample Description 8-09 FD
 Water Fountain near Room 26 (L)
Collected: 11/24/2021
 7:15:00 AM
Lab ID: 012113727-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:44

Client Sample Description 8-10 FD
 Room 24A Water Fountain
Collected: 11/24/2021
 7:28:00 AM
Lab ID: 012113727-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	8.55	1.00 µg/L	12/2/2021 IC	12/3/2021 JW 13:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113727

CustomerID: OMEG50

CustomerPO: 21-1275-8

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 12/1/2021 09:00 AM

Project: Edison BOE/ Lindeneau/ 21-1275-8

Analytical Results

Client Sample Description 8-11 FD
 Room 24B Water Fountain
Collected: 11/24/2021
 7:31:00 AM
Lab ID: 012113727-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.99	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:45

Client Sample Description 8-12 FD
 Water Fountain Room 23
Collected: 11/24/2021
 7:32:00 AM
Lab ID: 012113727-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	36.2	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:47

Client Sample Description 8-13 FD
 Water Fountain Room 25
Collected: 11/24/2021
 7:26:00 AM
Lab ID: 012113727-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	41.3	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:51

Client Sample Description 8-14 FD
 Water Fountain Room 22
Collected: 11/24/2021
 7:23:00 AM
Lab ID: 012113727-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.52	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:52

Client Sample Description 8-15 FD
 Water Fountain Room 26
Collected: 11/24/2021
 7:19:00 AM
Lab ID: 012113727-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.49	1.00 µg/L	12/2/2021 IC	12/3/2021 JW 13:28

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113727

CustomerID: OMEG50

CustomerPO: 21-1275-8

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 12/1/2021 09:00 AM

Project: Edison BOE/ Lindeneau/ 21-1275-8

Analytical Results

Client Sample Description 8-16 FD **Collected:** 11/24/2021 **Lab ID:** 012113727-0016
 Water Fountain Room 21B 7:20:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.59	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:57

Client Sample Description 8-17 FD **Collected:** 11/24/2021 **Lab ID:** 012113727-0017
 Water Fountain Room 21A 7:21:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.77	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 18:58

Client Sample Description 8-18 FD **Collected:** 11/24/2021 **Lab ID:** 012113727-0018
 Water Fountain near Room 9 (R) 7:04:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 19:00

Client Sample Description 8-19 FD **Collected:** 11/24/2021 **Lab ID:** 012113727-0019
 Water Fountain near Room 9 (L) 7:05:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 19:01

Client Sample Description 8-20 FD **Collected:** 11/24/2021 **Lab ID:** 012113727-0020
 Water Fountain next to Room 4 (R) 7:01:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.11	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 19:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012113727

CustomerID: OMEG50

CustomerPO: 21-1275-8

ProjectID:

Attn: **Lab**
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

Phone: (201) 489-8700
 Fax: (201) 489-8797
 Received: 12/1/2021 09:00 AM

Project: Edison BOE/ Lindeneau/ 21-1275-8

Analytical Results

Client Sample Description 8-21 FD **Collected:** 11/24/2021 **Lab ID:** 012113727-0021
 Water Fountain next to Room 4 (L) 7:02:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.60	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 19:04

Client Sample Description 8-22 FD **Collected:** 11/24/2021 **Lab ID:** 012113727-0022
 Water Fountain Next MPR 1 (R) 6:53:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	11.7	1.00 µg/L	12/6/2021 KB	12/6/2021 KB 19:06

Client Sample Description 8-23 FD **Collected:** 11/24/2021 **Lab ID:** 012113727-0023
 Water Fountain Next MPR 1 (L) 6:54:00 AM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	10.3	1.00 µg/L	12/2/2021 KB	12/3/2021 KB 06:31

Client Sample Description 8-24 **Collected:** 11/24/2021 **Lab ID:** 012113727-0024
 Blank

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	12/2/2021 KB	12/3/2021 KB 06:33

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results

EMSL Order Number / Lab Use Only

PHONE: (800) 220-3675

EMAIL: ClanumisonLeadLab@ornl.com

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

012113727

Customer Information	Customer ID:			Billing Information	Billing ID:		
	Company Name: Omega Environmental				Company Name: Omega Environmental		
	Contact Name:				Billing Contact:		
	Street Address: 280 Huyler Street				Street Address: 280 Huyler Street		
	City, State, Zip: S. Hackensack, NJ 07606		Country: USA		City, State, Zip: S. Hackensack, NJ 07606		Country: USA
	Phone: 201-489-8700				Phone: 201-489-8700		
Email(s) for Report: Lab@omega-env.com			Email(s) for Invoice: ap@omega-env.com				

Project information

Project Name/No: Edison BOE/ Lindeneau / 21-1275-8		Purchase Order:	
EMSL LIMS Project ID: (If applicable, EMSL will provide)	US State where samples collected: NJ	State of Connecticut (CT) must select project location: <input type="checkbox"/> Commercial (Taxable)	<input type="checkbox"/> Residential (Non-Taxable)
Sampled By Name: Kari-Dean Scatell	Sampled By Signature: Kari-Dean Scatell	No. of Samples in Shipment: 24	
Turn-Around-Time (TAT)			
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 32 Hour
<input type="checkbox"/> 48 Hour	<input type="checkbox"/> 72 Hour	<input type="checkbox"/> 96 Hour	<input type="checkbox"/> 1 Week
		<input checked="" type="checkbox"/> 2 Week	

MATRIX		METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS	<input type="checkbox"/> % by wt. <input type="checkbox"/> ppm (mg/g) <input type="checkbox"/> mg/cm ²	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	<input type="checkbox"/>
Reporting Limit based on a minimum 0.25g sample weight		SW 846-8010D	ICP-OES	0.0004% (4ppm)	<input type="checkbox"/>
		NIOSH 7082	Flame Atomic Absorption	4µg/liter	<input type="checkbox"/>
		NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/liter	<input type="checkbox"/>
AIR		NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/liter	<input type="checkbox"/>
WIPE	<input type="checkbox"/> ASTM <input type="checkbox"/> NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	<input type="checkbox"/>
If no box is checked, non-ASTM Wipe is assumed		SW 846-8010D	ICP-OES	1.0µg/wipe	<input type="checkbox"/>
TCLP		SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
		SW 846-1311 / SW 846-8010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
SPLP		SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
		SW 846-1312 / SW 846-8010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
TTLIC		22 CFR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
		22 CFR App. II, SW 846-8010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
STLC		22 CFR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
		22 CFR App. II, SW 846-8010D*	ICP-OES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil		SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	<input type="checkbox"/>
		SW 846-8010D*	ICP-OES	2mg/kg (ppm)	<input type="checkbox"/>
Wastewater		SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
Unpreserved	<input type="checkbox"/>	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	<input type="checkbox"/>
Preserved with HNO ₃	<input type="checkbox"/> PH<2				
Drinking Water		EPA 200.5	ICP-OES	0.003 mg/L (ppm)	<input type="checkbox"/>
Unpreserved	<input type="checkbox"/>	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	<input type="checkbox"/>
Preserved with HNO ₃	<input checked="" type="checkbox"/> PH<2				
TSP/SPM Filter		40 CFR Part 50	ICP-OES	12 µg/liter	<input type="checkbox"/>
Other:					<input type="checkbox"/>

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
Samples begin on the following page			

Method of Shipment:		Sample Condition Upon Receipt:	
Requisitioned by: Keri-Dean Scarlett	Date/Time: 11/24/21 8:30	Received by: [Signature]	Date/Time: 11/30/21 8:25
Requisitioned by:	Date/Time:	Received by: [Signature]	Date/Time: 12/1/21 9:00

Controlled Document - DOC#25 Lead #1 4/19/2021

*B010C Available Upon Request

☐ **AGREE TO ELECTRONIC SIGNATURE** (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.



EMSL ANALYTICAL, INC.
250 ROUTE 130 NORTH
CINNAMILTON, NJ 08077
TESTING LABORATORY / TRAINING

Lead Chain of Custody

EMSL Order Number / Lab Use Only
012113727

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Units of Detection, etc.)

Lindeneau 21-1275-8

EMSL Analytical, Inc.
200 Route 130 North
Cinnamilton, NJ 08077

PHONE: (800) 220-3675
EMAIL: Cinnamilton.esd@emsl.com

Sample Number	Outlet #	Sample Location	Volume / Area	Date / Time Sampled	Notes
8-01FD		Kitchen Sink	250 mL	11/24/21 6:41	
8-02 FD		Water Fountain by Room 19 (R)		6:45	
8-03 FD		Water Fountain by Room 19 (L)		6:46	
8-04 FD		Water Fountain across MPR 3		6:58	
8-05 FD		Nurse's Office Water Fountain Sink		7:10	
8-06 FD		Faculty Room Sink		7:17	
8-07 FD		Main Office Water Fountain Sink		7:37	
8-08 FD		Water Fountain near Room 26 (R)		7:14	
8-09 FD		Water Fountain near Room 26 (L)		7:15	
8-10 FD		Room 24A Water Fountain		7:28	
8-11 FD		Room 24B Water Fountain		7:31	
8-12 FD		Water Fountain Room 23		7:32	
8-13FD		Water Fountain Room 25		7:32	
8-14 FD		Water Fountain Room 22		7:32	
8-15 FD		Water Fountain Room 26		7:34	
8-16 FD		Water Fountain Room 21B		7:38	
8-17 FD		Water Fountain Room 21A		7:21	
8-18 FD		Water Fountain near Room 9 (R)		7:04	7:10er off school

Method of Shipment: Sample Condition Upon Receipt

Relinquished by: K Seabold Date/Time: 11/24/21 8:38 Received by: Date/Time:



ENST Order Number / Lab Use Only

Climamison, NJ 08077

PHONE: (800) 220-3675
Email: Cinnamilton@aol.com

Cinnamonson, b.a.d., ab@emsf.com

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Lindeneau 21-1275-8

[illegible]

OrderID: 012113727