Water Testing Results - Pleasant Hill School District Action Level for Copper is 1.30 mg/L		
Fixture Location / Description	**Test Date**	**Results (mg/L)**
PHES Wrestling Gym Drinking Fountain	6/17/2022	ND
PHHS Library South Sink	6/17/2022	0.172
PHES K-1 Commons Drinking Fountain	6/17/2022	0.204
PHES Library South Sink	6/17/2022	0.163
PHHS Office Staff Lunch Room Sink	6/17/2022	0.136
PHES Classroom #17 Drinking Fountain	6/17/2022	ND
District Office Kitchen Sink	6/17/2022	0.218
PHHS Band Room Sink	6/17/2022	0.184
PHES Classroom #14 Drinking Fountain	6/17/2022	0.118
PHHS Gym Canteen Sink	6/17/2022	0.418
ND = Not Detected - Level is below the set detection limits of 0.100 mg/L		

Water Testing Results - Pleasant Hill School District Action Level for Lead is 0.0150 mg/L		
Fixture Location / Description	**Test Date**	**Results (mg/L)**
PHES Wrestling Gym Drinking Fountain	6/17/2022	0.00201
PHHS Library South Sink	6/17/2022	0.00314
PHES K-1 Commons Drinking Fountain	6/17/2022	0.00661
PHES Library South Sink	6/17/2022	0.0554
PHHS Office Staff Lunch Room Sink	6/17/2022	ND
PHES Classroom #17 Drinking Fountain	6/17/2022	0.00221
District Office Kitchen Sink	6/17/2022	0.0416
PHHS Band Room Sink	6/17/2022	0.00272
PHES Classroom #14 Drinking Fountain	6/17/2022	ND
PHHS Gym Canteen Sink	6/17/2022	0.00934
ND = Not Detected - Level is below the set detection limits of 0.0150 mg/L		