



May 24, 2022

ADDENDUM NO.3 TO ALL OFFERORS:

Invitation to Bid: ITB 7447

Description: HVAC Renovations Project at Charles Barrett Elementary

RFP Dated: April 26, 2022

For Delivery To: Alexandria City Public Schools (ACPS)

Invitation to Bids Due: May 31, 2022, 3:00 PM EST

**THE ITB IS HEREBY BEEN MODIFIED AS FOLLOWS:**

- CHANGE BID DUE DATE TO MAY 31, 2022, 3:00 PM EST
- ANSWER TO THE QUESTION

---

**Note:** A signed acknowledgment of this addendum should be received at the location indicated on the ITB either prior to the due date and hour or attached to your response. Signature on this addendum does not substitute for your signature on the original ITB document. The original ITB document must be signed.

Best Regards,

Lander Napper  
Buyer II

---

Name of Firm/Contractor

---

Authorized Signature/Title

---

Date

1. Volume dampers are being shown in the library, see where it says "TYP" if what is shown on the drawing below is correct, we will need to have access to every tap shown to have a volume damper installed, and of course all of them are above that corrugated metal ceiling etc... It might be something to investigate, how did they balance it before? Are volume dampers existing already?

**Answer:** For bidding please plan on installing the volume dampers as shown on the drawing. The balancing information is not available and currently is single zone space. ACPS is expecting the Contractor to perform pre-balancing after the metal ceiling is removed. Engineer of Records will be providing additional guidelines upon the submitted Pre-Tab report.

