

Water Testing Results - Pleasant Hill School District Action Level for Copper is 1.30 mg/L		
Fixture Location / Description	Test Date	Results (mg/L)
PHES Library South Sink	8/12/2022	0.109
PHES Library Drinking Fountain	8/12/2022	ND
District Office Kitchen Sink	8/12/2022	ND
ND = Not Detected - Level is below the set detection limits of 0.100 mg/L		

Water Testing Results - Pleasant Hill School District Action Level for Lead is 0.0150 mg/L		
Fixture Location / Description	Test Date	Results (mg/L)
PHES Library South Sink	6/17/2022	0.00365
PHES Library Drinking Fountain	6/17/2022	ND
District Office Kitchen Sink	6/17/2022	ND
ND = Not Detected - Level is below the set detection limits of 0.0150 mg/L		