

ANALYTICAL REPORT

Job Number: 420-194500-1
SDG Number: SR High/ JR High
Job Description: Ulster BOCES

For:
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Attention: Christy Fischer

Meredith Ruthven

Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
05/17/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-194500-1
SDG Number: SR High/ JR High

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-194500-1
SDG Number: SR High/ JR High

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-194500-1
SDG Number: SR High/ JR High

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194500-1	HS1 - Kitchen Slicer Sink	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-2	HS2 - Kitchen Store Room Hand/Eye Wash	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-3	HS3 - Kitchen Prep Sink by Ice Machine	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-4	HS4 - Kitchen Ice Machine	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-5	HS5 - Kitchen Kettle Left	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-6	HS6 - Kitchen Kettle Right	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-7	HS7 - Kitchen Bathroom by Kettle	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-8	HS8 - Kitchen Storeroom Bathroom	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-9	HS9 - Kitchen Snack Hut Coffee Machine	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-10	HS10 - Kitchen Snack Hut Prep Sink	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-11	HS11 - Kitchen Snack Hut Hand/Eye Wash	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-12	HS12 - Kitchen Serving Line Sink	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-13	HS13 - Kitchen Dishwashing Sink Left	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-14	HS14 - Kitchen Dishwashing Sink Right	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-15	HS15 - Kitchen Dishwashing Hand/Eye Wash	Drinking Water	03/24/2021 0500	04/06/2021 1228
420-194500-16	HS16 - 400 Wing Handicap Bathroom	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-17	HS17 - 400 Wing Water Fountain	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-18	HS18 - 400 Wing Mens Room	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-19	HS19 - 400 Wing Ladies Room	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-20	HS20 - Custodial Break Sink	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-21	HS21 - Custodial Ice Machine Tap	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-22	HS22 - Custodial Bathroom	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-23	HS23 - 400 Stage Right Bathroom	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-24	HS24 - 400 Stage Left Bathroom	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-25	HS25 - Auditorium Ladies Bathroom	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-26	HS26 - Auditorium Mens Bathroom	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-27	HS27 - High School Office Sink	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-28	HS28 - Sr High Faculty Bathroom	Drinking Water	03/24/2021 0515	04/06/2021 1228

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-194500-1
SDG Number: SR High/ JR High

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194500-29	HS29 - Sr High Faculty Break Room Sink	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-30	HS30 - 300 Bottle Filling Station	Drinking Water	03/24/2021 0515	04/06/2021 1228
420-194500-31	HS31 - 300 Girls Bathroom	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-32	HS32 - 300 Boys Bathroom	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-33	HS33 - Sr High Faculty Bath Left Across from Media Center	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-34	HS34 - Sr High Faculty Bath Right Across from Media Center	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-35	HS35 - Media Center Office Sink	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-36	HS36 - Media Center Bath Left	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-37	HS37 - Media Center Bath Right	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-38	HS38 - Room 16 Left	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-39	HS39 - Room 16 Left Center	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-40	HS40 - Room 16 Right Center	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-41	HS41 - Room 16 Right	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-42	HS42 - 17B Sink	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-43	HS43 - 17A Sink 1 (Left Single Bowl)	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-44	HS44 - 17A Sink 2 (Left Double Bowl)	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-45	HS45 - 17A Sink 3 (Right Double Bowl)	Drinking Water	03/24/2021 0530	04/06/2021 1228
420-194500-46	HS46 - 17a Sink 4 (Right Single Bowl)	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-47	HS47 - 100 Womens Bathroom (Faculty)	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-48	HS48 - Green House Sink	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-49	HS49 - Weight Room Fountain	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-50	HS50 - Sr High Girls Locker Room Sink	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-51	HS51 - Sr Hight Girls Locker Room Fountain Left	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-52	HS52 - Sr High Girls Locker Room Fountain Right	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-53	HS53 - Sr High Girls Coaches Office Sink	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-54	HS54 - Sr High Boys Coaches Office Sink	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-55	HS55 - Sr High Boys Locker Room Sink Left	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-56	HS56 - Sr High Boys Locker Room Sink Right	Drinking Water	03/24/2021 0545	04/06/2021 1228

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-194500-1
SDG Number: SR High/ JR High

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194500-57	HS57 - Sr High Boys Locker Room Fountain Left	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-58	HS58 - Sr High Boys Locker Room Fountain Right	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-59	HS59 - 300 Wing Faculty Bathroom Left	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-60	HS60 - 300 Wing Faculty Bathroom Right	Drinking Water	03/24/2021 0545	04/06/2021 1228
420-194500-61	HS61 - Jr High Faculty Lounge	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-62	HS62 - 307A Athletic Trainers Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-63	HS63 - Nurse Main Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-64	HS64 - Nurse Office/Closet Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-65	HS65 - Nurse Bathroom Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-66	HS66 - Home Economics Room 615 Lab 1	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-67	HS67 - Home Economics Room 615 Lab 2	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-68	HS68 - Home Economics Room 615 Lab 3	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-69	HS69 - Home Economics Room 615 Lab 4	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-70	HS70 - Home Economics Room 616 Blue Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-71	HS71 - Home Economics Room 616 Yellow Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-72	HS72 - Home Economics Room 616 Green Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-73	HS73 - Home Economics Room 616 Red Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-74	HS74 - 600 Handicap Bathroom	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-75	HS75 - 600 Boys Room Sink	Drinking Water	03/24/2021 0600	04/06/2021 1228
420-194500-76	HS76 - 600 Bottle Filling Station	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-77	HS77 - 600 Faculty Bathroom Left	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-78	HS78 - 600 Faculty Bathroom Right	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-79	HS79 - Jr High Library Office	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-80	HS80 - Jr High 500 Wing Handicap Bathroom	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-81	HS81 - 500 Boys Bathroom Left	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-82	HS82 - 500 Boys Bathroom Right	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-83	HS83 - 500 Wing Bottle Filling Station	Drinking Water	03/24/2021 0615	04/06/2021 1228

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-194500-1
SDG Number: SR High/ JR High

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194500-84	HS84 - Jr High Office	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-85	HS85 - Sr Cafe Bottle Filling Station	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-86	HS86 - Room 505	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-87	HS87 - Room 503 North Sink	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-88	HS88 - Room 503 South Sink	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-89	HS89 - Room 501 North Sink	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-90	HS90 - Room 501 South Sink	Drinking Water	03/24/2021 0615	04/06/2021 1228
420-194500-91	HS91 - Jr Cafe Bottle Filling Station	Drinking Water	03/24/2021 0630	04/06/2021 1228
420-194500-92	HS92 - Jr High Boys Coaches Bathroom	Drinking Water	03/24/2021 0630	04/06/2021 1228
420-194500-93	HS93 - Jr Boys Locker Room Sink Left	Drinking Water	03/24/2021 0630	04/06/2021 1228
420-194500-94	HS94 - Jr Boys Locker Room Sink Right	Drinking Water	03/24/2021 0630	04/06/2021 1228
420-194500-95	HS95 - Jr High Girls Coaches Bathroom	Drinking Water	03/24/2021 0630	04/06/2021 1228
420-194500-96	HS96 - Jr High Girls Locker Room Sink Left	Drinking Water	03/24/2021 0630	04/06/2021 1228
420-194500-97	HS97 - Jr High Girls Locker Room Sink Right	Drinking Water	03/24/2021 0630	04/06/2021 1228

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS1 - Kitchen Slicer Sink
Lab Sample ID: 420-194500-1

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 2034	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	7.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS2 - Kitchen Store Room Hand/Eye Wash
Lab Sample ID: 420-194500-2

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 2036	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	15	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS3 - Kitchen Prep Sink by Ice Machine
Lab Sample ID: 420-194500-3

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 2038	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS4 - Kitchen Ice Machine
Lab Sample ID: 420-194500-4

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 2040	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS5 - Kitchen Kettle Left
Lab Sample ID: 420-194500-5

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/06/2021 1625	
Prep Method: 200.7/200.8			Date Prepared:	05/03/2021 1210	
Pb	73	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS6 - Kitchen Kettle Right
Lab Sample ID: 420-194500-6

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 2042	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	21 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS7 - Kitchen Bathroom by Kettle
Lab Sample ID: 420-194500-7

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 2047	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	5.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS8 - Kitchen Storeroom Bathroom
Lab Sample ID: 420-194500-8

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/06/2021 1628	
Prep Method: 200.7/200.8			Date Prepared:	05/03/2021 1210	
Pb	2.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS9 - Kitchen Snack Hut Coffee Machine
Lab Sample ID: 420-194500-9

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 2049	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	4.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS10 - Kitchen Snack Hut Prep Sink
Lab Sample ID: 420-194500-10

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 2051	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	20 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS11 - Kitchen Snack Hut Hand/Eye Wash
Lab Sample ID: 420-194500-11

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0029	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	21 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS12 - Kitchen Serving Line Sink
Lab Sample ID: 420-194500-12

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0031	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS13 - Kitchen Dishwashing Sink Left
Lab Sample ID: 420-194500-13

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0033	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	5.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS14 - Kitchen Dishwashing Sink Right
Lab Sample ID: 420-194500-14

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0035	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	4.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS15 - Kitchen Dishwashing Hand/Eye Wash
Lab Sample ID: 420-194500-15

Date Sampled: 03/24/2021 0500
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0038	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	4.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS16 - 400 Wing Handicap Bathroom
Lab Sample ID: 420-194500-16

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0040	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS17 - 400 Wing Water Fountain
Lab Sample ID: 420-194500-17

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0042	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS18 - 400 Wing Mens Room
Lab Sample ID: 420-194500-18

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0055	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS19 - 400 Wing Ladies Room
Lab Sample ID: 420-194500-19

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0057	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS20 - Custodial Break Sink
Lab Sample ID: 420-194500-20

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0059	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS21 - Custodial Ice Machine Tap
Lab Sample ID: 420-194500-21

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed: 05/09/2021 0102	
Prep Method: 200.7/200.8				Date Prepared: 05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS22 - Custodial Bathroom
Lab Sample ID: 420-194500-22

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0104	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS23 - 400 Stage Right Bathroom
Lab Sample ID: 420-194500-23

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0106	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS24 - 400 Stage Left Bathroom
Lab Sample ID: 420-194500-24

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0108	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS25 - Auditorium Ladies Bathroom
Lab Sample ID: 420-194500-25

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				05/09/2021 0110	
Prep Method: 200.7/200.8				05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS26 - Auditorium Mens Bathroom
Lab Sample ID: 420-194500-26

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				05/09/2021 0113	
Prep Method: 200.7/200.8				05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS27 - High School Office Sink
Lab Sample ID: 420-194500-27

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0119	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS28 - Sr High Faculty Bathroom
Lab Sample ID: 420-194500-28

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0123	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS29 - Sr High Faculty Break Room Sink
Lab Sample ID: 420-194500-29

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0126	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS30 - 300 Bottle Filling Station
Lab Sample ID: 420-194500-30

Date Sampled: 03/24/2021 0515
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0128	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS31 - 300 Girls Bathroom
Lab Sample ID: 420-194500-31

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0130	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS32 - 300 Boys Bathroom
Lab Sample ID: 420-194500-32

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0132	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS33 - Sr High Faculty Bath Left Across from
Lab Sample ID: 420-194500-33

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0134	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	7.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS34 - Sr High Faculty Bath Right Across from
Lab Sample ID: 420-194500-34

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0137	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	5.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS35 - Media Center Office Sink
Lab Sample ID: 420-194500-35

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0139	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	6.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS36 - Media Center Bath Left
Lab Sample ID: 420-194500-36

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0145	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS37 - Media Center Bath Right
Lab Sample ID: 420-194500-37

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0148	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS38 - Room 16 Left
Lab Sample ID: 420-194500-38

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0156	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	3.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS39 - Room 16 Left Center
Lab Sample ID: 420-194500-39

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0158	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS40 - Room 16 Right Center
Lab Sample ID: 420-194500-40

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0201	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	5.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS41 - Room 16 Right
Lab Sample ID: 420-194500-41

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0203	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	8.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS42 - 17B Sink
Lab Sample ID: 420-194500-42

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0205	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	3.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS43 - 17A Sink 1 (Left Single Bowl)
Lab Sample ID: 420-194500-43

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0212	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	20	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS44 - 17A Sink 2 (Left Double Bowl)
Lab Sample ID: 420-194500-44

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0214	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	51 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS45 - 17A Sink 3 (Right Double Bowl)
Lab Sample ID: 420-194500-45

Date Sampled: 03/24/2021 0530
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0216	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	25 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS46 - 17a Sink 4 (Right Single Bowl)
Lab Sample ID: 420-194500-46

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0218	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	4.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS47 - 100 Womens Bathroom (Faculty)
Lab Sample ID: 420-194500-47

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0220	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS48 - Green House Sink
Lab Sample ID: 420-194500-48

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0225	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS49 - Weight Room Fountain
Lab Sample ID: 420-194500-49

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0227	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS50 - Sr High Girls Locker Room Sink
Lab Sample ID: 420-194500-50

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				05/09/2021 0229	
Prep Method: 200.7/200.8				05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS51 - Sr Hight Girls Locker Room Fountain
Lab Sample ID: 420-194500-51

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0231	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	120 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS52 - Sr High Girls Locker Room Fountain
Lab Sample ID: 420-194500-52

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0238	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	55 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS53 - Sr High Girls Coaches Office Sink
Lab Sample ID: 420-194500-53

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0240	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	12	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS54 - Sr High Boys Coaches Office Sink
Lab Sample ID: 420-194500-54

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0242	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	18 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS55 - Sr High Boys Locker Room Sink Left
Lab Sample ID: 420-194500-55

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0244	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	8.9	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS56 - Sr High Boys Locker Room Sink Right
Lab Sample ID: 420-194500-56

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0247	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	10	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS57 - Sr High Boys Locker Room Fountain
Lab Sample ID: 420-194500-57

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0249	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	6.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS58 - Sr High Boys Locker Room Fountain
Lab Sample ID: 420-194500-58

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0257	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	6.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS59 - 300 Wing Faculty Bathroom Left
Lab Sample ID: 420-194500-59

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0304	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	6.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS60 - 300 Wing Faculty Bathroom Right
Lab Sample ID: 420-194500-60

Date Sampled: 03/24/2021 0545
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0306	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS61 - Jr High Faculty Lounge
Lab Sample ID: 420-194500-61

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0308	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	23 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS62 - 307A Athletic Trainers Sink
Lab Sample ID: 420-194500-62

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0311	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS63 - Nurse Main Sink
Lab Sample ID: 420-194500-63

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0313	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS64 - Nurse Office/Closet Sink
Lab Sample ID: 420-194500-64

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0315	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	68	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS65 - Nurse Bathroom Sink
Lab Sample ID: 420-194500-65

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0317	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	7.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS66 - Home Economics Room 615 Lab 1
Lab Sample ID: 420-194500-66

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0319	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	13	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS67 - Home Economics Room 615 Lab 2
Lab Sample ID: 420-194500-67

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0321	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	32 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS68 - Home Economics Room 615 Lab 3
Lab Sample ID: 420-194500-68

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0330	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	99 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS69 - Home Economics Room 615 Lab 4
Lab Sample ID: 420-194500-69

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0332	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	91 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS70 - Home Economics Room 616 Blue Sink
Lab Sample ID: 420-194500-70

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0334	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	15	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS71 - Home Economics Room 616 Yellow Sink
Lab Sample ID: 420-194500-71

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0337	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	7.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS72 - Home Economics Room 616 Green Sink
Lab Sample ID: 420-194500-72

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0339	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS73 - Home Economics Room 616 Red Sink
Lab Sample ID: 420-194500-73

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	9.7	ug/L	1.0	1.0	1.0

Date Analyzed: 05/09/2021 0341

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS74 - 600 Handicap Bathroom
Lab Sample ID: 420-194500-74

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	1.0 U	ug/L	1.0	05/09/2021 0343 1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS75 - 600 Boys Room Sink
Lab Sample ID: 420-194500-75

Date Sampled: 03/24/2021 0600
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	50	g	ug/L	1.0	1.0

Date Analyzed: 05/09/2021 0345

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS76 - 600 Bottle Filling Station
Lab Sample ID: 420-194500-76

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	1.0 U	ug/L	1.0	05/09/2021 0348 1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS77 - 600 Faculty Bathroom Left
Lab Sample ID: 420-194500-77

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4 Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS78 - 600 Faculty Bathroom Right
Lab Sample ID: 420-194500-78

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0356	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	1.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS79 - Jr High Library Office
Lab Sample ID: 420-194500-79

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0405	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	18	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS80 - Jr High 500 Wing Handicap Bathroom
Lab Sample ID: 420-194500-80

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0407	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS81 - 500 Boys Bathroom Left
Lab Sample ID: 420-194500-81

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0409	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS82 - 500 Boys Bathroom Right
Lab Sample ID: 420-194500-82

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0412	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	27 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS83 - 500 Wing Bottle Filling Station
Lab Sample ID: 420-194500-83

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0414	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS84 - Jr High Office
Lab Sample ID: 420-194500-84

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0422	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	3.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS85 - Sr Cafe Bottle Filling Station
Lab Sample ID: 420-194500-85

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0425	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS86 - Room 505
Lab Sample ID: 420-194500-86

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0427	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	11	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS87 - Room 503 North Sink
Lab Sample ID: 420-194500-87

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0429	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	2.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS88 - Room 503 South Sink
Lab Sample ID: 420-194500-88

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0431	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	2.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS89 - Room 501 North Sink
Lab Sample ID: 420-194500-89

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0433	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	6.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS90 - Room 501 South Sink
Lab Sample ID: 420-194500-90

Date Sampled: 03/24/2021 0615
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0435	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	2.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS91 - Jr Cafe Bottle Filling Station
Lab Sample ID: 420-194500-91

Date Sampled: 03/24/2021 0630
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0438	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS92 - Jr High Boys Coaches Bathroom
Lab Sample ID: 420-194500-92

Date Sampled: 03/24/2021 0630
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0440	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	15 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS93 - Jr Boys Locker Room Sink Left
Lab Sample ID: 420-194500-93

Date Sampled: 03/24/2021 0630
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0442	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	5.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS94 - Jr Boys Locker Room Sink Right
Lab Sample ID: 420-194500-94

Date Sampled: 03/24/2021 0630
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0455	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	6.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS95 - Jr High Girls Coaches Bathroom
Lab Sample ID: 420-194500-95

Date Sampled: 03/24/2021 0630
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0457	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	2.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS96 - Jr High Girls Locker Room Sink Left
Lab Sample ID: 420-194500-96

Date Sampled: 03/24/2021 0630
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0500	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	18 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194500-1
Sdg Number: SR High/ JR High

Client Sample ID: HS97 - Jr High Girls Locker Room Sink Right
Lab Sample ID: 420-194500-97

Date Sampled: 03/24/2021 0630
Date Received: 04/06/2021 1228
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/09/2021 0502	
Prep Method: 200.7/200.8			Date Prepared:	05/04/2021 1000	
Pb	72 g	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: SR High/ JR High

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: SR High/ JR High

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: SR High/ JR High

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 194500	
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail: cfischer@ulsterbores.org rricks@saugerties.k12.ny.us					
Company: Saugerties CSD C/O Ulster BOCES								Page: Page 1 of 7	
Address: Call Box A		Due Date Requested:		Analysis Requested Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead (DW 200.8)		Total Number of Containers		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify) Other:	
City: Saugerties		TAT Requested (days):							
State, Zip: NY, 12477		PO #:							
Phone: 845-2551400 X1361		PWS #:							
Email: cfischer@ulsterbores.org		Project #:							
Project Name: Saugerties Central School District		Additional Contacts:							
Site: SR High/JR High		Please Email Results to cfischer@ulsterbores.org and rricks@saugerties.k12.ny.us							
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)				
				Preservation Code:					
HS1 - Kitchen Slicer Sink		3/24/21	500	G	DW				
HS2 - Kitchen Store Room Hand/Eye Wash		3/24/21	500	G	DW				
HS3 - Kitchen Prep Sink by Ice Machine		3/24/21	500	G	DW				
HS4 - Kitchen Ice Machine		3/24/21	500	G	DW				
HS5 - Kitchen Kettle Left		3/24/21	500	G	DW				
HS6 - Kitchen Kettle Right		3/24/21	500	G	DW				
HS7 - Kitchen Bathroom by Kettle		3/24/21	500	G	DW				
HS8 - Kitchen Storeroom Bathroom		3/24/21	500	G	DW				
HS9 - Kitchen Snack Hut Coffee Machine		3/24/21	500	G	DW				
HS10 - Kitchen Snack Hut Prep Sink		3/24/21	500	G	DW				
HS11 - Kitchen Snack Hut Hand/Eye Wash		3/24/21	500	G	DW				
HS12 - Kitchen Serving Line Sink		3/24/21	500	G	DW				
HS13 - Kitchen Dishwashing Sink Left		3/24/21	500	G	DW				
HS14 - Kitchen Dishwashing Sink Right		3/24/21	500	G	DW				
HS15 - Kitchen Dishwashing Hand/Eye Wash		3/24/21	500	G	DW				
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle									
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other									
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):			
Manufacturer/Lot #:									
Relinquished by: <i>[Signature]</i>		Date/Time: 4/6/21 1228		Company: <i>[Signature]</i>		Received by: <i>[Signature]</i>		Date/Time: 4/6/21 1228	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
ICE Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Cooler Temperature(s) °C/ IR GUN #: 20.6 °C		05/17/2021	

420-194500-B-1
 HS1 - Kitchen Slicer Sink
 Date Sampled: 3/24/2021 420-1659319

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 194500							
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail: cfischer@ulsterboces.org rricks@saugerties.k12.ny.us											
Company: Saugerties CSD C/O Ulster BOCES								Page: Page 2 of 7							
Address: Call Box A		Due Date Requested:		Analysis Requested Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead (DW 200.8)		Total Number of Containers		Preservation Codes: A - HCL L - EDA B - NaOH M - Sodium Sulfite C - Zn Acetate N - None D - Nitric Acid O - MCAA E - H2SO4 P - Other (specify) F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other:							
City: Saugerties		TAT Requested (days):													
State, Zip: NY, 12477		PO #:													
Phone: 845-2551400 X1361		PWS #:													
Email: cfischer@ulsterboces.org		Project #:													
Project Name: Saugerties Central School District		Additional Contacts:													
Site: SR High/JR High		Please Email Results to cfischer@ulsterboces.org and ricks@saugerties.k12.ny.us													
Sample Identification		Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=comp, G=grab)		Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)		Preservation Code		Special Instructions/Note:	
HS16 - 400 Wing Handicap Bathroom				3/24/21		515		G		DW					
HS17 - 400 Wing Water Fountain				3/24/21		515		G		DW					
HS18 - 400 Wing Mens Room				3/24/21		515		G		DW					
HS19 - 400 Wing Ladies Room				3/24/21		515		G		DW					
HS20 - Custodial Break Sink				3/24/21		515		G		DW					
HS21 - Custodial Ice Machine Tap				3/24/21		515		G		DW					
HS22 - Custodial Bathroom				3/24/21		515		G		DW					
HS23 - 400 Stage Right Bathroom				3/24/21		515		G		DW					
HS24 - 400 Stage Left Bathroom				3/24/21		515		G		DW					
HS25 - Auditorium Ladies Bathroom				3/24/21		515		G		DW					
HS26 - Auditorium Mens Bathroom				3/24/21		515		G		DW					
HS27 - High School Office Sink				3/24/21		515		G		DW					
HS28 - Sr High Faculty Bathroom				3/24/21		515		G		DW					
HS29 - Sr High Faculty Break Room Sink				3/24/21		515		G		DW					
HS30 - 300 Bottle Filling Station				3/24/21		515		G		DW					
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle														Container Type	
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other														Container Size	
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):									
Relinquished by: <i>[Signature]</i>		Date/Time: 4/6/21 1228		Company: <i>[Signature]</i>		Received by: <i>[Signature]</i>		Date/Time: 4/6/21 1228		Company: ETC					
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:					
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:					
ICE Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Page 2 of 9		Temperature(s) °C/ IR GUN #: 20.6 °C								05/17/2021	

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-194500-1
SDG Number: SR High/ JR High

Login Number: 194500

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	20.6 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	True	
If false, was sample received on ice within 6 hours of collection.	NA	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	