

ANALYTICAL REPORT

Job Number: 420-194492-1

SDG Number: Riccardi Elementary School

Job Description: Ulster BOCES

For:

Ulster BOCES

175 Route 32 North

New Paltz, NY 12561

Attention: Christy Fischer

Meredith Ruthven

Meredith W Ruthven

Customer Service Manager

mruthven@envirotestlaboratories.com

05/16/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

Envirotest Laboratories

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-194492-1
SDG Number: Riccardi Elementary School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-194492-1
SDG Number: Riccardi Elementary School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-194492-1
SDG Number: Riccardi Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194492-1	R1 - 1st Floor Handicap Bathroom By Teacher's Lounge	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-2	R2 - Teachers Lounge	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-3	R3 - 1st Floor Old Wing Girls Bathroom Left	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-4	R4 - 1st Floor Old Wing Girls Bathroom Right	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-5	R5 - Cafe Bottle Filling Station	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-6	R6 - Kitchen Prep Sink Left	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-7	R7 - Kitchen Prep Sink Right	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-8	R8 - Music Room by Gym	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-9	R9 - OT/PT by Gym	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-10	R10 - Boiler Room Sink	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-11	R11 - 1st Floor Old Wing Boys Room	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-12	R12 - Nurse Sink	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-13	R13 - Nurse Toilet Room	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-14	R14 - Conference Room	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-15	R15 - Office Kitchen Area Sink	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-16	R16 - Office Toilet Room	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-17	R17 - Room 109	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-18	R18 - 100 Wing Bottle Fill Station	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-19	R19 - Room 111	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-20	R20 - Room 112	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-21	R21 - Room 124	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-22	R22 - Room 122	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-23	R23 - Room 115	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-24	R24 - Room 116	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-25	R25 - Room 119	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-26	R26 - 2nd Floor New Wing Boys Bathroom Right	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-27	R27 - 2nd Floor New Wing Boys Bathroom Left	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-28	R28 - Room 205	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-29	R29 - 200 Wing Bottle Filling Station	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-30	R30 - 2nd Floor New Wing Girls Bathroom Left	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-31	R31 - 2nd Floor New Wing Girls Bathroom Right	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-32	R32 - Room 206	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-33	R33 - Room 207	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-34	R34 - 2nd Floor Faculty Bathroom Right	Drinking Water	03/26/2021 0515	04/06/2021 1227

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-194492-1
SDG Number: Riccardi Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-194492-35	R35 - 2nd Floor Faculty Bathroom Left	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-36	R36 - Room 213	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-37	R37 - Room 208	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-38	R38 - Room 209	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-39	R39 - Room 212	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-40	R40 - Room 211	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-41	R41 - 2nd Floor Old Wing Boys Bathroom Left	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-42	R42 - 2nd Floor Old Wing Boys Bathroom Right	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-43	R43 - 2nd Floor Old Wing Bottle Filling Station	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-44	R44 - 2nd Floor Old Wing Girls Bathroom Left	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-45	R45 - 2nd Floor Old Wing Girls Bathroom Right	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-46	R46 - Room 129	Drinking Water	03/26/2021 0515	04/06/2021 1227
420-194492-47	R47 - Room 127	Drinking Water	03/26/2021 0515	04/06/2021 1227

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R1 - 1st Floor Handicap Bathroom By Teacher's
Lab Sample ID: 420-194492-1

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1711	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R2 - Teachers Lounge
Lab Sample ID: 420-194492-2

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1713	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	4.9	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R3 - 1st Floor Old Wing Girls Bathroom Left
Lab Sample ID: 420-194492-3

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1722	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R4 - 1st Floor Old Wing Girls Bathroom Right
Lab Sample ID: 420-194492-4

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1728	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R5 - Cafe Bottle Filling Station
Lab Sample ID: 420-194492-5

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1730	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R6 - Kitchen Prep Sink Left
Lab Sample ID: 420-194492-6

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1733	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R7 - Kitchen Prep Sink Right
Lab Sample ID: 420-194492-7

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1735	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R8 - Music Room by Gym
Lab Sample ID: 420-194492-8

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1737	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	3.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R9 - OT/PT by Gym
Lab Sample ID: 420-194492-9

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1739	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R10 - Boiler Room Sink
Lab Sample ID: 420-194492-10

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1741	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R11 - 1st Floor Old Wing Boys Room
Lab Sample ID: 420-194492-11

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1743	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R12 - Nurse Sink
Lab Sample ID: 420-194492-12

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1746	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R13 - Nurse Toilet Room
Lab Sample ID: 420-194492-13

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1754	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.9	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R14 - Conference Room
Lab Sample ID: 420-194492-14

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1757	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	9.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R15 - Office Kitchen Area Sink
Lab Sample ID: 420-194492-15

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1759	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R16 - Office Toilet Room
Lab Sample ID: 420-194492-16

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1801	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R17 - Room 109
Lab Sample ID: 420-194492-17

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1803	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	3.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R18 - 100 Wing Bottle Fill Station
Lab Sample ID: 420-194492-18

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1805	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R19 - Room 111
Lab Sample ID: 420-194492-19

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1807	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R20 - Room 112
Lab Sample ID: 420-194492-20

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1810	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R21 - Room 124
Lab Sample ID: 420-194492-21

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1812	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R22 - Room 122
Lab Sample ID: 420-194492-22

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1814	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R23 - Room 115
Lab Sample ID: 420-194492-23

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1827	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R24 - Room 116
Lab Sample ID: 420-194492-24

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1829	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R25 - Room 119
Lab Sample ID: 420-194492-25

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1831	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R26 - 2nd Floor New Wing Boys Bathroom
Lab Sample ID: 420-194492-26

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1834	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R27 - 2nd Floor New Wing Boys Bathroom Left
Lab Sample ID: 420-194492-27

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1836	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	17	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R28 - Room 205
Lab Sample ID: 420-194492-28

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1838	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R29 - 200 Wing Bottle Filling Station
Lab Sample ID: 420-194492-29

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1840	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R30 - 2nd Floor New Wing Girls Bathroom Left
Lab Sample ID: 420-194492-30

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1847	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R31 - 2nd Floor New Wing Girls Bathroom Right
Lab Sample ID: 420-194492-31

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1849	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R32 - Room 206
Lab Sample ID: 420-194492-32

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1851	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	2.9	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R33 - Room 207
Lab Sample ID: 420-194492-33

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1855	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	20	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R34 - 2nd Floor Faculty Bathroom Right
Lab Sample ID: 420-194492-34

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1858	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	4.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R35 - 2nd Floor Faculty Bathroom Left
Lab Sample ID: 420-194492-35

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1900	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	3.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R36 - Room 213
Lab Sample ID: 420-194492-36

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1902	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	6.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R37 - Room 208
Lab Sample ID: 420-194492-37

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1904	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	4.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R38 - Room 209
Lab Sample ID: 420-194492-38

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1906	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	3.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R39 - Room 212
Lab Sample ID: 420-194492-39

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1913	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	6.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R40 - Room 211
Lab Sample ID: 420-194492-40

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1915	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	10	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R41 - 2nd Floor Old Wing Boys Bathroom Left
Lab Sample ID: 420-194492-41

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1917	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R42 - 2nd Floor Old Wing Boys Bathroom Right
Lab Sample ID: 420-194492-42

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1919	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R43 - 2nd Floor Old Wing Bottle Filling Station
Lab Sample ID: 420-194492-43

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1928	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R44 - 2nd Floor Old Wing Girls Bathroom Left
Lab Sample ID: 420-194492-44

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1930	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R45 - 2nd Floor Old Wing Girls Bathroom Right
Lab Sample ID: 420-194492-45

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1932	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	1.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R46 - Room 129
Lab Sample ID: 420-194492-46

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1939	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	64	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-194492-1
Sdg Number: Riccardi Elementary School

Client Sample ID: R47 - Room 127
Lab Sample ID: 420-194492-47

Date Sampled: 03/26/2021 0515
Date Received: 04/06/2021 1227
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	05/08/2021 1941	
Prep Method: 200.7/200.8			Date Prepared:	05/02/2021 1200	
Pb	10	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: Riccardi Elementary School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: Riccardi Elementary School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: Riccardi Elementary School

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 194492	
Client Contact: C Fischer		Phone: 845-255-1400 X1361		E-Mail: cfischer@ulsterbores.org ricks@saugerties.k12.ny.us					
Company: Saugerties CSD C/O Ulster BOCES					Analysis Requested				
Address: Call Box A		Due Date Requested:		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead (DW 200.8)				Total Number of Containers	
City: Saugerties		TAT Requested (days):							
State, Zip: NY, 12477		PO #:							
Phone: 845-2551400 X1361		PWS #:							
Email: cfischer@ulsterbores.org		Project #:							
Project Name: Saugerties Central School District		Additional Contacts:							
Site: Riccardi Elementary School					Please Email Results to cfischer@ulsterbores.org and ricks@saugerties.k12.ny.us				
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)				
				Preservation Code				Upon Receipt Preservation verified: Y / N	
								Special Instructions/Note:	
R1- 1st Floor Handicap Bathroom by Teacher's Lounge		3/26/21	515	G	DW		X		
R2- Teacher's Lounge		3/26/21	515	G	DW		X		
R3- 1st Floor Old Wing Girls Bathroom Left		3/26/21	515	G	DW		X		
R4- 1st Floor Old Wing Girls Bathroom Right		3/26/21	515	G	DW		X		
R5- Café Bottle Filling Station		3/26/21	515	G	DW		X		
R6- Kitchen Prep Sink Left		3/26/21	515	G	DW		X		
R7- Kitchen Prep Sink Right		3/26/21	515	G	DW		X		
R8- Music Room by Gym		3/26/21	515	G	DW		X		
R9- OT/PT by Gym		3/26/21	515	G	DW		X		
R10- Boiler Room Sink		3/26/21	515	G	DW		X		
R11- 1st Floor Old Wing Boys Room		3/26/21	515	G	DW		X		
R12- Nurse Sink		3/26/21	515	G	DW		X		
R13- Nurse Toilet Room		3/26/21	515	G	DW		X		
R14- Conference Room		3/26/21	515	G	DW		X		
R15- Office Kitchen Area Sink		3/26/21	515	G	DW		X		
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle						P		Container Type	
Size Code: 1=1 Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other						2		Container Size	
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):			
Manufacturer/Lot #:									
Relinquished by:		Date/Time: 4/6/21 1227		Company: ulsterbores		Received by:		Date/Time: 4/6/21 1227	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
ICE Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Cooler Temperature(s) °C/ IR GUN #: 20.6 °C		05/16/2021	

420-194492-B-1
 R1 - 1st Floor Handicap Bathroom By Teacher's Lounge
 Date Sampled: 3/26/2021 420-1659177

194492

Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #:			
Client Contact: C Fischer		Phone: 845-255-1400 X1361		E-Mail: cfischer@ulsterboces.org rricks@saugerties.k12.ny.us				Page: 2 of 4			
Company: Saugerties CSD C/O Ulster BOCES		Address: Call Box A		Due Date Requested:		Analysis Requested		Preservation Codes:			
City: Saugerties		TAT Requested (days):						A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate		L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
State, Zip: NY, 12477		PO #:						Total Number of Containers		Other:	
Phone: 845-2551400 X1361		PWS #:								Upon Receipt Preservation verified: Y / N	
Email: cfischer@ulsterboces.org		Project #:									
Project Name: Saugerties Central School District		Additional Contacts:									
Site: Riccardi Elementary School		Please Email Results to cfischer@ulsterboces.org and ricks@saugerties.k12.ny.us									
Sample Identification Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)			
								Field Filtered Sample (Yes or No)			
								Perform MS/MSD (Yes or No)			
								Chlorite Present (Yes or No)			
								Lead (DW 200.8)			
								Preservation Code:			
R16- Office Toilet Room		3/26/21		515		G DW		X			
R17- Room 109		3/26/21		515		G DW		X			
R18- 100 Wing Bottle Filling Station		3/26/21		515		G DW		X			
R19- Room 111		3/26/21		515		G DW		X			
R20- Room 112		3/26/21		515		G DW		X			
R21 - Room 124		3/26/21		515		G DW		X			
R22 - Room 122		3/26/21		515		G DW		X			
R23- Room 115		3/26/21		515		G DW		X			
R24- Room 116		3/26/21		515		G DW		X			
R25- Room 119		3/26/21		515		G DW		X			
R26- 2nd Floor New Wing Boys Bathroom Right		3/26/21		515		G DW		X			
R27- 2nd Floor New Wing Boys Bathroom Left		3/26/21		515		G DW		X			
R28- Room 205		3/26/21		515		G DW		X			
R29- 200 Wing Bottle Filling Station		3/26/21		515		G DW		X			
R30- 2nd Floor New Wing Girls Bathroom Left		3/26/21		515		G DW		X			
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle								P			
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other								2			
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):		Container Type			
Manufacturer/Lot #:								Container Size			
Relinquished by:		Date/Time: 4/6/21 1227		Company: ulsterboces		Received by:		Date/Time: 4/6/21 1227			
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:			
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:			
ICE Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Cooler Temperature(s) °C/IR GUN #: 20.6 °C		Page 57 of 60			

Chain of Custody Record

Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 194492		
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail: cfischer@ulsterbooces.org rricks@saugerties.k12.ny.us				Page: 3 of 4		
Company: Saugerties CSD C/O Ulster BOCES						Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)		
Address: Call Box A		Due Date Requested:								
City: Saugerties		TAT Requested (days):								
State, Zip: NY, 12477										
Phone: 845-2551400 X1361		PO #:								
Email: cfischer@ulsterbooces.org		PWS #:								
Project Name: Saugerties Central School District		Project #:								
Site: Riccardi Elementary School		Additional Contacts:								
Please Email Results to cfischer@ulsterbooces.org and ricks@saugerties.k12.ny.us										
Sample Identification	Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead (DW 200.8)	Total Number of Containers
Preservation Code:										
Special Instructions/Note:										
R31- 2nd Floor New Wing Girls Bathroom Right		3/26/21	515	G	DW				X	
R32- Room 206		3/26/21	515	G	DW				X	
R33- Room 207		3/26/21	515	G	DW				X	
R34- 2nd Floor Faculty Bathroom Right		3/26/21	515	G	DW				X	
R35- 2nd Floor Faculty Bathroom Left		3/26/21	515	G	DW				X	
R36- Room 213		3/26/21	515	G	DW				X	
R37- Room 208		3/26/21	515	G	DW				X	
R38- Room 209		3/26/21	515	G	DW				X	
R39- Room 212		3/26/21	515	G	DW				X	
R40- Room 211		3/26/21	515	G	DW				X	
R41- 2nd Floor Old Wing Boys Bathroom Left		3/26/21	515	G	DW				X	
R42- 2nd Floor Old Wing Boys Bathroom Right		3/26/21	515	G	DW				X	
R43- 2nd Floor Old Wing Bottle Filling Station		3/26/21	515	G	DW				X	
R44- 2nd Floor Old Wing Girls Bathroom Left		3/26/21	515	G	DW				X	
R45- 2nd Floor Old Wing Girls Bathroom Left		3/26/21	515	G	DW				X	
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle										
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other										
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):				
Manufacturer/Lot #:										
Relinquished by: <i>[Signature]</i>	Date/Time: 3/16/21 1227	Company: <i>ulsterbooces</i>	Received by: <i>[Signature]</i>	Date/Time: 4/16/21 1227	Company: <i>ETC</i>					
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:					
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:					
ICE Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Custody Seal No.:	Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Page 58 of 60	Cooler Temperature(s) °C/ IR GUN #: 20.6 °C						

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: Randy Ricks	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 194492						
Client Contact: C Fischer		Phone: 845-255-1400 X1361	E-Mail: cfischer@ulsterbores.org rricks@saugerties.k12.ny.us								
Company: Saugerties CSD C/O Ulster BOCES		Analysis Requested			Page: 4 of 4						
Address: Call Box A	Due Date Requested:				Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead (DW 200.8)			
City: Saugerties	TAT Requested (days):								Total Number of Containers	Preservation Codes:	
State, Zip: NY, 12477										A - HCL	L - EDA
Phone: 845-2551400 X1361	PO #:									B - NaOH	M - Sodium Sulfite
Email: cfischer@ulsterbores.org	PWS #:									C - Zn Acetate	N - None
Project Name: Saugerties Central School District	Project #:									D - Nitric Acid	O - MCAA
Site: Riccardi Elementary School	Additional Contacts:									E - H2SO4	P - Other (specify)
Please Email Results to cfischer@ulsterbores.org and ricks@saugerties.k12.ny.us		Other:		Upon Receipt Preservation verified: Y / N							
Sample Identification Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)							
Preservation Code:											
R46- Room 129	3/26/21	515	G	DW	X						
R47- Room 127	3/26/21	515	G	DW	X						
Special Instructions/Note:											
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle					P						
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other					2						
Preservation Added Upon Receipt:		Date:	Time:	Sample # (s):							
Manufacturer/Lot #:											
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:						
<i>[Signature]</i>	4/6/21 1227	ulsterbores	<i>[Signature]</i>	4/6/21 1227	ETL						
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:						
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:						
ICE Present Δ Yes <input checked="" type="checkbox"/> No	Custody Seal No.:	Custody Seals Intact Yes Δ No <input checked="" type="checkbox"/>	Page 59 of 60	Cooler Temperature(s) °C/ IR GUN #: 20.6 °C	05/16/2021						

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-194492-1
SDG Number: Riccardi Elementary School

Login Number: 194492

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	20.6 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	True	
If false, was sample received on ice within 6 hours of collection.	NA	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	