

ANALYTICAL REPORT

Job Number: 420-195423-1

SDG Number: Cahill Elementary School

Job Description: Ulster BOCES

For:
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Attention: Christy Fischer



Designee for
Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
06/21/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

Envirotest Laboratories

315 Fullerton Avenue, Newburgh, NY 12550
Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-195423-1
SDG Number: Cahill Elementary School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-195423-1
SDG Number: Cahill Elementary School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-195423-1
SDG Number: Cahill Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195423-1	C1- Room 169	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-2	C2 - Toilet Room 169	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-3	C3- 1st Floor Girls Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-4	C4- 1st Floor Girls Bathroom Center	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-5	C5- 1st Floor Girls Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-6	C6 - Floor 1 Bottle Filling Station	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-7	C7- 1st Floor Boys Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-8	C8- 1st Floor Boys Bathroom Center	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-9	C9- 1st Floor Boys Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-10	C10 - Room 174	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-11	C11 - Toilet Room 174	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-12	C12 - Room 177	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-13	C13 - Toilet Room 177	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-14	C14 - Kitchen South Sink	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-15	C15 - Kitchen Foot Pedal Sink	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-16	C16 - Kitchen Prep Sink	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-17	C17 - Room 265	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-18	C18 - 2nd Floor Girls Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-19	C19 - 2nd Floor Girls Bathroom Center	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-20	C20 - 2nd Floor Girls Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-21	C21- 2nd Floor Boys Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-22	C22- 2nd Floor Boys Bathroom Center	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-23	C23 - Room 273	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-24	C24- Toilet Room 273	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-25	C25- Room 270	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-26	C26- Teachers Lounge off of Library	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-27	C27- Basement Teacher's Lounge	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-28	C28- Basement Faculty Women Bathroom off of Faculty Room	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-29	C29- Basement Faculty Men Bathroom off of Faculty Room	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-30	C30-Basement Girls Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-195423-1
SDG Number: Cahill Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195423-31	C31-Basement Girls Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-32	C32-Basement Boys Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-33	C33-Basement Boys Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-34	C34- Basement Science Lab	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-35	C35- Room 101	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-36	C36- 1R Bottle Filling Station	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-37	C37- Nurse Sink	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-38	C38-Nurse Toilet Room	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-39	C39-1 R Women Bathroom by the Office Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-40	C40-1 R Men Bathroom by the Office Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-41	C41-1 R Men Bathroom by the Office Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-42	C42- Office Kitchen Area Sink	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-43	C43- Office Toilet Room	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-44	C44- Spec Ed Office Bar Sink	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-45	C45- Room 114	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-46	C46-Room 138 Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-47	C47-Room 138 Left Center	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-48	C48-Room 138 Right Center	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-49	C49-Room 138 Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-50	C50-1R Boys Bathroom by the Gym Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-51	C51-1R Boys Bathroom by the Gym Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-52	C52-1R Girls Bathroom by the Gym Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-53	C53-1R Girls Bathroom by the Gym Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-54	C54-Room 201	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-55	C55-2R Girls Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-56	C56-2R Girls Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-57	C57-Room 203	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-58	C58- Room 205 Teachers Lounge	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-59	C59- Room 205 Faculty Bathroom	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-60	C60-Room 207	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-61	C61- 2R Boys Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-195423-1
SDG Number: Cahill Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195423-62	C62- 2R Boys Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-63	C63- Room 209	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-64	C64- Room 211	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-65	C65- Room 229	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-66	C66 - Room 231	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-67	C67- Room 235	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-68	C68-Room 233	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-69	C69-3R Teacher lounge	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-70	C70-3R Toilet Room Teacher Lounge	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-71	C71-Room 303	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-72	C72- Room 319	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-73	C73-Room 305	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-74	C74-Room 317	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-75	C75-3R Girls Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-76	C76-3R Girls Bathroom Center	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-77	C77-3R Girls Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-78	C78-Room 307	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-79	C79-Room 315	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-80	C80-3R Boys Bathroom Left	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-81	C81-3R Boys Bathroom Center	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-82	C82-3R Boys Bathroom Right	Drinking Water	03/26/2021 0615	04/14/2021 1246
420-195423-83	C83-3R Bottle Filling Station	Drinking Water	03/26/2021 0615	04/14/2021 1246

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C1- Room 169
Lab Sample ID: 420-195423-1

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0900	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C2 - Toilet Room 169
Lab Sample ID: 420-195423-2

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0902	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C3- 1st Floor Girls Bathroom Left
Lab Sample ID: 420-195423-3

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0904	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C4- 1st Floor Girls Bathroom Center
Lab Sample ID: 420-195423-4

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0907	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C5- 1st Floor Girls Bathroom Right
Lab Sample ID: 420-195423-5

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0909	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C6 - Floor 1 Bottle Filling Station
Lab Sample ID: 420-195423-6

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0911	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C7- 1st Floor Boys Bathroom Left
Lab Sample ID: 420-195423-7

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0920	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C8- 1st Floor Boys Bathroom Center
Lab Sample ID: 420-195423-8

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0922	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C9- 1st Floor Boys Bathroom Right
Lab Sample ID: 420-195423-9

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0924	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C10 - Room 174
Lab Sample ID: 420-195423-10

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0926	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C11 - Toilet Room 174
Lab Sample ID: 420-195423-11

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0929	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C12 - Room 177
Lab Sample ID: 420-195423-12

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0931	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C13 - Toilet Room 177
Lab Sample ID: 420-195423-13

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0933	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C14 - Kitchen South Dink
Lab Sample ID: 420-195423-14

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021	0935	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021	1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C15 - Kitchen Foot Pedal Sink
Lab Sample ID: 420-195423-15

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0937	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	66	g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C16 - Kitchen Prep Sink
Lab Sample ID: 420-195423-16

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0944	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C17 - Room 265
Lab Sample ID: 420-195423-17

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021	0953	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021	1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C18 - 2nd Floor Girls Bathroom Left
Lab Sample ID: 420-195423-18

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0955	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C19 - 2nd Floor Girls Bathroom Center
Lab Sample ID: 420-195423-19

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0957	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C20 - 2nd Floor Girls Bathroom Right
Lab Sample ID: 420-195423-20

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 0959	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C21- 2nd Floor Boys Bathroom Left
Lab Sample ID: 420-195423-21

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1001	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C22- 2nd Floor Boys Bathroom Center
Lab Sample ID: 420-195423-22

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1004	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C23 - Room 273
Lab Sample ID: 420-195423-23

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1010	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C24- Toilet Room 273
Lab Sample ID: 420-195423-24

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1012	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C25- Room 270
Lab Sample ID: 420-195423-25

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1014	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C26- Teachers Lounge off of Library
Lab Sample ID: 420-195423-26

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1017	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C27- Basement Teacher's Lounge
Lab Sample ID: 420-195423-27

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1021	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C28- Basement Faculty Women Bathroom off of
Lab Sample ID: 420-195423-28

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1023	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C29- Basement Faculty Men Bathroom off of
Lab Sample ID: 420-195423-29

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1025	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C30-Basement Girls Bathroom Left
Lab Sample ID: 420-195423-30

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1028	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C31-Basement Girls Bathroom Right
Lab Sample ID: 420-195423-31

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1030	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C32-Basement Boys Bathroom Left
Lab Sample ID: 420-195423-32

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1036	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C33-Basement Boys Bathroom Right
Lab Sample ID: 420-195423-33

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1038	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	4.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C34- Basement Science Lab
Lab Sample ID: 420-195423-34

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1041	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	43	g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C35- Room 101
Lab Sample ID: 420-195423-35

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1043	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C36- 1R Bottle Filling Station
Lab Sample ID: 420-195423-36

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1045	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C37- Nurse Sink
Lab Sample ID: 420-195423-37

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1054	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C38-Nurse Toilet Room
Lab Sample ID: 420-195423-38

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1056	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C39-1 R Women Bathroom by the Office Left
Lab Sample ID: 420-195423-39

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1102	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C40-1 R Men Bathroom by the Office Left
Lab Sample ID: 420-195423-40

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1105	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C41-1 R Men Bathroom by the Office Right
Lab Sample ID: 420-195423-41

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1107	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C42- Office Kitchen Area Sink
Lab Sample ID: 420-195423-42

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/17/2021 1500	
Prep Method: 200.7/200.8				Date Prepared:	06/09/2021 1350	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C43- Office Toilet Room
Lab Sample ID: 420-195423-43

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1109	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C44- Spec Ed Office Bar Sink
Lab Sample ID: 420-195423-44

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1111	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C45- Room 114
Lab Sample ID: 420-195423-45

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1113	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C46-Room 138 Left
Lab Sample ID: 420-195423-46

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1116	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	6.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C47-Room 138 Left Center
Lab Sample ID: 420-195423-47

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1118	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C48-Room 138 Right Center
Lab Sample ID: 420-195423-48

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1122	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C49-Room 138 Right
Lab Sample ID: 420-195423-49

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1129	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	9.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C50-1R Boys Bathroom by the Gym Left
Lab Sample ID: 420-195423-50

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1131	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C51-1R Boys Bathroom by the Gym Right
Lab Sample ID: 420-195423-51

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1133	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C52-1R Girls Bathroom by the Gym Left
Lab Sample ID: 420-195423-52

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1135	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C53-1R Girls Bathroom by the Gym Right
Lab Sample ID: 420-195423-53

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1137	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C54-Room 201
Lab Sample ID: 420-195423-54

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1140	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C55-2R Girls Bathroom Left
Lab Sample ID: 420-195423-55

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1142	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C56-2R Girls Bathroom Right
Lab Sample ID: 420-195423-56

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1144	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C57-Room 203
Lab Sample ID: 420-195423-57

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1701	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C58- Room 205 Teachers Lounge
Lab Sample ID: 420-195423-58

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1714	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C59- Room 205 Faculty Bathroom
Lab Sample ID: 420-195423-59

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1716	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C60-Room 207
Lab Sample ID: 420-195423-60

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1718	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C61- 2R Boys Bathroom Left
Lab Sample ID: 420-195423-61

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1720	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C62- 2R Boys Bathroom Right
Lab Sample ID: 420-195423-62

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1723	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C63- Room 209
Lab Sample ID: 420-195423-63

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1725	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C64- Room 211
Lab Sample ID: 420-195423-64

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1727	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C65- Room 229
Lab Sample ID: 420-195423-65

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1729	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C66 - Room 231
Lab Sample ID: 420-195423-66

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1736	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C67- Room 235
Lab Sample ID: 420-195423-67

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1738	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C68-Room 233
Lab Sample ID: 420-195423-68

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1742	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	4.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C69-3R Teacher lounge
Lab Sample ID: 420-195423-69

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1744	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C70-3R Toilet Room Teacher Lounge
Lab Sample ID: 420-195423-70

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1747	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C71-Room 303
Lab Sample ID: 420-195423-71

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1749	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C72- Room 319
Lab Sample ID: 420-195423-72

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1751	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C73-Room 305
Lab Sample ID: 420-195423-73

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1753	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C74-Room 317
Lab Sample ID: 420-195423-74

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1755	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C75-3R Girls Bathroom Left
Lab Sample ID: 420-195423-75

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1802	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C76-3R Girls Bathroom Center
Lab Sample ID: 420-195423-76

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1804	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C77-3R Girls Bathroom Right
Lab Sample ID: 420-195423-77

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1806	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C78-Room 307
Lab Sample ID: 420-195423-78

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 1815	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C79-Room 315
Lab Sample ID: 420-195423-79

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1817	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C80-3R Boys Bathroom Left
Lab Sample ID: 420-195423-80

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1819	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C81-3R Boys Bathroom Center
Lab Sample ID: 420-195423-81

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1821	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C82-3R Boys Bathroom Right
Lab Sample ID: 420-195423-82

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1828	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195423-1
Sdg Number: Cahill Elementary School

Client Sample ID: C83-3R Bottle Filling Station
Lab Sample ID: 420-195423-83

Date Sampled: 03/26/2021 0615
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/12/2021 1830	
Prep Method: 200.7/200.8				Date Prepared:	06/08/2021 1000	
Pb	1.0	U	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:

Sdg Number: Cahill Elementary School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: Cahill Elementary School

The following analytes are Not Part of the ELAP scope of accreditation

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation

Ammonia (SM 4500NH₃G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Settable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation

Ammonia (SM 4500NH₃G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: Cahill Elementary School

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

EnviroTest
Laboratories

Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 195423 1 of 6		
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail: cfischer@ulsterboces.org rricks@saugerties.k12.ny.us						
Company: Saugerties CSD C/O Ulster BOCES										
Address: Call Box A		Due Date Requested:		Analysis Requested Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead (DW 200.8)						
City: Saugerties		TAT Requested (days):								
State, Zip: NY, 12477										
Phone: 845-2551400 X1361		PO #:								
Email: cfischer@ulsterboces.org		PWS #:								
Project Name: Saugerties Central School District		Project #:								
Site: Cahill Elementary School		Additional Contacts:								
		Please Email Results to cfischer@ulsterboces.org and rricks@saugerties.k12.ny.us								
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)					Total Number of containers
										Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)
										Other:
										Upon Receipt Preservation verified: Y / N
										Special Instructions/Note:
C1- Room 169		3/26/21	615	G	DW				X	
C2- Toilet Room 169		3/26/21	615	G	DW				X	
C3- 1st Floor Girls Bathroom Left		3/26/21	615	G	DW				X	
C4- 1st Floor Girls Bathroom Center		3/26/21	615	G	DW				X	
C5- 1st Floor Girls Bathroom Right		3/26/21	615	G	DW				X	
C6- Floor 1 Bottle Filling Station		3/26/21	615	G	DW				X	
C7- 1st Floor Boys Bathroom Left		3/26/21	615	G	DW				X	
C8- 1st Floor Boys Bathroom Center		3/26/21	615	G	DW				X	
C9- 1st Floor Boys Bathroom Right		3/26/21	615	G	DW				X	
C10- Room 174		3/26/21	615	G	DW				X	
C11- Toilet Room 174		3/26/21	615	G	DW				X	
C12- Room 177		3/26/21	615	G	DW				X	
C13- Toilet Room 177		3/26/21	615	G	DW				X	
C14- Kitchen South Sink		3/26/21	615	G	DW				X	
C15- Kitchen Foot Pedal Sink		3/26/21	615	G	DW				X	
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle						P				Container Type
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other						2				Container Size
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):				
Manufacturer/Lot #:										
Relinquished by: <i>[Signature]</i>		Date/Time: 4/14/21 1246		Company: ulsterboces		Received by: <i>[Signature]</i>		Date/Time: 4/14/21 1246 Company: ETC		
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time: Company:		
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time: Company:		
ICE Present: ☒ Yes ☐ No		Custody Seal No.:		Custody Seals intact: ☒ Yes ☐ No		Cooling Temperature(s) °C/ IR GUN #: 24.7C		06/21/2021		



EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

EnviroTest
Laboratories

Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 195423 286			
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail: cfischer@ulsterboces.org rricks@saugerties.k12.ny.us							
Company: Saugerties CSD C/O Ulster BOCES				Analysis Requested				Page: Page 2 of 6			
Address: Call Box A		Due Date Requested:						Preservation Codes:			
City: Saugerties		TAT Requested (days):		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead (DW 200.8) Total Number of containers		A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)					
State, Zip: NY, 12477		PO #:				Other:					
Phone: 845-2551400 X1361		PWS #:				Upon Receipt Preservation verified: Y / N					
Email: cfischer@ulsterboces.org		Project #:									
Project Name: Saugerties Central School District		Additional Contacts: Please Email Results to cfischer@ulsterboces.org and ricks@saugerties.k12.ny.us									
Site: Cahill Elementary School											
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead (DW 200.8)	Special Instructions/Note:	
C16- Kitchen Prep Sink		3/26/21	615	G	DW				X		
C17- Room 265		3/26/21	615	G	DW				X		
C18- 2nd Floor Girls Bathroom Left		3/26/21	615	G	DW				X		
C19- 2nd Floor Girls Bathroom Center		3/26/21	615	G	DW				X		
C20- 2nd Floor Girls Bathroom Right		3/26/21	615	G	DW				X		
C21- 2nd Floor Boys Bathroom Left		3/26/21	615	G	DW				X		
C22- 2nd Floor Boys Bathroom Center		3/26/21	615	G	DW				X		
C23- Room 273		3/26/21	615	G	DW				X		
C24- Toilet Room 273		3/26/21	615	G	DW				X		
C25- Room 270		3/26/21	615	G	DW				X		
C26- Teachers Lounge off of Library		3/26/21	615	G	DW				X		
C27- Basement Teachers Lounge		3/26/21	615	G	DW				X		
C28- Basement Faculty Women Bathroom off of Faculty Room		3/26/21	615	G	DW				X		
C29- Basement Faculty Men Bathroom off of Faculty Room		3/26/21	615	G	DW				X		
C30- Basement Girls Bathroom Left		3/26/21	615	G	DW				X		
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle						P				Container Type	
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other						2				Container Size	
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):					
Manufacturer/Lot #:											
Relinquished by: <i>[Signature]</i>		Date/Time: 4/14/21 1246		Company: <i>[Signature]</i>		Received by: <i>[Signature]</i>		Date/Time: 7/11/21 1246		Company: <i>[Signature]</i>	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:	
ICE Present: ☒ Yes ☐ No		Custody Seal No.:		Custody Seals Intact: ☒ Yes ☐ No		Cooler Temperature(s) °C/ IR GUN #: 29.71C		06/21/2021			

EnviroTest Laboratories, LLC



315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

EnviroTest
Laboratories

Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 195423 386				
Client Contact: C Fischer		Phone: 845-255-1400 X1361		E-Mail: cfischer@ulsterboces.org rricks@saugerties.k12.ny.us								
Company: Saugerties CSD C/O Ulster BOCES				Analysis Requested				Page: 3 of 6				
Address: Call Box A		Due Date Requested:										
City: Saugerties		TAT Requested (days):						Preservation Codes: A - HCL L- EDA B - NaOH M - Sodium Sulfite C - Zn Acetate N - None D - Nitric Acid O - MCAA E - H2SO4 P - Other (specify) F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other:				
State, Zip: NY, 12477												
Phone: 845-255-1400 X1361		PO #:										
Email: cfischer@ulsterboces.org		PWS #:										
Project Name: Saugerties Central School District		Project #:										
Site: Cahill Elementary School		Additional Contacts:										
				Please Email Results to cfischer@ulsterboces.org and ricks@saugerties.k12.ny.us								
Sample Identification		Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead (DW 200.8)	Total Number of containers	Upon Receipt Preservation verified: Y / N
												Special Instructions/Note:
C31- Basement Girls Bathroom Right			3/26/21	615	G	DW				X		
C32- Basement Boys Bathroom Left			3/26/21	615	G	DW				X		
C33- Basement Boys Bathroom Right			3/26/21	615	G	DW				X		
C34- Basement Science lab			3/26/21	615	G	DW				X		
C35- Room 101			3/26/21	615	G	DW				X		
C36- 1R Bottle Filling Station			3/26/21	615	G	DW				X		
C37- Nurse Sink			3/26/21	615	G	DW				X		
C38- Nurse Toilet Room			3/26/21	615	G	DW				X		
C39- 1R Women Bathroom by the Office Left			3/26/21	615	G	DW				X		
C40- 1R Men Bathroom by the Office Left			3/26/21	615	G	DW				X		
C41- 1R Men Bathroom by the Office Right			3/26/21	615	G	DW				X		
C42- Office Kitchen Area Sink			3/26/21	615	G	DW				X		
C43- Office Toilet Room			3/26/21	615	G	DW				X		
C44- Spec Ed Office Bar Sink			3/26/21	615	G	DW				X		
C45- Room 114			3/26/21	615	G	DW				X		
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle												Container Type
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other												Container Size
Preservation Added Upon Receipt:			Date:		Time:		Sample # (s):					
Manufacturer/Lot #:												
Relinquished by: <i>[Signature]</i>			Date/Time: 4/14/21 1246		Company: <i>[Signature]</i>		Received by: <i>[Signature]</i>			Date/Time: 7/19/21 1246		Company: <i>[Signature]</i>
Relinquished by:			Date/Time:		Company:		Received by:			Date/Time:		Company:
Relinquished by:			Date/Time:		Company:		Received by:			Date/Time:		Company:
ICE Present: ☒ Yes ☐ No		Custody Seal No.:		Custody Seals Intact: ☒ Yes ☐ No		Cooler Temperature(s) °C/ IR GUN #: 29.9 °C		06/21/2021				

EnviroTest Laboratories

Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #:									
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail: cfischer@ulsterboces.org rricks@saugerties.k12.ny.us				195423 4 86									
Company: Saugerties CSD C/O Ulster BOCES				Analysis Requested						Page: 4 of 6							
Address: Call Box A		Due Date Requested:								Total Number of containers		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other: Upon Receipt Preservation verified: Y / N					
City: Saugerties		TAT Requested (days):															
State, Zip: NY, 12477																	
Phone: 845-2551400 X1361		PO #:															
Email: cfischer@ulsterboces.org		PWS #:															
Project Name: Saugerties Central School District		Project #:															
Site: Cahill Elementary School		Additional Contacts:															
Please Email Results to cfischer@ulsterboces.org and ricks@saugerties.k12.ny.us																	
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil,	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead (DW 200.8)								
C46- Room 138 Left		3/26/21	615	G	DW				X								
C47- Room 138 Left Center		3/26/21	615	G	DW				X								
C48- Room 138 Right Center		3/26/21	615	G	DW				X								
C49- Room 138 Right		3/26/21	615	G	DW				X								
C50- 1R Boys Bathroom by the Gym Left		3/26/21	615	G	DW				X								
C51- 1R Boys Bathroom by the Gym Right		3/26/21	615	G	DW				X								
C52- 1R Girls Bathroom by the Gym Left		3/26/21	615	G	DW				X								
C53- 1R Girls Bathroom by the Gym Right		3/26/21	615	G	DW				X								
C54- Room 201		3/26/21	615	G	DW				X								
C55- 2R Girls Bathroom Left		3/26/21	615	G	DW				X								
C56- 2R Girls Bathroom Right		3/26/21	615	G	DW				X								
C57- Room 203		3/26/21	615	G	DW				X								
C58- Room 205 Teachers Lounge		3/26/21	615	G	DW				X								
C59- Room 205 Faculty Bathroom		3/26/21	615	G	DW				X								
C60- Room 207		3/26/21	615	G	DW				X								
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle												P		Container Type			
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other												2		Container Size			
Preservation Added Upon Receipt:				Date:		Time:				Sample # (s):							
Relinquished by: 		Date/Time: 4/14/21 1246		Company: ulsterboces		Received by: 		Date/Time: 4/14/21 1246		Company: ET L							
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:							
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:							
ICE Present: ☒ Yes ☐ No		Custody Seal No.:		Custody Seals Intact: ☒ Yes ☐ No		Cooler Temperature(s) °C/ IR GUN #: 29.7°C								06/2			

EnviroTest Laboratories

Client Information		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #:							
Client Contact: C Fischer		Phone: 845-255-1400 X1361		E-Mail: cfischer@ulsterboces.org ricks@saugerties.k12.ny.us		195423 586							
Company: Saugerties CSD C/O Ulster BOCES				Page: 6 of 6									
Address: Call Box A		Due Date Requested:		Analysis Requested									
City: Saugerties		TAT Requested (days):		Preservation Codes:									
State, Zip: NY, 12477				A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate									
Phone: 845-2551400 X1361		PO #:		L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)									
Email: cfischer@ulsterboces.org		PWS #:											
Project Name: Saugerties Central School District		Project #:											
Site: Cahill Elementary School		Additional Contacts:		Other:									
Please Email Results to cfischer@ulsterboces.org and ricks@saugerties.k12.ny.us				Upon Receipt Preservation verified: Y / N									
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil,	Field, Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead (DW 200.8)	Total Number of containers			
C61- 2R Boys Bathroom Left		3/26/21	615	G	DW				X				
C62- 2R Boys Bathroom Right		3/26/21	615	G	DW				X				
C63- Room 209		3/26/21	615	G	DW				X				
C64- Room 211		3/26/21	615	G	DW				X				
C65- Room 229		3/26/21	615	G	DW				X				
C66- Room 231		3/26/21	615	G	DW				X				
C67- Room 235		3/26/21	615	G	DW				X				
C68- Room 233		3/26/21	615	G	DW				X				
C69- 3R Teacher Lounge		3/26/21	615	G	DW				X				
C70- 3R Toilet Room Teacher Lounge		3/26/21	615	G	DW				X				
C71- Room 303		3/26/21	615	G	DW				X				
C72- Room 319		3/26/21	615	G	DW				X				
C73- Room 305		3/26/21	615	G	DW				X				
C74- Room 317		3/26/21	615	G	DW				X				
C75- 3R Girls Bathroom Left		3/26/21	615	G	DW				X				
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle								P	Container Type				
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other								2	Container Size				
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):							
Manufacturer/Lot #:													
Relinquished by: <i>Cheryl</i>		Date/Time: 4/14/21 1246		Company: <i>ulsterboces</i>		Received by: <i>cr</i>		Date/Time: 4/14/21 1246		Company: <i>ETC</i>			
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:			
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:			
ICE Present: ☒ Yes ☐ No		Custody Seal No.:		Custody Seals Intact: ☒ Yes ☐ No		Cooler Temperature(s) °C/ IR GUN #: 24.9		Page 97 of 99					
06/2													

EnviroTest Laboratories

Client Information		Sampler: Randy Ricks		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 195423 6 #			
Client Contact: C Fischer		Phone:845-255-1400 X1361		E-Mail: cfischer@ulsterboces.org ricks@saugerties.k12.ny.us							
Company: Saugerties CSD C/O Ulster BOCES											
Address: Call Box A		Due Date Requested:		Analysis Requested							
City:Saugerties		TAT Requested (days):									
State, Zip: NY, 12477											
Phone: 845-2551400 X1361		PO #:									
Email: cfischer@ulsterboces.org		PWS #:									
Project Name: Saugerties Central School District		Project #:									
Site: Cahill Elementary School		Additional Contacts:									
Please Email Results to cfischer@ulsterboces.org and ricks@saugerties.k12.ny.us											
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil,	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead (DW 200.8)	Total Number of containers	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L- EDA M - Sodium Sulfitte N - None O - MCAA P - Other (specify) Other: Upon Receipt Preservation verified: Y / N
C76- 3R Girls Bathroom Center		3/26/21	615	G	DW	X			X		Special Instructions/Note:
C77- 3R Girls Bathroom Right		3/26/21	615	G	DW	X			X		
C78- Room 307		3/26/21	615	G	DW	X			X		
C79- Room 315		3/26/21	615	G	DW	X			X		
C80- 3R Boys Bathroom Left		3/26/21	615	G	DW	X			X		
C81- 3R Boys Bathroom Center		3/26/21	615	G	DW	X			X		
C82- 3R Boys Bathroom Right		3/26/21	615	G	DW	X			X		
C83- 3R Bottle Filling Station		3/26/21	615	G	DW	X			X		
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle										P	Container Type
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other										2	Container Size
Preservation Added Upon Receipt:		Date:	Time:		Sample # (s):						
Manufacturer/Lot #:		Date/Time:		Company	Received by:		Date/Time:		Company		
Relinquished by:		Date/Time:		Company	Received by:		Date/Time:		Company		
Relinquished by:		Date/Time:		Company	Received by:		Date/Time:		Company		
ICE Present: Δ Yes Δ No		Custody Seal No.:		Custody Seals Intact: Yes Δ No		Temperature(s) °C/ IR GUN #:		Page 98 of 99			

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-195423-1
SDG Number: Cahill Elementary School

Login Number: 195423

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	24.4 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	