

ANALYTICAL REPORT

Job Number: 420-195419-1

SDG Number: Mount Marion Elementary School

Job Description: Ulster BOCES

For:
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Attention: Christy Fischer



Designee for
Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
06/21/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-195419-1
SDG Number: Mount Marion Elementary School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-195419-1
SDG Number: Mount Marion Elementary School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-195419-1
SDG Number: Mount Marion Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195419-1	MM-31 Room 8	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-2	MM-32 Room 10	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-3	MM-33 Faculty Bathrom East Wing Right	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-4	MM-34 Faculty Bathrom East Wing Left	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-5	MM-35 Bottle Filling Station East Wing	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-6	MM-36 Girls Bathroom East Wing	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-7	MM-37 Nurse Office Toilet Room	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-8	MM-38 Nurs Office	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-9	MM-39 Cafeteria Handicap Bathroom	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-10	MM-40 Boys Room East Wing	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-11	MM-41 Audio Visual Room off of Library	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-12	MM-42 Kitchen Prep Left	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-13	MM-43 Kitchen Rinse Station	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-14	MM-44 Kitchen Prep Right	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-15	MM-45 Teacher's Lounge/ Staff Room	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-16	MM-16 Room 113	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-17	MM-17 6th Grade Boys Bathroom Left	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-18	MM-18 6th Grade Boys Bathroom Right	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-19	MM-19 6th Grade Girls Bathroom Left	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-20	MM-20 6th Grade Girls Bathroom Right	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-21	MM-21 Room 116	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-22	MM-22 Room 116 Toilet Room Left	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-23	MM-23 Room 116 Toilet Room Right	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-24	MM-24 Room 115	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-25	MM-25 Room 117	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-26	MM-26 Room 118	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-27	MM-27 Room 118 Toilet Room	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-28	MM-28 Bottle Filling Station West Wing	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-29	MM-29 Room 7	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-30	MM-30 Rom 9	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-46	MM-1 Custodial Sink	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-47	MM-2 Girls Bathroom West Wing by Custodial Room	Drinking Water	03/26/2021 0700	04/14/2021 1246

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-195419-1
SDG Number: Mount Marion Elementary School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195419-48	MM-3 Boys Bathroom West Wing by Custodial Room	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-49	MM-4 Room 101	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-50	MM-5 Room 102	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-51	MM-6 Room 103	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-52	MM-7 Room 104	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-53	MM-8 Room 105	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-54	MM-9 Room 107	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-55	MM-10 Room 106	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-56	MM-11 Room 108	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-57	MM-12 Room 109	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-58	MM-13 Room 111	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-59	MM-14 Room 110	Drinking Water	03/26/2021 0700	04/14/2021 1246
420-195419-60	MM-15 Room 112	Drinking Water	03/26/2021 0700	04/14/2021 1246

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-31 Room 8
Lab Sample ID: 420-195419-1

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2133	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-32 Room 10
Lab Sample ID: 420-195419-2

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2146	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	4.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-33 Faculty Bathrom East Wing Right
Lab Sample ID: 420-195419-3

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2149	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-34 Faculty Bathrom East Wing Left
Lab Sample ID: 420-195419-4

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2151	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-35 Bottle Filling Station East Wing
Lab Sample ID: 420-195419-5

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2153	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-36 Girls Bathroom East Wing
Lab Sample ID: 420-195419-6

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2155	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-37 Nurse Office Toilet Room
Lab Sample ID: 420-195419-7

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2157	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-38 Nurs Office
Lab Sample ID: 420-195419-8

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2200	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-39 Cafeteria Handicap Bathroom
Lab Sample ID: 420-195419-9

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2202	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-40 Boys Room East Wing
Lab Sample ID: 420-195419-10

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2204	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-41 Audio Visual Room off of Library
Lab Sample ID: 420-195419-11

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2210	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	9.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-42 Kitchen Prep Left
Lab Sample ID: 420-195419-12

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2215	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	6.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-43 Kitchen Rinse Station
Lab Sample ID: 420-195419-13

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2217	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	4.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-44 Kitchen Prep Right
Lab Sample ID: 420-195419-14

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2219	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	14	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-45 Teacher's Lounge/ Staff Room
Lab Sample ID: 420-195419-15

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2221	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-16 Room 113
Lab Sample ID: 420-195419-16

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2223	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	5.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-17 6th Grade Boys Bathroom Left
Lab Sample ID: 420-195419-17

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2226	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-18 6th Grade Boys Bathroom Right
Lab Sample ID: 420-195419-18

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2228	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-19 6th Grade Girls Bathroom Left
Lab Sample ID: 420-195419-19

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2230	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	5.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-20 6th Grade Girls Bathroom Right
Lab Sample ID: 420-195419-20

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2237	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-21 Room 116
Lab Sample ID: 420-195419-21

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2239	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-22 Room 116 Toilet Room Left
Lab Sample ID: 420-195419-22

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2247	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-23 Room 116 Toilet Room Right
Lab Sample ID: 420-195419-23

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2250	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-24 Room 115
Lab Sample ID: 420-195419-24

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2252	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-25 Room 117
Lab Sample ID: 420-195419-25

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2254	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-26 Room 118
Lab Sample ID: 420-195419-26

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2256	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-27 Room 118 Toilet Room
Lab Sample ID: 420-195419-27

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/15/2021 2303	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-28 Bottle Filling Station West Wing
Lab Sample ID: 420-195419-28

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 2232	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-29 Room 7
Lab Sample ID: 420-195419-29

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 2234	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-30 Rom 9
Lab Sample ID: 420-195419-30

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 2237	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	5.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-1 Custodial Sink
Lab Sample ID: 420-195419-46

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 2239	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	12	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-2 Girls Bathroom West Wing by Custodial
Lab Sample ID: 420-195419-47

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 2243	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-3 Boys Bathroom West Wing by Custodial
Lab Sample ID: 420-195419-48

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 2245	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	1.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-4 Room 101
Lab Sample ID: 420-195419-49

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 2247	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	5.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-5 Room 102
Lab Sample ID: 420-195419-50

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/11/2021 2250	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.9	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-6 Room 103
Lab Sample ID: 420-195419-51

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0827	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	7.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-7 Room 104
Lab Sample ID: 420-195419-52

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0829	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	6.2	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-8 Room 105
Lab Sample ID: 420-195419-53

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0832	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	12	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-9 Room 107
Lab Sample ID: 420-195419-54

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0834	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-10 Room 106
Lab Sample ID: 420-195419-55

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0836	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-11 Room 108
Lab Sample ID: 420-195419-56

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0838	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-12 Room 109
Lab Sample ID: 420-195419-57

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0851	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-13 Room 111
Lab Sample ID: 420-195419-58

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0854	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	2.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-14 Room 110
Lab Sample ID: 420-195419-59

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0856	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-195419-1
Sdg Number: Mount Marion Elementary School

Client Sample ID: MM-15 Room 112
Lab Sample ID: 420-195419-60

Date Sampled: 03/26/2021 0700
Date Received: 04/14/2021 1246
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/12/2021 0858	
Prep Method: 200.7/200.8			Date Prepared:	06/08/2021 1000	
Pb	3.2	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: Mount Marion Elementary School

Lab Section	Qualifier	Description
Metals	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: Mount Marion Elementary School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Settable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: Mount Marion Elementary School

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-195419-1

SDG Number: Mount Marion Elementary School

Login Number: 195419

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	24.4 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	True	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	