



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

GANNETT FLEMING, INC.

Project Name: IHS

ERIC BUZZA
FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE
PITTSBURGH, PA 15220

Project / PO Number: IHS
Received: 08/18/2022
Reported: 08/24/2022

Analytical Testing Parameters

Table with sample details: Client Sample ID: Office Men Fountain, Sample Matrix: Drinking Water, Lab Sample ID: 2084203-01, Collected By: Eric Buzza, Collection Date: 08/18/2022 8:03

Table with analytical results: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Lead result <0.000400 mg/L

Table with sample details: Client Sample ID: Office Women Fountain, Sample Matrix: Drinking Water, Lab Sample ID: 2084203-02, Collected By: Eric Buzza, Collection Date: 08/18/2022 8:04

Table with analytical results: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Lead result <0.000400 mg/L

Table with sample details: Client Sample ID: Security Desk Fountain, Sample Matrix: Drinking Water, Lab Sample ID: 2084203-03, Collected By: Eric Buzza, Collection Date: 08/18/2022 8:05

Table with analytical results: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Lead result <0.000400 mg/L

Table with sample details: Client Sample ID: Nurses Desk Sink, Sample Matrix: Drinking Water, Lab Sample ID: 2084203-04, Collected By: Eric Buzza, Collection Date: 08/18/2022 8:01

Table with analytical results: Metals Total by ICPMS, Method: EPA 200.8, Rv. 5.4 (1994), Lead result 0.00845 mg/L



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Client Sample ID: Aux Gym Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:00
Lab Sample ID: 2084203-05	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1714	08/22/22 1714	SEV

Client Sample ID: Pool Left Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 9:03
Lab Sample ID: 2084203-06	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000557	0.0150	0.000400	mg/L		08/22/22 1716	08/22/22 1716	SEV

Client Sample ID: Pool Right Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 9:04
Lab Sample ID: 2084203-07	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00108	0.0150	0.000400	mg/L		08/22/22 1718	08/22/22 1718	SEV

Client Sample ID: Weight Room Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 9:01
Lab Sample ID: 2084203-08	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1719	08/22/22 1719	SEV

Client Sample ID: Training Room Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 9:00
Lab Sample ID: 2084203-09	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1721	08/22/22 1721	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Client Sample ID: Training Room Ice	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:59
Lab Sample ID: 2084203-10	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1723	08/22/22 1723	SEV

Client Sample ID: ROTC Men Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:07
Lab Sample ID: 2084203-11	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1730	08/22/22 1730	SEV

Client Sample ID: Cafe B Front Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:56
Lab Sample ID: 2084203-12	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1737	08/22/22 1737	SEV

Client Sample ID: Cafe C Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:34
Lab Sample ID: 2084203-13	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0117	0.0150	0.000400	mg/L		08/22/22 1739	08/22/22 1739	SEV

Client Sample ID: 140 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:52
Lab Sample ID: 2084203-14	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1741	08/22/22 1741	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Client Sample ID: 126 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:51
Lab Sample ID: 2084203-15	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00119	0.0150	0.000400	mg/L		08/22/22 1743	08/22/22 1743	SEV

Client Sample ID: 124 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:49
Lab Sample ID: 2084203-16	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1745	08/22/22 1745	SEV

Client Sample ID: Cafe A Back Fountain and Bottle Filler	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:31
Lab Sample ID: 2084203-17	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1746	08/22/22 1746	SEV

Client Sample ID: Cafe A Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:30
Lab Sample ID: 2084203-18	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00599	0.0150	0.000400	mg/L		08/22/22 1748	08/22/22 1748	SEV

Client Sample ID: 115 Sink 1	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:17
Lab Sample ID: 2084203-20	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0823	0.0150	0.000400	mg/L		08/22/22 1750	08/22/22 1750	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Client Sample ID: 108 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:14
Lab Sample ID: 2084203-21	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1752	08/22/22 1752	SEV

Client Sample ID: Wood Shop Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:12
Lab Sample ID: 2084203-22	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.0150	0.000400	mg/L		08/22/22 1804	08/22/22 1804	SEV

Client Sample ID: 103 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:11
Lab Sample ID: 2084203-23	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1811	08/22/22 1811	SEV

Client Sample ID: Lounge Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:09
Lab Sample ID: 2084203-24	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00252	0.0150	0.000400	mg/L		08/22/22 1813	08/22/22 1813	SEV

Client Sample ID: JROTC 1 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:54
Lab Sample ID: 2084203-25	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00104	0.0150	0.000400	mg/L		08/22/22 1815	08/22/22 1815	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Client Sample ID: Cafe D Back Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:40
Lab Sample ID: 2084203-26	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1817	08/22/22 1817	SEV

Client Sample ID: 207 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:39
Lab Sample ID: 2084203-27	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L			08/22/22 1819	SEV

Client Sample ID: English WRR Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:37
Lab Sample ID: 2084203-28	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1820	08/22/22 1820	SEV

Client Sample ID: Cafe C Back Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:35
Lab Sample ID: 2084203-29	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1822	08/22/22 1822	SEV

Client Sample ID: 246 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:44
Lab Sample ID: 2084203-30	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1824	08/22/22 1824	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Client Sample ID: 243 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:45
Lab Sample ID: 2084203-31	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/22/22 1826	08/22/22 1826	SEV

Client Sample ID: Rm 18 Sink 1	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:23
Lab Sample ID: 2084203-32	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00106	0.0150	0.000400	mg/L		08/23/22 0758	08/23/22 0758	SEV

Client Sample ID: Rm 18 Sink 2	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:24
Lab Sample ID: 2084203-33	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000661	0.0150	0.000400	mg/L		08/23/22 0806	08/23/22 0806	SEV

Client Sample ID: Rm 18 Sink 3	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:25
Lab Sample ID: 2084203-34	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000779	0.0150	0.000400	mg/L		08/23/22 0807	08/23/22 0807	SEV

Client Sample ID: Rm 18 Sink 4	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:26
Lab Sample ID: 2084203-35	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000705	0.0150	0.000400	mg/L		08/23/22 0809	08/23/22 0809	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Client Sample ID: Rm 18 Sink 5	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:27
Lab Sample ID: 2084203-36	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000748	0.0150	0.000400	mg/L		08/23/22 0811	08/23/22 0811	SEV

Client Sample ID: Rm 18 Sink 6	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:28
Lab Sample ID: 2084203-37	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00101	0.0150	0.000400	mg/L		08/23/22 0813	08/23/22 0813	SEV

Client Sample ID: Rm 115 Sink 2	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:18
Lab Sample ID: 2084203-38	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00175	0.0150	0.000400	mg/L		08/23/22 0815	08/23/22 0815	SEV

Client Sample ID: Rm 115 Sink 3	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:19
Lab Sample ID: 2084203-39	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00235	0.0150	0.000400	mg/L		08/23/22 0816	08/23/22 0816	SEV

Client Sample ID: Rm 115 Sink 4	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 08/18/2022 8:20
Lab Sample ID: 2084203-40	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00232	0.0150	0.000400	mg/L		08/23/22 0818	08/23/22 0818	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Client Sample ID:	Rm 115 Sink 5	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	08/18/2022 8:21
Lab Sample ID:	2084203-41		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00110	0.0150	0.000400	mg/L		08/23/22 0820	08/23/22 0820	SEV

Client Sample ID:	Rm 115 Sink 6	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	08/18/2022 8:22
Lab Sample ID:	2084203-42		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00175	0.0150	0.000400	mg/L		08/22/22 1615	08/22/22 1615	SEV

Client Sample ID:	Rm 18 Sink7	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	08/18/2022 8:29
Lab Sample ID:	2084203-43		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00112	0.0150	0.000400	mg/L		08/22/22 1617	08/22/22 1617	SEV

Client Sample ID:	Cafe D Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	08/18/2022 8:42
Lab Sample ID:	2084203-44		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00343	0.0150	0.000400	mg/L		08/22/22 1619	08/22/22 1619	SEV

Client Sample ID:	Cafe B Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	08/18/2022 8:58
Lab Sample ID:	2084203-45		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00967	0.0150	0.000400	mg/L		08/22/22 1620	08/22/22 1620	SEV

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2084203

Definitions

mg/L: Milligrams per Liter
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
02-00257

PA Department of Environmental Protection
PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at https://www.microbac.com/standard-terms-conditions.

Reviewed and Approved By:

Handwritten signature: Carolyn M. Vollentine

Carolyn Vollentine
Service Center Manager
Reported: 08/24/2022 20:23

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com

MICROBAC 100 Marshall Dr., Warrendale, PA 15085 | 724.772.0610 p | 724.772.1686 f



Gannett Fleming, Inc. - Pittsburgh, PA
PM: Carolyn Volentine

RECORD

Lab Report Address
Client Name: GANNETT FLEMING

Invoice Address
Client Name: STATE

Turnover to:
 Routine (5 to 7 business days)
 RUSH* (notify lab)

Temperature Upon Receipt (C)
Therm ID
Holding Time

7/14/02

Address: FOSTER PLAZA 8, SUITE 400 750 HIGHLAND AVE

Address:

(needed by)
Report Type

Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

City, State, Zip: PITTSBURGH, PA 15220

City, State, Zip:

Level 1 Level 2 Level 3 Level 4 EDD

Contact: ERIC HUTZLA

Contact:

Level 1 Level 2 Level 3 Level 4 EDD

Telephone No.: 412.503.4343

Telephone No.:

Send Report via: Mail Fax e-mail (address) chuz@ghm.com

Send Invoice via: Mail Fax e-mail (address) s_h_u_z_l_a@g_f_l_e_m_i_n_g.com

Project: BUTLER AREA SCHOOL DISTRICT

Location:

PO No.:

Compliance Monitoring? Yes No
Agency/Program

Sampled by (PRINT): ERIC HUTZLA

Sampler Signature: *E-H*

Sampler Phone No.: 412.503.4343

HNO3 Preserved
Date: 8-19-02
Time: 11:00
Initials: CEI

* Matrix Types: Soil/Sed (S), Sludge, Oil Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify):
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	LEAD	Additional Notes
SEE ATTACHED		8/18/02			AW	G	U	✓	

Possible Hazard Identification: Hazardous Non-Hazardous Reactive Non-Reactive

Relinquished By (signature): *E-H* Date/Time: 8/18/02 1042
 Relinquished By (signature): *E-H* Date/Time: 8/18/02 1042
 Relinquished By (signature): *[Signature]* Date/Time: 8/18/02 1042
 Relinquished By (signature): *[Signature]* Date/Time: 8/18/02 1042



2 0 8 4 2 0 3

Gannett Fleming, Inc. - Pittsburgh, PA

PM: Carolyn Vollentine

Butler Area School District

Intermediate High School 42

Location	Date	Time
1 Office Men Fountain	8/18/22	803
2 Office Women Fountain		804
3 Security Desk Fountain		805
4 Nurse's Desk Sink		805
5 Aux Gym Fountain		807
6 Pool Left Fountain		903
7 Pool Right Fountain		904
8 Weight Room Fountain		907
9 Training Room Sink		900
10 Training Room Ice		859
11 ROTC 111 Men Fountain		807
12 Café B Front Fountain		856
13 Café A Sink Café C Sink		834
14 140 L Fountain		852
15 126 Fountain		851
16 124 Fountain		844
17 Café A Back Fountain f Botkyh 2. Kos		831
18 Café A Sink Café C Sink		830
19 115 Fountain		832
20 115 Sink 1		817
21 108 Fountain		814
22 Wood Shop Fountain		812
23 103 Fountain		811
24 Lounge Sink		809
25 JROTC 1 Fountain		854
26 Café D Back Fountain		840
27 207 Fountain		839
28 English WRR Fountain		837
29 Café C Back Fountain		835
30 246 Fountain		844
31 243 Fountain		845
32 Rm 18 Sink 1		823
33 Rm 18 Sink 2		824
34 Rm 18 Sink 3		825
35 Rm 18 Sink 4		826
36 Rm 18 Sink 5		827
37 Rm 18 Sink 6		828
38 Rm 115 Sink 2		818
39 Rm 115 Sink 3		819
40 Rm 115 Sink 4		820
41 Rm 115 Sink 5		821
42 Rm 115 Sink 6		822
43 Rm 18 Sink 7		829
44 Café D Sink 15		842
45 Café B Sink		850

18 Café A Sink
 NO sample
 CK 8/19