



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2083991

GANNETT FLEMING, INC.

ERIC BUZZA
FOSTER PLAZA III- SUITE 200 601 HOLIDAY DRIVE
PITTSBURGH, PA 15220

Project Name: Analytical Services

Project / PO Number: N/A
Received: 08/16/2022
Reported: 08/26/2022

Analytical Testing Parameters

Client Sample ID: Maintenance Garage Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-01

Collected By: Eric Buzza
Collection Date: 08/16/2022 7:58

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00268	0.0150	0.000400	mg/L		08/19/22 1629	08/19/22 1629	SEV

Client Sample ID: Maintenance Store Room Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-02

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:00

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1634	08/19/22 1634	SEV

Client Sample ID: Maintenance Lounge Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-03

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:01

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00538	0.0150	0.000400	mg/L		08/19/22 1636	08/19/22 1636	SEV

Client Sample ID: Auditorium Fountain 1
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-04

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:03

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000762	0.0150	0.000400	mg/L		08/19/22 1638	08/19/22 1638	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2083991

Client Sample ID: Auditorium Bottle Filler

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-05

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:04

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1640	08/19/22 1640	SEV

Client Sample ID: Food Service Prep Sink 2

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-06

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:06

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0254	0.0150	0.000400	mg/L		08/19/22 1641	08/19/22 1641	SEV

Client Sample ID: Serving Line Sink

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-07

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:07

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0480	0.0150	0.000400	mg/L		08/19/22 1643	08/19/22 1643	SEV

Client Sample ID: Cafe Fountain 1 Bottle Filler

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-08

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:52

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1645	08/19/22 1645	SEV

Client Sample ID: Cafe Fountain 2 Bottle Filler

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-09

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:11

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1647	08/19/22 1647	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2083991

Client Sample ID: Nurses Office Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-10

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:16

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0316	0.0150	0.000400	mg/L		08/19/22 1648	08/19/22 1648	SEV

Client Sample ID: Nurses Kitchen Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-11

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:17

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0198	0.0150	0.000400	mg/L		08/19/22 1654	08/19/22 1654	SEV

Client Sample ID: SHS Office Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-12

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:19

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.203	0.0150	0.00200	mg/L		08/22/22 1321	08/22/22 1321	SEV

Client Sample ID: 100-1 Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-13

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:22

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00119	0.0150	0.000400	mg/L		08/19/22 1701	08/19/22 1701	SEV

Client Sample ID: 100-2 Fountain and Bottle Filler
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-14

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:24

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1703	08/19/22 1703	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2083991

Client Sample ID: 200-1 Fountain and Bottle Filler

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-15

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:27

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1705	08/19/22 1705	SEV

Client Sample ID: 300-1 Fountain and Bottle Filler

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-16

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:45

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1706	08/19/22 1706	SEV

Client Sample ID: 300-2 Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-17

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:47

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000922	0.0150	0.000400	mg/L		08/19/22 1708	08/19/22 1708	SEV

Client Sample ID: Sink

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-18

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:49

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00626	0.0150	0.000400	mg/L		08/19/22 1710	08/19/22 1710	SEV

Client Sample ID: 400-1 Fountain and Bottle Filler

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-19

Collected By: Eric Buzza

Collection Date: 08/16/2022 8:30

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1712	08/19/22 1712	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2083991

Client Sample ID: 400-2 Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-20

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:31

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00503	0.0150	0.000400	mg/L		08/19/22 1713	08/19/22 1713	SEV

Client Sample ID: 400-3 Fountain Lower Level and Bottle Filler
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-21

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:34

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1724	08/19/22 1724	SEV

Client Sample ID: 400-4 Lower Level
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-22

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:35

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0153	0.0150	0.000400	mg/L		08/19/22 1730	08/19/22 1730	SEV

Client Sample ID: Gm Annex Upper Floor Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-23

Collected By: Eric Buzza
Collection Date: 08/16/2022 9:07

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1731	08/19/22 1731	SEV

Client Sample ID: Gym Annex Training Room Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-24

Collected By: Eric Buzza
Collection Date: 08/16/2022 9:10

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00123	0.0150	0.000400	mg/L		08/19/22 1733	08/19/22 1733	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2083991

Client Sample ID: Gym Annex Training Room Ice

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-25

Collected By: Eric Buzza

Collection Date: 08/16/2022 9:08

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.0150	0.000400	mg/L		08/19/22 1735	08/19/22 1735	SEV

Client Sample ID: Gym Annex Weight Room Fountain

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-26

Collected By: Eric Buzza

Collection Date: 08/16/2022 9:11

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000942	0.0150	0.000400	mg/L		08/22/22 1323	08/22/22 1323	SEV

Client Sample ID: Gym Annex Lower Floor Locker Room Fountain and Bottle Filler

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-27

Collected By: Eric Buzza

Collection Date: 08/16/2022 9:13

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00129	0.0150	0.000400	mg/L		08/22/22 1325	08/22/22 1325	SEV

Client Sample ID: Gym Fountain 1

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-28

Collected By: Eric Buzza

Collection Date: 08/16/2022 9:22

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00107	0.0150	0.000400	mg/L		08/22/22 1326	08/22/22 1326	SEV

Client Sample ID: Gym Fountain 2

Sample Matrix: Drinking Water

Lab Sample ID: 2083991-29

Collected By: Eric Buzza

Collection Date: 08/16/2022 9:23

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00223	0.0150	0.000400	mg/L		08/22/22 1328	08/22/22 1328	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2083991

Client Sample ID: 603-A Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-30

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:14

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0593	0.0150	0.000400	mg/L		08/22/22 1330	08/22/22 1330	SEV

Client Sample ID: 603-B Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-31

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:15

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0584	0.0150	0.000800	mg/L		08/24/22 0846	08/24/22 1551	SEV

Client Sample ID: Home Economics 203 Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-32

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:43

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00250	0.0150	0.000400	mg/L		08/22/22 1332	08/22/22 1332	SEV

Client Sample ID: 422-A Faculty Sink
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-33

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:37

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00213	0.0150	0.000400	mg/L		08/22/22 1339	08/22/22 1339	SEV

Client Sample ID: Boiler Room Fountain
Sample Matrix: Drinking Water
Lab Sample ID: 2083991-34

Collected By: Eric Buzza
Collection Date: 08/16/2022 8:57

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00300	0.0150	0.000400	mg/L		08/22/22 1341	08/22/22 1341	SEV

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

2083991

Definitions

mg/L: Milligrams per Liter
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
02-00257

PA Department of Environmental Protection
PADEP Accreditation by Rule

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:


Tina Sharer
Administration
Reported: 08/26/2022 12:04

Microbac Laboratories, Inc.

100 Marshall Drive | Warrendale, PA 15086 | 724-772-0610 p | www.microbac.com

Page 8 of 14

MICROBAC 100 Marshall Dr., Warendale, PA 15086 | 724.772.0610 P | 724.772.1686 F



Gannett Fleming, Inc. - Pittsburgh, PA
PM: Carolyn Volentine

Lab Report Address

Client Name: **SAVANT**

Address: **FOSTER PLAZA 8, SUITE 400 730 HOLLIDAY DR**

City, State, Zip: **PITTSBURGH, PA 15220**

Contact: **ERIK ROZZA**

Telephone No.: **412.303.1343**

Send Report via: ☒ Mail ☐ Fax ☐ e-mail (address) **chuz@ghut.com**

Project: **BUTLER AREA SCHOOL DISTRICT**

Sampled by (PRINT): **SAVANT**

Location:

119th School

PO No:

Sampler Signature: **[Signature]**

Sampler Phone No: **[Signature]**

Send Invoice via: ☒ Mail ☐ Fax ☐ e-mail (address) **chuz@ghut.com**

Compliance Monitoring? ☒ Yes ☐ No
Agency/Program

Turnaround Time

☒ Routine (5 to 7 business days)
☐ RUSH* (notify lab)

(needed by)

Report Type

Temperature Upon Receipt (°C)
Therm ID: **1402**
Holding Time: **176**
Samples Received on Ice? ☒ Yes ☐ No ☐ N/A
Custody Seals Intact? ☒ Yes ☐ No ☐ N/A

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (Specify)
Preservative Types: (1) HNO₃, (2) H₂SO₄, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (10) Unpreserved

REQUESTED ANALYSIS

HNO₃ Preserved
Date: **8-18-20**
Time: **0930**
Initials: **CET**

Lab ID

Date Collected

Time Collected

No. of Containers

Matrix

Grab / Comp

Preservative Type #

LEAD

Additional Notes

SEE ATTACHED

Possible Hazard Identification

☒ Hazardous

☐ Non-Hazardous

☐ Radioactive

Sample Disposition

☒ Dispose as appropriate

☐ Return

☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Butler Area School District
High School 52

Location	Date	Time
Maintenance Garage Fountain	8/16/23	2:58
Maintenance Store Room Fountain		3:00
Maintenance Lounge Sink		3:01
Auditorium Fountain 1		3:04
Auditorium Fountain 2		3:04
Auditorium Fountain 3		3:04
Auditorium Fountain 4		3:04
Auditorium Fountain 5		3:06
Food Service Prep Sink 2		3:07
Food Service Sink		3:07
Serving Line Sink		3:07
Café Fountain 1 + Bottle Filler 8		3:07
Café Fountain 2 + Bottle Filler 9		3:07
Café Fountain 3		3:07
Café Fountain 4		3:07
Nurses Office Sink		3:10
Nurses Kitchen Sink		3:10
SHS Office Sink		3:19
100-1 Fountain		3:22
100-2 Fountain		3:22
100 Wing Fountain 13		3:24
Cons. Serv. Sink		3:27
200-1 Fountain		3:27
300-1 Fountain		3:45
300-2 Fountain		3:47
300 Wing Fountain 5		3:49
306 Sink		3:49
200-2 Fountain		3:50
400-1 Fountain + Bottle Filler 19		3:51
400-2 Fountain + Bottle Filler 20		3:51
400-3 Fountain		3:54
400-4 Fountain		3:55
Lower 400 Fountain 11		3:57
Gym Annex Upper Floor Fountain		3:57
Gym Annex Training Room Sink		3:57
Gym Annex Training Room Ice		3:57
Gym Annex Weight Room Fountain		3:57
Gym Annex Lower Floor Locker Room Fountain		3:57
Gym Fountain 1		3:57
Gym Lobby Fountain + 24		3:57
Gym Lobby Fountain 2		3:57
Gym Rear Hall Fountain		3:57

Boys Varsity Locker Room Fountain	8/15/22	1
Swimming Pool Fountain		1
Boys Main Locker Room Fountain		1
Gym Training Room Sink		1
Gym Training Room Ice		1
Gym Weight Room Fountain		1
Gym Main Locker Room Fountain		1
603-A Sink	30	212
603-B Sink	31	215
Home Economics 203 Sink	32	243
W22-A Faculty Sink 33		
Boys Room Fountain 34		
8/15/22		
837		
837		
857		

MICROBAC 100 Marshall Dr., Warrendale, PA 15085 | 724.772.0610 P | 724.772.1686 F

Gannett Fleming, Inc. - Pittsburgh, PA

PM: Carolyn Volentine



Lab Report Address

Client Name: GANNETT FLEMING

Address: POSTER PLAZA 8, SUITE 400 750 HOLLYWAY DR

City, State, Zip: PITTSBURGH, PA 15220

Contact: ERIC RUZZA

Telephone No.: 412.503.4343

Send Report via:

☒ Mail ☒ Fax ☐ e-mail (address) shuzha@microbac.com

Project: BUTLER AREA SCHOOL DISTRICT

Location:

PO No.:

Sampled by (PRINT): ERIC RUZZA

Sampler Signature:

Sampler Phone No.:

Compliance Monitoring? ☒ Yes ☐ No
Agency/Program

Turnaround Time

☐ Routine (5 to 7 business days)
☐ RUSH* (notify lab)

Temperature Upon Receipt (°C)
Therm ID
Holding Time

(needed by)

Samples Received on Ice? ☒ Yes ☐ No ☐ N/A

Report Type ☒ Results Only ☐ Level 1 ☐ Level 2 ☐ Level 3 ☐ Level 4 ☐ EDD

Custody Seals Intact? ☒ Yes ☐ No ☐ N/A

* Matrix Types: Soil/Solid (S), Sludge, Oil, WIPA, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (10) Unpreserved

REQUESTED ANALYSIS

HNO3 Preserved
Date: 8-18-22
Time: 0930
Initials: CET

Lab ID

Client Sample ID

Date Collected

Time Collected

No. of Containers

Matrix

Grab / Comp

Preservative Type #

LEAD

Additional Notes

SEE ATTACHED

8/18/22

DWC

Possible Hazard Identification

☒ Hazardous ☐ Non-hazardous ☐ Reactive

Sample Disposition

☐ Dispose as appropriate ☐ Return ☐ Archive

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Location	Date	Time
Maintenance Garage Fountain 1	8/16/22	750
Maintenance Store Room Fountain 2		800
Maintenance Lounge Sink 3		801
Auditorium Fountain 1 4		802
Auditorium Fountain 2 Bottle Filler 5		803
Auditorium Fountain 3		804
Auditorium Fountain 4		—
Auditorium Fountain 5		—
Food Service Prep Sink 6		806
Food Service Sink		—
Serving Line Sink 7		807
Café Fountain 1 + Bottle Filler 8		852
Café Fountain 2 Bottle Filler 9		811
Café Fountain 3		—
Café Fountain 4		—
Nurses Office Sink 10		816
Nurses Kitchen Sink 11		846 817
SHS Office Sink 12		819
100-1 Fountain 13		822
100-2 Fountain + Bottle Filler 14		824
100 Wing Fountain 13		—
Cons Serv Sink		—
200-1 Fountain + Bottle Filler 15		827
300-1 Fountain + Bottle Filler 16		845
300-2 Fountain 17		847
300 Wing Fountain 5		—
306 Sink 18		849
200-2 Fountain		—
400-1 Fountain + Bottle Filler 19		830
400-2 Fountain + Bottle Filler 20		831
400-3 Fountain Lower Level + Bottle Filler 21		834
400-4 Fountain Lower Level 22		835
Lower 400 Fountain 11		—
Gym Annex Upper Floor Fountain 23		907
Gym Annex Training Room Sink 24		910
Gym Annex Training Room Ice 25		908
Gym Annex Weight Room Fountain 26		911
Gym Annex Lower Floor Locker Room Fountain + Bottle Filler 27		913
Gym Fountain 1 28		922
Gym Lobby Fountain + 29 Gym Fountain 2 as per container 30		925
Gym Lobby Fountain 2	8/17/22	—
Gym Rear Hall Fountain		—

Boys Varsity Locker Room Fountain	8/56/28	—
Swimming Pool Fountain		—
Boys Main Locker Room Fountain		—
Gym Training Room Sink		—
Gym Training Room Ice		—
Gym Weight Room Fountain		—
Gym Main Locker Room Fountain		—
603-A Sink 30		812
603-B Sink 31		815
Home Economics 203 Sink 32		843

422-A Faculty Sink 33
Boiler Room Fountain 34

837
857