



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER


Client Name: Woodburn School District
1390 Meridian Drive
Woodburn, OR 97071

Reference Number: **16-16116**

Project: Nellie

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
County:

Analyst: mvp
Date Received: 7/6/2016
Report Date: 7/20/2016
Approved By: bj
Authorized by:



Colin P. O'Dwyer
Chemist/Microbiologist

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_38808	7/6/2016	Room 17	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
16_38809	7/6/2016	Staff Room	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_38810	7/6/2016	Room 18	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
16_38811	7/6/2016	Room 19	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_38812	7/6/2016	Kinder Hallway Tall Fountain	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_38813	7/6/2016	Kinder Hallway Short Fountain	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_38814	7/6/2016	Room 2	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
16_38815	7/6/2016	Room 3	1030	LEAD	0.011	mg/L	0.015	0.001	200.8	4072	
16_38816	7/6/2016	Room 5	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
16_38817	7/6/2016	Room 6	1030	LEAD	0.009	mg/L	0.015	0.001	200.8	4072	
16_38818	7/6/2016	Room 7	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
16_38819	7/6/2016	Library Hallway Tall Fountain	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_38820	7/6/2016	Library Hallway Short Fountain	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_38821	7/6/2016	Room 9	1030	LEAD	0.005	mg/L	0.015	0.001	200.8	4072	
16_38822	7/6/2016	Room 10	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
16_38823	7/6/2016	Room 11	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
16_38824	7/6/2016	Room 13	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_38825	7/6/2016	Room 12	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
16_38826	7/6/2016	Room 14	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
16_38827	7/6/2016	Room 15	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_38828	7/6/2016	Cafeteria	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
16_38829	7/6/2016	Kitchen Steamer - Back	1030	LEAD	0.010	mg/L	0.015	0.001	200.8	4072	
16_38830	7/6/2016	Kitchen Steamer - Back	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_38831	7/6/2016	Kitchen Triple Sink	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
16_38832	7/6/2016	Kitchen Triple Sink	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.