



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)  
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

## INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Woodburn School District  
1390 Meridian Drive  
Woodburn, OR 97071

Reference Number: **16-16111**  
Project: Lincoln

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
County:

Analyst: mvp  
Date Received: 7/6/2016  
Report Date: 7/21/2016  
Approved By: bj  
Authorized by:

Thanh B Phan  
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_38774	7/6/2016	L1 - Room 1	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_38775	7/6/2016	L2 - Room 2	1030	LEAD	0.030	mg/L	0.015	0.001	200.8	4072	
16_38776	7/6/2016	L3 - Hallway	1030	LEAD	0.007	mg/L	0.015	0.001	200.8	4072	
16_38777	7/6/2016	L4 - Office	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_38778	7/6/2016	L5 - Office	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_38779	7/6/2016	L6 - Room 6	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_38780	7/6/2016	L10 - Room 10	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_38781	7/6/2016	L11 - Hallway	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_38782	7/6/2016	L12 - Hallway	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_38783	7/6/2016	L13 - Room 14	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_38784	7/6/2016	L14 - Room 16	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_38785	7/6/2016	L15 - Room 18	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_38786	7/6/2016	L16 - Hallway	1030	LEAD	0.040	mg/L	0.015	0.001	200.8	4072	
16_38787	7/6/2016	L17 - Room 19	1030	LEAD	0.008	mg/L	0.015	0.001	200.8	4072	
16_38788	7/6/2016	L18 - Room 20	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_38789	7/6/2016	L19 - Room 17	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_38790	7/6/2016	L20 - Room 15	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.

## INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_38791	7/6/2016	L21 - Hallway	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_38792	7/6/2016	L22 - Hallway	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_38793	7/6/2016	L23 - Staff Lounge	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_38794	7/6/2016	L24 - Staff Lounge	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_38795	7/6/2016	L25 - Kitchen	1030	LEAD	0.006	mg/L	0.015	0.001	200.8	4072	
16_38796	7/6/2016	L26 - Kitchen	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_38797	7/6/2016	L27 - Kitchen	1030	LEAD	0.003	mg/L	0.015	0.001	200.8	4072	
16_38798	7/6/2016	L28 - Kitchen	1030	LEAD	0.013	mg/L	0.015	0.001	200.8	4072	
16_38799	7/6/2016	L29 - Kitchen	1030	LEAD	0.038	mg/L	0.015	0.001	200.8	4072	
16_38800	7/6/2016	L30 - Cafeteria	1030	LEAD	0.004	mg/L	0.015	0.001	200.8	4072	
16_38801	7/6/2016	L31 - Hallway	1030	LEAD	0.234	mg/L	0.015	0.001	200.8	4072	
16_38802	7/6/2016	L32 - Gym	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	
16_38803	7/6/2016	L33 - Room 42	1030	LEAD	0.002	mg/L	0.015	0.001	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

**These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.**