



Burlington, WA Corporate Laboratory (a)  
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)  
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)  
540 SW Third Street - Corvallis, OR 97333 - 541.753.4946

Bend, OR Microbiology (e)  
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425


## INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Woodburn School District  
1390 Meridian Drive  
Woodburn, OR 97071

Reference Number: **16-15908**  
Project: Valor

System Name:  
System ID Number:  
DWP Source Number:  
Multiple Sources:  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
County:

Analyst: mvp  
Date Received: 7/6/2016  
Report Date: 7/20/2016  
Approved By: bj  
Authorized by:

  
Lawrence J Henderson, PhD  
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_37936	7/6/2016	Girl's Locker Room	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37937	7/6/2016	Boy's Locker Room	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37938	7/6/2016	VA Gym S Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37939	7/6/2016	VA Gym N Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37940	7/6/2016	VA Cafe W Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37941	7/6/2016	VA Cafe Middle Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37942	7/6/2016	VA Cafe E Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37943	7/6/2016	VA Band/Music	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37944	7/6/2016	A6	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37945	7/6/2016	Office Filter Water	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37946	7/6/2016	Staff Room Water Filter	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37947	7/6/2016	Staff Room Sink	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37948	7/6/2016	Room 101	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37949	7/6/2016	Room 109	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37950	7/6/2016	Room 107	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37951	7/6/2016	Room 103	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37952	7/6/2016	Room 108	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.

## INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_37953	7/6/2016	Room 106	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37954	7/6/2016	Room 212	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37955	7/6/2016	Room 211	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37956	7/6/2016	Room 209	1030	LEAD	0.035	mg/L	0.015	0.001	200.8	4072	
16_37957	7/6/2016	Room 210	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37958	7/6/2016	Room 208	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37959	7/6/2016	Upstairs Fountain	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37960	7/6/2016	Room 206	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37961	7/6/2016	Room 207	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37962	7/6/2016	Room 203	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37963	7/6/2016	Room 204	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_37964	7/6/2016	Room 201	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

**These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.**